

**Monitoring Emissions of Metals,
Solid Waste Incinerator**

8th October 2003

For inspection purposes only.
Consent of copyright owner required for any other use.

**Monitoring Emissions of Metals,
Liquid Vapour Incinerator**

7th October 2003

For inspection purposes only.
Consent of copyright owner required for any other use.

GROUP TECHNOLOGY DEVELOPMENT

DEPT. Environmental Policy



CONFIDENTIAL REPORT

Glasnevin
Dublin 9
Ireland

Tel +353 1 857 0000
+353 1 808 2000
Fax +353 1 808 2020

Client:

Title:

Novartis Ringaskiddy Ltd.
Ringaskiddy,
Co. Cork.,

Monitoring Emissions of Dioxins,
Hydrogen Fluoride and Hydrogen
Bromide from Solid Waste
Incinerator
15th March 2005

Attention: Mr. Vincent Boyton.

Report Ref: 141567-SWI-D

Order No: OP 78818

File no: R.6/30204L

Report by: Paddy Wright/Willie Kelly

For inspection purposes only.
Consent of copyright owner required for any other use.

Paddy Wright

Date recd:

Approved by: Martin Reilly

Martin Reilly

Copies to: N/A

Issue Date: 25th April 2005

Standard Terms & Conditions for Testing and Consultancy Assignments

1. Reports issued by the Technology Services Directorate of Enterprise Ireland are copyright to Enterprise Ireland and shall not be used, either in whole or in part, for the purposes of advertising, publicity or litigation without the written consent of the Chief Executive or his nominee.
2. Reports shall only be reproduced in full.
3. Non-perishable samples received for testing or laboratory work shall be disposed of after three months from date of final report unless claimed or unless instructions to the contrary have been notified to Technology Services Directorate, Enterprise Ireland by the client within the said three-month period.
4. Payment for work carried out shall be in accordance with the terms stated on Enterprise Ireland's invoices.
5. No action or legal proceeding shall be taken (except in the case of wilful neglect or default) against Enterprise Ireland or the Board or any member of the Board or any committee appointed by the Board or any officer or servant of Enterprise Ireland, by reason of or arising out of the carrying out of any research, investigation, test or analysis or the publication of the results thereof in the name of Enterprise Ireland.
6. Enterprise Ireland will not release any information received from or provided to the client in relation to this report except as may be required by law, including the Freedom of Information Act 1997, or as specified by the client.
7. The laws of Ireland whose courts shall have exclusive jurisdiction govern this contract.

CONTENTS

		Page
1.	INTRODUCTION	3
2.	SUMMARY	4
3.	RESULTS	5
4.	APPENDIX I Sampling and Analytical Methods	8
5.	APPENDIX II Explanation of TEQ	11

For inspection purposes only.
Consent to copy granted by owner required for any other use.

1. INTRODUCTION

At the request of Novartis Ringaskiddy Ltd., the Environment Department of Enterprise Ireland sampled the flue gas of the company's Solid Waste Incinerator for dioxins, hydrogen fluoride and hydrogen bromide. Samples of the ash and fly-ash were also taken from the Solid Waste Incinerator and a leachate prepared from each and the leachate analysed for dioxins.

The tests were carried out on the 15th March 2005.

This report contains the results obtained and compares them with the limits set in the company's Integrated Pollution Control Licence, Register No. 545.

Note: The survey work and preparation of this report were carried out in conjunction with Mr. Paddy Wright of Wright Environmental Services.

For inspection purposes only.
Consent of copyright owner required for any other use.

2. SUMMARY

The flue gas of the company's Solid Waste Incinerator was sampled and analysed for dioxins, hydrogen fluoride and hydrogen bromide. A sample of the ash and fly-ash were also taken from the Solid Waste Incinerator and a leachate prepared from each and the leachate analysed for dioxins.

A summary of the results is presented in Table 1 along with the emission limit values specified in the company's Integrated Pollution Control Licence.

Table 1 - Summary of Results – 15th March 2005

Test	Analytical Result (TEQ)	Concentration Dioxins (TEQ)	Emission Limit Value
Equipment Blank Dioxins (TEQ)*	0.00045ng	-	-
Flue Gas Dioxins (TEQ)	0.021ng	0.0036 ng/Nm ³	0.1 ng/Nm ³
Ash Leachate Dioxins (TEQ)	-	ND ** ng/l	-
Fly-Ash Leachate Dioxins (TEQ)	-	0.00034 ng/l	-
Hydrogen Fluoride	-	Less than 0.4 mg/Nm ³	4 mg/Nm ³
Hydrogen Bromide	-	Less than 0.5 mg/Nm ³	5 mg/Nm ³

* An explanation of TEQ is given in Appendix II.

** All 17 congeners were below the limit of detection in the leachate.

From this it can be seen that the emissions of dioxins, hydrogen fluoride and hydrogen bromide are well below the emission limit values.

3. RESULTS

The flue gas of the company's Solid Waste Incinerator (Emission Point Reference No. 3) was sampled and analysed for dioxins, hydrogen fluoride and hydrogen bromide. A blank sample was collected from the dioxin sampling equipment in the same manner as the emission test except that no gas was drawn through the sampling train, this result is used to measure any contribution from the equipment, collecting medium or washing solvents. Samples of the ash and fly-ash were also taken from the Solid Waste Incinerator and leachates prepared from each and analysed for dioxins.

Sampling and analytical methods are described in Appendix I.

The tests were carried out on the 15th March 2005 and samples for dioxin analysis were sent to Analytical and Environmental Services in the UK for analysis. Copies of their analytical reports are supplied separately. The reports are numbered D3286-3289 and D3291-3293. The samples for hydrogen fluoride and hydrogen bromide were analysed at the Enterprise Ireland laboratories.

The results are presented in Tables 2 and 3.

These results show that the emissions of dioxins, hydrogen fluoride and hydrogen bromide are well below the emission limit values (ELV) contained in the company's Integrated Pollution Control Licence.

Table 2 - Dioxins (TEQ*) - 15th March 2005

Sample No. **	Sample	Sampling Period	Analytical Result (TEQ)	Concentration Dioxins (TEQ)	ELV Dioxins (TEQ)
Sample 1	Equipment Blank Dioxins (TEQ)	18.00 on 14.3.2005 to 09.00 on 15.3.2005	0.00045ng	-	-
Sample 2	Flue Gas Dioxins (TEQ)	10.15 to 16.30 15.3.2005	0.021 ng	0.0036 ng/Nm ³	0.1 ng/Nm ³
Sample 3	Ash Leachate Dioxins (TEQ)	15.3.2005	-	ND *** ng/l	-
Sample 4	Fly-Ash Leachate Dioxins (TEQ)	15.3.2005	-	0.00034 ng/l	-

* An explanation of TEQ is given in Appendix II.

** These sample numbers identify the samples in the Analytical and Environmental Services reports.

*** All 17 congeners were below the limit of detection in the leachate.

Consent of copyright owner required for any other use.

Table 3

Hydrogen Fluoride and Hydrogen Bromide Emissions – 15th March 2005

Compound Measured	Sampling Period	Test Result mg/Nm ³	Emission Limit Value mg/Nm ³
Hydrogen Fluoride	10.23 - 11.15	Less than 0.4	4
Hydrogen Fluoride	11.19 - 12.03	Less than 0.4	4
Hydrogen Fluoride	12.07 - 12.52	Less than 0.4	4
Hydrogen Bromide	10.23 - 11.15	Less than 0.5	5
Hydrogen Bromide	11.19 - 12.03	Less than 0.5	5
Hydrogen Bromide	12.07 - 12.52	Less than 0.5	5

1 For inspection purposes only.
Consent of copyright owner required for any other use.

Appendix I
Sampling and Analytical Methods

For inspection purposes only
Consent of copyright owner required for any other use.

Sampling and Analytical Methods

Dioxins Emissions

The term dioxins is used in this report to include the 17 congeners of dioxins and dibenzofurans specified in the company's integrated pollution control licence.

The flue gas was sampled using a Graseby Anderson Universal Stack Sampler as outlined in U.S. E.P.A. Method 23. This involves drawing a measured volume of the flue gas through a heated sampling probe and filter and then through a cooled XAD 2 resin trap over a period of at least six hours. The filter and resin trap together with washings of the sampling train are collected and preserved as the sample.

This sample was analysed by Analytical and Environmental Services, Northumberland Dock Road, Wallsend, Tyne and Wear, United Kingdom.

The blank sample was collected in the same manner except that no gas was drawn through the sampling train, this result is used to measure any contribution from the equipment, collecting medium or washing solvents.

The results are expressed as ng/Nm³, dry gas corrected to 11% oxygen content.

A copy of the Analytical and Environmental Services report is supplied separately. The report is numbered D3286-3289.

Dioxins in Ash and Fly-Ash

Samples of the ash and fly-ash were collected by the company from the Solid Waste Incinerator during the emission test. These samples were sent to be analysed by Analytical and Environmental Services, Northumberland Dock Road, Wallsend, Tyne and Wear, United Kingdom. The leachates were prepared according to DIN 38414.

These leachate samples were then analysed for dioxin content. The results are expressed as ng/l of leachate.

A copy of the Analytical and Environmental Services report is supplied separately. The report is numbered D3291-3293.

Hydrogen Fluoride and Hydrogen Bromide

A measured volume of flue gas was drawn through high purity water in plastic impingers over periods of about 30 to 60mins. After each sampling period, sample collection was completed by drawing about 25mls of high purity water through the PTFE sampling probe into the impingers. The samples were returned to the Enterprise Ireland laboratories where total fluoride and bromide were determined by ion-chromatography as per method 4110B: "Determination of Anions by Ion Chromatography - Standard Methods for Examination of Water and Wastewater - 19th edition 1995".

The result is expressed as mg/Nm³, dry gas corrected to 11% oxygen content.

Standardisation of Flue Gas Emissions

The concentrations of flue gas emissions have been calculated to standard reference conditions as specified in the company's Integrated Pollution Control Licence Reg. No. 545.

- Temperature : 273 K.
- Pressure : 101.3 kPa.
- Oxygen : 11 %.
- Dry gas :

Appendix II
Explanation of TEQ

For inspection purposes only.
Consent of copyright owner required for any other use.

Toxic Equivalents

In order to assess the toxicity of complex mixtures of PCDDs (dioxins) and PCDFs (furans) the concept of toxic equivalents was devised. International Toxicity Equivalent Factors are assigned to individual dioxins and furans on the basis of how toxic they are in comparison with 2,3,7,8-TCDD, the most potent dioxin which has been assigned a value of 1.0. By comparison, animal and cell tests show that 2,3,7,8-TCDF is approximately one-tenth as toxic as 2,3,7,8-TCDD. Consequently its toxic equivalent value is 0.1.

International Toxicity Equivalent Factors have been developed for those dioxins and furans that contribute most to the toxicity of a complex mixture which are those that have chlorine substitution in at least the 2,3,7 and 8 positions. Multiplication of the concentration of a particular PCDD or PCDF by its International Toxicity Equivalent Factor therefore gives a 2,3,7,8-TCDD Toxic Equivalent. The toxicity of any mixture, relative to 2,3,7,8-TCDD is therefore the sum of individual Toxic Equivalents.

Of the 210 dioxins and furans, 17 contribute most to the toxicity of a complex mixture and are of most concern. This does not mean that the remaining 193 dioxins and furans are not toxic but that they contribute comparatively little to the toxicity of a complex mixture.

The most widely accepted Toxic Equivalent system is the NATO/CCMS system.

When measuring the emission of dioxins and furans the Environmental Protection Agency specifies that these 17 congeners should be determined. The amount of each congener found is multiplied by its Toxic Equivalent Factor and the results added together to obtain their I-TEQ (International Toxic Equivalent) or TEQ (Toxic Equivalent). The limit set in the company's Integrated Pollution Control Licence is for these 17 congeners TEQ.

Dioxin and Furan Congeners (17) and their Toxic Equivalent Factors

Compound	I-TEF
2,3,7,8-Tetrachlorodibenzodioxin (TCDD)	1
1,2,3,7,8-Pentachlorodibenzodioxin	0.5
1,2,3,4,7,8-Hexachlorodibenzodioxin (HxCDD)	0.1
1,2,3,7,8,9-Hexachlorodibenzodioxin (HxCDD)	0.1
1,2,3,6,7,8-Hexachlorodibenzodioxin (HxCDD)	0.1
1,2,3,4,6,7,8-Heptachlorodibenzodioxin (HpCDD)	0.01
Octachlorodibenzodioxin (OCDD)	0.001
2,3,7,8-Tetrachlorodibenzofuran (TCDF)	0.1
2,3,4,7,8-Pentachlorodibenzofuran (PeCDF)	0.5
1,2,3,7,8-Pentachlorodibenzofuran (PeCDF)	0.05
1,2,3,4,7,8-Hexachlorodibenzofuran (HxCDF)	0.1
1,2,3,7,8,9-Hexachlorodibenzofuran (HxCDF)	0.1
1,2,3,6,7,8-Hexachlorodibenzofuran (HxCDF)	0.1
2,3,4,6,7,8-Hexachlorodibenzofuran (HxCDF)	0.1
1,2,3,4,6,7,8-Heptachlorodibenzofuran (HpCDF)	0.01
1,2,3,4,7,8,9-Heptachlorodibenzofuran (HpCDF)	0.01
Octachlorodibenzofuran (OCDF)	0.001

Consent of copy right owner required for any other use.