Incident INCI032047 for Runways Information Services Limited Licence (P1192-01)

Notification No: INCI032047

Submitted: 22/01/2026 16:28

Licensee Details

Organisation:

Runways Information Services Limited

Licence Name:

Runways Information Services Limited

Reg No:

P1192-01

Site Address:

Slí Na Cháirde, Portan, Clonee, Meath, D15 NN9V

Notifier Details

Name:

Edward Muldowney

Address:

Meta Clonee Slí na gChairde, ,Meath,Ireland

Phone:

Email:

muldowe@meta.com

Details

Description of Incident:

The peak wastewater flow discharge rates from the Clonee Data Centre (1-3 campus) was not in compliance with the peak wastewater flow limit (m3/hour) as set out in the IE Licence (noting below). This took place on the 21st Jan 2026.

The site has received an upgraded wastewater connection agreement with Uisce Eireann that allows for a higher volume of wastewater to be released from the facility (noting that a new connection offer with higher flows was received and approved 28 Feb 2024). The wastewater discharge from the Clonee DC campus was below the compliance limits of the connection agreement. A technical amendment has been submitted to the EPA to update the existing IE licence limits to reflect those in the Irish Water / Uisce Eireann Connection Agreement. We are currently in the process of a technical amendment submission to address.

Incident Category:

Category 1

Approximate Start of Incident:

21/01/2026 04:15

First Noticed:

21/01/2026 04:15

Still Ongoing:

No

End Date:

21/01/2026 08:00

New or Recurring Incident:

New

Incident Nature:

Other

Impact of Incident on Environment:

None

Uncontrolled Release to Receptors:

Water

Details of any Vulnerable Receptors:

SE1

Likely Cause:

Adverse Weather

Incident Location

Licensed Discharge Point: No

Location Description: Clonee 1/2/3 Terminal Pumping Station, specifically where site combined (process effluent + foul) effluent exits Meta property and discharges into Uisce Eireann sewer network- SE1

Emission Parameter Results

Communication

EPA Informed by Telephone: No

EPA Informed Date:

EPA Informed Staff Member:

EPA Informed Contact Details:

Other Communications:

Additional Details

Activity in Process at time of incident:

Pumping water that was stored in our attenuation tank as requested by the inhibit signal from Uisce Eireann.

Corrective Actions Taken:

Action	Name	Date
The site has received an upgraded wastewater connection agreement with Uisce Eireann that allows for a higher volume of wastewater to be released from the facility (noting that a new connection offer with higher flows was received and approved 28 Feb 2024). The wastewater discharge from the Clonee DC campus was below the compliance limits of the connection agreement. A technical amendment has been submitted to the EPA to update the existing IE licence limits to reflect those in the Irish Water / Uisce Eireann Connection Agreement. We are currently in the process of a technical amendment submission to address.		22/01/2026 00:00

Preventive Actions to be Taken:

Action	Target Date
The site has received an upgraded wastewater connection agreement with Uisce Eireann that allows for a higher volume of wastewater to be released from the facility (noting that a new connection offer with higher flows was received and approved 28 Feb 2024). The wastewater discharge from the Clonee DC campus was below the compliance limits of the connection agreement. A technical amendment has been submitted to the EPA to update the existing IE licence limits to reflect those in the Irish Water / Uisce Eireann Connection Agreement. We are currently in the process of a technical amendment submission to address.	30/04/2026 00:00

Likelyhood of Recurrence: Low

Other Revelant Information

More details to follow