

Incident INCI031360 for Mullagh Waste Water Treatment Works Licence (D0252-01)

Notification No: INCI031360

Submitted: 13/10/2025 12:36

Licensee Details

Organisation:

Uisce Éireann

Licence Name:

Mullagh Waste Water Treatment Works

Reg No:

D0252-01

Site Address:

Cavan

Notifier Details

Name:

Aishwarya kartham

Address:

Colville House Talbot Street, Dublin,Ireland ,Dublin,Ireland

Phone:

01318925725

Email:

aishwarya.kartham@water.ie

Details

Description of Incident:

Issues with the inlet and outlet samplers in Mullagh WWTP. Following a meeting with Operations on Friday 10/10/2025 it has been reported that there are issues with the samplers in Mullagh WWTP that are under review. Further updates will issue on the resolution of the issues as they become available from site.

Incident Category:

Category 1

Approximate Start of Incident:

10/10/2025 11:00

First Noticed:

10/10/2025 11:00

Still Ongoing:

Yes

New or Recurring Incident:

New

Incident Nature:

Monitoring Equipment Issues

Impact of Incident on Environment:

NA

Uncontrolled Release to Receptors:

No

uncontrolled
release

Details of any Vulnerable Receptors:

NA

Likely Cause:

Plant or equipment breakdown at WWTP

Incident Location

Licensed Discharge Point: No

Location Description: composite samplers

Emission Parameter Results

Communication

EPA Informed by Telephone: No

EPA Informed Date:

EPA Informed Staff Member:

EPA Informed Contact Details:

Other Communications:

Additional Details

Activity in Process at time of incident:

normal activities

Corrective Actions Taken:

Action	Name	Date
Following a meeting with Operations on Friday 10/10/2025 it has been reported that there are issues with the samplers in Mullagh WWTP that are under review. Further updates will issue on the resolution of the issues as they become available from site.		10/10/2025 11:00

Preventive Actions to be Taken:

Action	Target Date
Further updates will issue on the resolution of the issues as they become available from site. In the interim grab samples will be taken from the channels.	31/10/2025 00:00

Likelihood of Recurrence: Low

Other Relevant Information

