

# IW CLARE - KILMIHIL WWTP

CE102  
Kilmihil WWTP  
Clare



**CSL**  
Deerpark Business Complex  
Dublin Road, Carlow  
Ireland  
Tel: 353 (0)59 914 3464

## J55294

**Job is Completed**

### JOB DETAILS

SCHEDULED	JOB LEAD	CREW
04/11/2021, 09:00	Sean Brennan	

**JOB TYPE:** Service

**CUSTOMER ORDER NUMBER:** 51620144

### JOB DESCRIPTION

Preventative Maintenance Service

### WORK DETAILS

NAME	DESCRIPTION	QTY
<b>FULL DESCRIPTION OF WORK DONE</b>		
<b>Notes:</b> Completed service as per sheets attached		
<b>Work Completed</b>		

**Notes:** Yes

### POST SIGNATURE

**Name of signee:** Sean Brennan

None

# IW CLARE - KILMIHIL WWTP

CE102  
Kilmihil WWTP  
Clare



**CSL**  
Deerpark Business Complex  
Dublin Road, Carlow  
Ireland  
Tel: 353 (0)59 914 3464

## J55410 Job is Completed

### JOB DETAILS

ASSET NAME	Outlet Flowmeter	ASSET LOCATION		ASSET CONTACT	
ASSET SERIAL #	05044434		CE102		
ASSET MAKE	ABB		Kilmihil WWTP		
ASSET MODEL	Watermaster		Clare		
ASSET MANUF.					
SCHEDULED	04/11/2021, 10:42	JOB LEAD	Sean Brennan	CREW	

**JOB TYPE:** Service

**CUSTOMER ORDER NUMBER:**

### JOB DESCRIPTION

### WORK DETAILS

NAME	DESCRIPTION	QTY
<b>Range</b>		
<b>Notes:</b> 0-100m3/h		
<b>Instrument Display Reading</b>		
<b>Notes:</b> 9.72m3/h		
<b>Scada Reading</b>		
<b>Notes:</b> Ok		
<b>Check Zero Point</b>		
<b>Checked?:</b> Yes		
<b>Check for damage to wires</b>	Checked	
<b>Notes:</b> Yes		
<b>Check Coil</b>		
<b>Checked?:</b> Yes		

**CSL**

Tel: 353 (0)59 914 3464

NAME	DESCRIPTION	QTY
<b>Check Transmitter Output</b>		

**Checked?:** Yes

<b>Check Transmitter Signal</b>		
---------------------------------	--	--

**Checked?:** Yes

<b>Details of Service &amp; Calibration</b>		
---	--	--

**Notes:** Checked operation of flowmeter

Zero ok

Span ok

Diagnostic clear

Signal ok

Left unit back in operation

<b>Next Calibration Due</b>		
-----------------------------	--	--

**Notes:** November 2022

**POST SIGNATURE**



**Name of signee:** Sean Brennan

None

# IW CLARE - KILMIHIL WWTP

CE102  
Kilmihil WWTP  
Clare



**CSL**  
Deerpark Business Complex  
Dublin Road, Carlow  
Ireland  
Tel: 353 (0)59 914 3464

## J55411 Job is Completed

### JOB DETAILS

ASSET NAME	Inlet Flowmeter	ASSET LOCATION	ASSET CONTACT
ASSET SERIAL #		CE102	
ASSET MAKE	ABB	Kilmihil WWTP	
ASSET MODEL	Parti Mag	Clare	
ASSET MANUF.			
SCHEDULED	JOB LEAD	CREW	
04/11/2021, 10:42	Sean Brennan		

**JOB TYPE:** Service **CUSTOMER ORDER NUMBER:**

### JOB DESCRIPTION

### WORK DETAILS

NAME	DESCRIPTION	QTY
<b>Range</b>		
<b>Notes:</b> 0-100m3/h		
<b>Instrument Display Reading</b>		
<b>Notes:</b> 13m3/h		
<b>Scada Reading</b>		
<b>Notes:</b> Na		
<b>Check Zero Point</b>		
<b>Checked?:</b> Yes		
<b>Check for damage to wires</b>	Checked	
<b>Notes:</b> Yes		
<b>Check Coil</b>		
<b>Checked?:</b> Yes		

NAME	DESCRIPTION	QTY
<b>Check Transmitter Output</b>		
<b>Checked?:</b> Yes		
<b>Check Transmitter Signal</b>		
<b>Checked?:</b> Yes		
<b>Details of Service &amp; Calibration</b>		
<p><b>Notes:</b> Checked operation of flowmeter</p> <p>Zero ok</p> <p>Span ok</p> <p>Diagnostic clear</p> <p>Signal ok</p> <p>Left unit back in operation</p>		
<b>Next Calibration Due</b>		
<b>Notes:</b> November 2022		

**POST SIGNATURE**



**Name of signee:** Sean Brennan

None