

County	Licence Ref.	Agglomeration	PE Design	PE Current	Sampling Method	Date	pH	Emmission Limit Values										
								cBOD	BOD (UWWT)	COD	COD (UWWT)	SS	SS (UWWT)	Ammonia	Total Nitrogen	Orthophosphate	Total Phosphorus	
Kilkenny	D0526-01	Freshford	320	763	Primary Discharge SW001		6.0 - 9.0	5	25	125	125	5	35	0.6		1.5		
Issued on	04/10/2013	DBO			Primary Discharge SW003 From 22/12/2015			5mg/L		125mg/L		5mg/L		0.6mg/L		1.5mg/L		
					Exceedence Limits Composite			1	100%	100%	100%	1.5	150%	20%		20%		
					Exceedence Limits Grab			1	100%	100%	100%	1.5	150%	20%		20%		
					Maximun ELV (Composite)			10	50	250	250	12.5	87.5	0.72		1.8		
					Maximum ELV (Grab)			10	50	250	250	12.5	87.5	0.72		1.8		
					Primary Discharge Monitoring (SW001)			6				6						
					Primary Discharge Monitoring (SW003)			6		6		6		6		6		
					Primary Discharge Monitoring (SW003)	Composite	25/05/2016	7.52	5	5	21	21	5	5	0.069	3.31	1.44	1.5
					Primary Discharge Monitoring (SW003)	Composite	20/07/2016	7.71	3	3	24	24	5	5	0.328	20.6	0.108	0.21
					Primary Discharge Monitoring (SW003)	Composite	13/09/2016	7.41	4	4	38	38	15	15	0.7224	23.7	0.493	0.603
					Primary Discharge Monitoring (SW003)	Composite	18/10/2016	7.46	5	5	35	35	11	11	0.144	12.1	0.286	0.718
					Primary Discharge Monitoring (SW003)	Composite	09/11/2016	7.59	4	4	29	29	13	13	2.17	20.1	0.099	0.184
					Primary Discharge Monitoring (SW003)	Composite	13/12/2016	7.61	6	6	36	36	7	7	1.88	29.4	1.48	1.55

Primary Discharge Point	Monitoring Location	Receiving Water Body
E 241087 N 1647	E 241048 N 164779	Nuenna River
E 241935 N 164408		Nuenna River