EPA Headquarters
P.O. Box 3000
Johnstown Castle Estate
County Wexford
Ireland

TECHNICAL AMENDMENT A

TO

INDUSTRIAL EMISSIONS LICENCE

Licence Register Number:	P1192-01
Company Registration Number:	553841
Licensee:	Runways Information Services Limited
Location of Installation:	Slí Na Cháirde Portan Clonee County Meath

Reasons for the Decision

The Environmental Protection Agency is satisfied, on the basis of the information available, that subject to compliance with the conditions of Licence Reg. No. P1192-01 granted on 03 October 2023 as well as any amendments noted herein, any emissions from the activity will comply with and not contravene any of the requirements of Section 83(5) of the Environmental Protection Agency Act 1992 as amended.

A screening for Appropriate Assessment was undertaken to assess, in view of best scientific knowledge and the conservation objectives of the site, if the activity, individually or in combination with other plans or projects is likely to have a significant effect on any European Site. In this context, particular attention was paid to the European Site(s) at Rye Water Valley/Carton SAC (001398), Dublin Bay South SAC (000210), North Dublin Bay SAC (000206), South Dublin Bay and River Tolka Estuary SPA (004024), North Bull Island SPA (004006) and North-west Irish Sea SPA (004236).

The activity is not directly connected with or necessary to the management of any European Site and the Agency considered, for the reasons set out below, that it can be excluded, on the basis of objective information, that the activity, individually or in combination with other plans or projects, will have a significant effect on any European Site and accordingly determined that an Appropriate Assessment of the activity was not required.

This determination has been made in light of the following reasons:

- the installation is not located within a European Site;
- the change is to the maximum permissible volumetric flow of waste water from the installation to the public sewer network, where it undergoes treatment by Uisce Éireann at the EPA licensed Ringsend Waste Water Treatment Plant (WWTP) (licence reg. no. D0034-02); and
- taking into account the nature of the change in permitted discharges to sewer from the installation, the capacity of the receiving Ringsend WWTP and the nature of the receiving environment, the changes will not have an impact on any European Sites.

Technical Amendment

In pursuance of the powers conferred on it by Section 96(1)(c) of the Environmental Protection Agency Act 1992 as amended, the Agency amends the licence, granted to Runways Information Services Limited, for an installation located at Slí Na Cháirde, Portan, Clonee, County Meath.

Henceforth, the licence must be read in conjunction with the amendment set out below.

This Technical Amendment is limited to the following Schedule:

Amendments

Amended Schedule

Amend Schedule B.3: Emissions to Sewer, of the existing licence to read as follows:

B.3 Emissions to Sewer

Emission Point Reference No.: SE1

Emission to (sewer description): UÉ Sewer at R156

Location: 703818 (E), 741332 (N)

Volume to be emitted:	Maximum in any one day:	2,726m^3
	Maximum rate per hour:	114m^3
	Maximum in any one second:	31.55l/s
	Average daily volume (over a year):	1,195 m^3/day

Parameter	**Emission Limit Value**			
Temperature	35°C (max)			
pH	6 – 10			
Toxicity	10 TU			
	Maximum Concentration Grab (mg/l)	Daily Mean Concentration (mg/l)	Maximum Load (kg/day) Note 1	Average Load (kg/day)
BOD	100	50	65	50
COD-Cr	200	100	130	100
Suspended Solids	500	250	324	250
Chloride (as Cl)	1,000	1,000	1,296	1,000
Sulphate (SO_4)	1,200	1,200	1,555	1,200
Total Hardness (as $CaCO_3$)	2,000	2,000	2,592	2,000
Fats, Oils and Greases	10	10	13	10

Note 1: In the event that the 9C Sewer is offline, trade effluent discharge must be held on-site within the 1,000 cubic meter on-site storage tank. When 9C sewer comes back online the discharge for the following 48hrs is allowable up to the maximum loadings (Maximum Load (kg/day)). For discharges other than 48 hours after the 9C Sewer being offline, the average loadings (Average Load (kg/day)) are applicable.

Emission Point Reference No.:	SE2	
Emission to (sewer description):	UÉ Sewer at R156	
Location:	703757 (E), 742022 (N)	
Volume to be emitted:	Maximum in any one day:	1,348m^3
	Maximum rate per hour:	56.2m^3
	Maximum in any one second:	15.6l/s
	Average daily volume (over a year):	500 m^3/day

Parameter	**Emission Limit Value**			
Temperature	35°C (max)			
pH	6 – 10			
Toxicity	10 TU			
	Maximum Concentration Grab (mg/l)	Daily Mean Concentration (mg/l)	Maximum Load (kg/day) Note 1	Average Load (kg/day)
BOD	100	50	67	25
COD-Cr	200	100	135	50
Suspended Solids	500	250	337	125
Chloride (as Cl)	1,000	1,000	1,348	500
Sulphate (SO_4)	1,200	1,200	1,618	600
Total Hardness (as $CaCO_3$)	2,000	2,000	2,696	1,000
Fats, Oils and Greases	10	10	13	5

Note 1: In the event that the 9C Sewer is offline, trade effluent discharge must be held on-site within the 1,000 cubic meter on-site storage tank. When 9C sewer comes back online the discharge for the following 48hrs is allowable up to the maximum loadings (Maximum Load (kg/day)). For discharges other than 48 hours after the 9C Sewer being offline, the average loadings (Average Load (kg/day)) are applicable.

This Technical Amendment must be cited as Amendment A to the licence.

Sealed by the Seal of the Agency on this the 3rd day of March 2026

PRESENT when the Seal of the Agency was affixed hereto

Kathleen Byrne, Authorised Person