

County	Licence Ref.	Agglomeration	Primary Discharge Point	Monitoring Location	Receiving Water Body					Emmission Limit Values										
										Sampling Method	Date	pH	cBOD	BOD (UWWT)	COD	COD (UWWT)	SS	SS (UWWT)	Ammonia	Total Nitrogen
Kilkenny	D0526-01	Freshford	E 241087 N 164766	E 241048 N 164779	Nuenna River	Primary Discharge SW001				20% Reduction	25		125	50% reduction	35					
Issued on	04/10/2013		E 241935 N 164408		Nuenna River	Primary Discharge SW003 From 22/12/2015				5		125		35		0.6		1.5		
DBO						Exceedence Limits Composite				100%	100%	100%	100%	150%	150%	100%		20%		
DBO						Exceedence Limits Grab				100%	100%	100%	100%	150%	150%	100%		20%		
DBO						Maximun ELV				10	50	250	250	87.5	87.5	1.2		1.8		
DBO						Primary Discharge Monitoring (SW001)				Bi-Monthly				Bi-Monthly						
DBO						Primary Discharge Monitoring (SW003)				Bi-Monthly	Bi-Monthly		Bi-Monthly	Bi-Monthly		Bi-Monthly		Bi-Monthly		
DBO						Primary Discharge Monitoring (SW003)	Composite	28/01/2020	8.3	4	4	13	13	6	6	0.02	9.03	0.55	0.65	
DBO						Primary Discharge Monitoring (SW003)	Composite	18/03/2020	7.8	2	2	7.5	7.5	2	2	0.01	7.73	0.37	0.4	
DBO						Primary Discharge Monitoring (SW003)	Composite	19/05/2020	7.7	8	8	29	29	3	3	0.05	21.5	0.56	0.69	
DBO						Primary Discharge Monitoring (SW003)	Composite	29/01/2019	7.75	2	2	10	10	3	3	0.0075	10.9	0.49	0.552	
DBO						Primary Discharge Monitoring (SW003)	Composite	27/03/2019	7.9	1	1	13	13	1	1	0.0075	11.2	0.44	0.53	
DBO						Primary Discharge Monitoring (SW003)	Composite	08/05/2019	7.9	1	1	12	12	2	2	0.03	10.4	0.58	0.63	
DBO						Primary Discharge Monitoring (SW003)	Composite	10/07/2019	7.9	5	5	39	39	12	12	0.07	13.2	1.94	2.17	
DBO						Primary Discharge Monitoring (SW003)	Composite	10/09/2019	7.6	2	2	32	32	4	4	0.05	16.1	1.87	2.03	
DBO						Primary Discharge Monitoring (SW003)	Composite	06/11/2019	7.7	2	2	14	14	3	3	0.01	9.42	0.07	0.16	