



Mountrath Road, Portlaoise, Co. Laois, Ireland R32 NXH2

Tel: +353 (57) 862 1224 · Fax: + 353 (57) 862 0723

Website: www.ids.ie · Email: info@ids.ie

11th October 2021

Test Programme

The installation of the recirculation fan environmental system has been completed in Declan Connolly's 2 houses (House ref. 3 & 4).

The recirculation fan controls are synchronised to switch on and off along with the heating system as required. The operation of the recirculation fans has been tested upon completion of installation to ensure that they are operating in conjunction with the heating system.

The Climate controls (DOL539) controls and synchronises the ventilation and heating system in the houses along with the recirculation fans. The FarmOnline system is monitoring and recording the climate as regards the temperature, humidity and CO2 as well as the heating system operation level and the ventilation level. It also records whether the recirculation fans are activated by the computer. (DOL 539).

The operation of the recirculation fans as installed can be tested/verified on an annual basis by technicians from I.D.S. when the ventilation system is being serviced.

Best regards
Gerard Kellett

Best regards
Gerard Kellett
ger@gkellettids.com
www.ids.ie
Mob : +353 87 2331325