

Incident INCI027559 for Kilmihil Licence (A0091-01)

Notification No: INCI027559

Submitted: 11/04/2024 10:58

Licensee Details

Organisation:

Uisce Éireann

Licence Name:

Kilmihil

Reg No:

A0091-01

Site Address:

Clare

Notifier Details

Name:

Paul Nolan

Address:

1 Foley Street ,Dublin,Ireland

Phone:

01 6021345

Email:

panolan@water.ie

Details

Description of Incident:

There has been a breakdown with the inlet screen onsite due to an issue with a motor. The new motor is on site and is due to be fitted as soon as possible. An update will be provided when it becomes available.

Incident Category:

Category 1

Approximate Start of Incident:

19/03/2024 00:00

First Noticed:

19/03/2024 00:00

Still Ongoing:

Yes

New or Recurring Incident:

New

Incident Nature:

Abatement equipment off-line

Impact of Incident on Environment:

No known impact

Uncontrolled Release to Receptors:

Water

Details of any Vulnerable Receptors:

Kilmihil Stream

Likely Cause:

Plant or equipment breakdown at WWTP

Incident Location

Licensed Discharge Point: No

Location Description: Inlet Screen

Emission Parameter Results

Communication

EPA Informed by Telephone: No

EPA Informed Date:

EPA Informed Staff Member:

EPA Informed Contact Details:

Other Communications:

Notified	Contact Details / Telephone	Date
Inland Fisheries Ireland	email	11/04/2024 10:51

Additional Details

Activity in Process at time of incident:

Normal

Corrective Actions Taken:

Action	Name	Date
New motor is on site and is due to be fitted.		11/04/2024 00:00

Preventive Actions to be Taken:

Action	Target Date
Repair screen	11/04/2024 00:00

Likelihood of Recurrence: Low

Other Relevant Information