



| | |
|--|---|
| Report Title | Air Emissions Compliance Monitoring Emissions Report |
| Company address | Air Scientific Ltd., Unit 3 Westlink Business Park, Clondrinagh, Limerick, V94 K6XK |
| Contact Details | Phone: 061 324587 |
| Stack Emissions Testing Report Commissioned by | Dawn Meats Ireland |
| Facility Name | Western Proteins |
| Contact Person | Brian Cloonan & Patrick Flynn |
| EPA Licence Number | P0048-03 |
| Licence Holder | Dawn Meats Ireland |
| Stack Reference Number | A1-1, A2-1 & A2-2 |
| Dates of the Monitoring Campaign | 23/05/2023 & 09/06/2023 |
| Job Reference Number | WEPRTL15230523 |
| Report Written By | Mr. Michael Healy |
| Report Approved by | Claire Boylan |
| Stack Testing Team | Mr. Michael Healy & Mr. Stephen Finn |
| Report Date | 12/07/2023 |
| Report Type | Test Report Compliance Monitoring |
| Version | 1 |
| Signature of Approver | <i>Claire Boylan.</i> Senior Quality Technician |

Contents

| | | |
|-------|---|----|
| 1.0 | Executive Summary | 3 |
| 1.1 | Overall aim of the monitoring campaign | 3 |
| 1.2 | Summary of substances to be monitored at each emission point: | 3 |
| 1.3 | Special Requirements | 3 |
| 1.4 | Summary of Results | 4 |
| | Emission Point Number: A1-1 | 4 |
| | Emission Point Number: A2-1 | 5 |
| | Emission Point Number: A2-2 | 6 |
| 1.5 | Operating Information | 7 |
| 1.6 | Monitoring Deviations | 7 |
| 1.7 | Reference Documents | 7 |
| 1.8 | Revision History | 7 |
| | Part 2: Supporting Information | 8 |
| | Appendix I | 9 |
| 1.1 | Monitoring Personnel | 9 |
| 1.2 | Equipment Inventory | 10 |
| | Appendix II | 11 |
| 2.1 | Stack Emission Point Reference: A1-1 | 11 |
| 2.1.1 | Suitability of Sample Location: | 11 |
| 2.1.2 | Stack Diagram | 12 |
| 2.1.3 | Stack Raw Data | 13 |
| 2.2 | Stack Emission Point Reference: A2-1 | 27 |
| 2.2.1 | Suitability of Sample Location: | 27 |
| 2.2.2 | Stack Diagram | 28 |
| 2.2.3 | Stack Raw Data | 29 |
| 2.3 | Stack Emission Point Reference: A2-2 | 32 |
| 2.3.1 | Suitability of Sample Location: | 32 |
| 2.3.2 | Stack Diagram | 33 |
| 2.3.3 | Stack Raw Data | 34 |
| | Appendix III: Certificates and Process Detail Form | 37 |

*Opinions and interpretations expressed herein will be outside the scope of Air Scientific Limited INAB accreditation.
This test report shall not be reproduced, without the written approval of Air Scientific Limited.
All sampling and reporting are completed in accordance with Environmental Protection Agency Air Guidance Note 2 requirements.*



1.0 Executive Summary

1.1 Overall aim of the monitoring campaign

The aim of the monitoring campaign was to demonstrate compliance with a set of emission limit values as specified in the site licence.

1.2 Summary of substances to be monitored at each emission point:

| | |
|---------------------------------------|-------------|
| Stack Name: | A1-1 |
| Total Particulate Matter | |
| Oxygen | |
| Nitrogen Oxides (as NO ₂) | |
| Sulphur Dioxide | |
| Carbon Dioxide | |
| Volumetric Flow Rate (Ref) | |

| | |
|--------------------|-------------|
| Stack Name: | A2-1 |
| Hydrogen Sulphide | |
| Mercaptans | |
| Amines | |
| Ammonia | |

| | |
|--------------------|-------------|
| Stack Name: | A2-2 |
| Hydrogen Sulphide | |
| Mercaptans | |
| Amines | |
| Ammonia | |

1.3 Special Requirements

There were no special requirements.

1.4 Summary of Results

Emission Point Number: A1-1

| Parameter | Method | Units | Result | MU +/- | Limit | O ₂ Ref. (%) | Moisture Ref. (%) | Blanks | Date | Time on | Time off | Accreditation | |
|--------------------------------|-------------|----------------------------------|--------|--------|--------|-------------------------|-------------------|--------|------------|---------|----------|---------------|----------|
| | | | | | | | | | | | | Sampling | Analysis |
| Total Particulate Matter (TPM) | EN13284 | mg.m ⁻³ | 8.78 | 0.53 | 50 | 3 | Dry | <1.08 | 23/05/2023 | 12:10 | 12:44 | Yes | Yes |
| Volumetric Flow Rate (Ref) | EN 16911 | m ³ .hr ⁻¹ | 6,120 | 1,596 | 25,000 | 3 | Dry | N/a | 23/05/2023 | 12:10 | 12:44 | Yes | N/a |
| Nitrogen Oxides | EN 14792 | mg.m ⁻³ | 351.7 | 21.1 | 450 | 3 | Dry | N/a | 23/05/2023 | 11:06 | 11:36 | Yes | N/a |
| Sulphur Dioxide | EN/TS 17021 | mg.m ⁻³ | 3.5 | 1.9 | 1700 | 3 | Dry | N/a | 23/05/2023 | 11:06 | 11:36 | Yes | N/a |
| Carbon Monoxide | EN 15058 | mg.m ⁻³ | 3.5 | 2.1 | 80 | 3 | Dry | N/a | 23/05/2023 | 11:06 | 11:36 | Yes | N/a |
| Carbon Dioxide | EN/TS 17045 | vol% | 10.70 | 0.3 | N/a | N/a | Dry | N/a | 23/05/2023 | 11:06 | 11:36 | Yes | N/a |
| Oxygen | EN 14789 | vol% | 4.42 | 0.3 | N/a | N/a | Dry | N/a | 23/05/2023 | 11:06 | 11:36 | Yes | N/a |

Note 1: All results are normalised to standard temperature and pressure (0°C and 101.3kPa)

Note 2: All results are reported in the format as defined by the EPA in guidance note AG2:2021.

Emission Point Number: A2-1

| Parameter | Method | Units | Result | MU +/- | Limit | O ₂ Ref. (%) | Moisture Ref. (%) | Blanks | Date | Time on | Time off | Accreditation | |
|-------------------|----------|-------|--------|--------|-------|-------------------------|-------------------|--------|------------|---------|----------|---------------|----------|
| | | | | | | | | | | | | Sampling | Analysis |
| Ammonia | EN 13649 | ppm | 3.06 | 0.16 | 50 | N/a | N/a | <0.1 | 23/05/2023 | 13:00 | 13:30 | No | Yes |
| Hydrogen Sulphide | Drager | ppm | 0 | N/a | 5 | N/a | N/a | N/a | 23/05/2023 | 13:00 | 13:30 | No | No |
| Mercaptans | Drager | ppm | 0 | N/a | 5 | N/a | N/a | N/a | 23/05/2023 | 13:00 | 13:30 | No | No |
| Amines | Drager | ppm | 0 | N/a | 5 | N/a | N/a | N/a | 23/05/2023 | 13:00 | 13:30 | No | No |

Note 1: All results are normalised to standard temperature and pressure (0°C and 101.3kPa)
 Note 2: All results are reported in the format as defined by the EPA in guidance note AG2:2021.

Emission Point Number: A2-2

| Parameter | Method | Units | Result | MU +/- | Limit | O ₂ Ref. (%) | Moisture Ref. (%) | Blanks | Date | Time on | Time off | Accreditation | |
|-------------------|----------|-------|--------|--------|-------|-------------------------|-------------------|--------|------------|---------|----------|---------------|----------|
| | | | | | | | | | | | | Sampling | Analysis |
| Ammonia | EN 13649 | ppm | 0.06 | 0.003 | 50 | N/a | N/a | <0.1 | 23/05/2023 | 14:30 | 15:00 | No | Yes |
| Hydrogen Sulphide | Drager | ppm | 0 | N/a | 5 | N/a | N/a | N/a | 23/05/2023 | 14:30 | 15:00 | No | No |
| Mercaptans | Drager | ppm | 0 | N/a | 5 | N/a | N/a | N/a | 23/05/2023 | 14:30 | 15:00 | No | No |
| Amines | Drager | ppm | 0 | N/a | 5 | N/a | N/a | N/a | 23/05/2023 | 14:30 | 15:00 | No | No |

Note 1: All results are normalised to standard temperature and pressure (0°C and 101.3kPa)
 Note 2: All results are reported in the format as defined by the EPA in guidance note AG2:2021.

1.5 Operating Information

Please reference Process Details as per Appendix III attached.

1.6 Monitoring Deviations

| Stack Name: A1-1 | |
|---------------------------------------|--|
| Parameter | Deviation |
| Total Particulate Matter | Differential Pressure <5Pa, constant flow testing carried out. |
| Oxygen | None |
| Nitrogen Oxides (as NO ₂) | None |
| Sulphur Dioxide | None |
| Carbon Dioxide | None |
| Volumetric Flow Rate (Ref) | EN 16911 - in accordance with MID 16911-1 |

| Stack Name: A2-1 | |
|------------------|-----------|
| Parameter | Deviation |
| H ₂ S | None |
| Mercaptans | None |
| Amines | None |
| Ammonia | None |

| Stack Name: A2-2 | |
|------------------|-----------|
| Parameter | Deviation |
| H ₂ S | None |
| Mercaptans | None |
| Amines | None |
| Ammonia | None |

1.7 Reference Documents

| | |
|------------------------------|----------|
| Risk Assessment (RA) | SOP 1011 |
| Site Review (SR) | SOP 1015 |
| Site Specific Protocol (SSP) | SOP 1015 |

1.8 Revision History

| Revision Number | Changes to the report |
|-----------------|--------------------------------|
| 1 | Original version of the report |

| Part 2: Supporting Information | |
|--|---|
| Report Title | Air Emissions Compliance Monitoring Emissions Report |
| Company address | Air Scientific Ltd., Unit 3 Westlink Business Park, Clondrinagh, Limerick, V94 K6XK |
| Stack Emissions Testing Report Commissioned by | Dawn Meats Ireland |
| Facility Name | Western Proteins |
| Contact Person | Brian Cloonan & Patrick Flynn |
| EPA Licence Number | P0048-03 |
| Licence Holder | Dawn Meats Ireland |
| Stack Reference Number | A1-1, A2-1 & A2-2 |
| Dates of the Monitoring Campaign | 23/05/2023 & 09/06/2023 |
| Job Reference Number | WEPRTL15230523 |
| Report Written By | Mr. Michael Healy |
| Report Approved by | Claire Boylan |
| Stack Testing Team | Mr. Michael Healy & Mr. Stephen Finn |
| Report Date | 12/07/2023 |
| Report Type | Test Report Compliance Monitoring |
| Version | 1 |
| Signature of Approver | <i>Claire Boylan.</i> Senior Quality Technician |



Appendix I

1.1 Monitoring Personnel

| | | |
|-------------|-----------------|--------------------------|
| Team Leader | Name | Michael Healy |
| | System approval | ASL Team Leader Approved |
| Technician | Name | Stephen Finn |
| | System approval | ASL Technician Approved |

1.2 Equipment Inventory

| ID | Item of Equipment | Used | ID | Item of Equipment | Used | ID | Item of Equipment | Used |
|--------------|------------------------|------|--------------|----------------------|------|--------------|--------------------|------|
| ASLLK12EQ500 | Pump | | ASLLK12EQ525 | Horiba (PG-250) X | | ASLLK13EQ501 | Vernier Calipers | |
| ASLLK12EQ532 | Pump | | ASLLK16EQ508 | Horiba- PG250z | | ASLLK14EQ503 | Vernier Calipers | x |
| ASLLK12EQ536 | Pump | | ASLLK14EQ501 | Horiba-PG 350 | X | ASLLK14EQ507 | Vernier Calipers | |
| ASLLK12EQ537 | Pump | | ASLLK17EQ515 | Horiba 350 | | ASLLK17EQ533 | Vernier Calipers | |
| ASLLK12EQ538 | Pump | | ASLLK20EQ506 | Horiba 350 | | ASLLK18EQ506 | Vernier Calipers | |
| ASLLK12EQ542 | Pump | | ASLLK21EQ503 | Horiba 350 | | ASLLK20EQ516 | Vernier Calipers | |
| ASLLK12EQ543 | Pump | | ASLLK21EQ522 | Horiba 350 | | | | |
| ASLLK13EQ514 | Pump | | | | | | | |
| ASLLK16EQ518 | Pump | | | | | ASLLK13EQ503 | 1kg weight | |
| ASLLK16EQ519 | Pump | | ASLLK12EQ526 | Chiller | | ASLLK13EQ508 | 500g Hafner weight | |
| ASLLK17EQ509 | Pump | | ASLLK14EQ513 | Chiller | X | ASLLK13EQ509 | 500g Hafner weight | |
| ASLLK17EQ510 | Pump | | ASLLK16EQ509 | Chiller | | ASLLK14EQ515 | 500g Weight | |
| ASLLK17EQ522 | Pump | | ASLLK18EQ505 | Chiller | | ASLLK15EQ511 | 1kg Weight | |
| ASLLK17EQ523 | Pump | | ASLLK21EQ504 | Chiller | | ASLLK15EQ512 | 1kg weight | |
| ASLLK17EQ524 | Pump | | ASLLK22EQ509 | Chiller | | ASLLK16EQ511 | 1kg weight | X |
| ASLLK17EQ525 | Pump | | | | | ASLLK16EQ512 | 500g weight | X |
| ASLLK17EQ526 | Pump | | | | | ASLLK17EQ529 | 500g weight | |
| ASLLK18EQ517 | Pump | | ASLLK14EQ518 | Velocity Meter | | ASLLK17EQ530 | 1kg weight | |
| ASLLK18EQ518 | Pump | | ASLLK16EQ501 | Velocity Meter | | ASLLK19EQ513 | 500g weight | |
| ASLLK21EQ507 | Pump | | ASLLK17EQ508 | Velocity Meter | | ASLLK19EQ514 | 1kg Weight | |
| ASLLK21EQ508 | Pump | | ASLLK17EQ514 | Velocity Meter | | ASLLK19EQ519 | 1kg weight | |
| ASLLK21EQ509 | Pump | | ASLLK18EQ504 | Velocity Meter | | ASLLK19EQ520 | 500g weight | |
| ASLLK21EQ510 | Pump | | ASLLK19EQ502 | Velocity Meter | | | | |
| ASLLK21EQ511 | Pump | | ASLLK20EQ504 | Velocity Meter | | | | |
| ASLLK22EQ500 | Pump | | | | | ASLLK17EQ534 | ST5 | |
| ASLLK22EQ501 | Pump | | ASLLK20EQ513 | Anemometer (Hotwire) | | ASLLK18EQ503 | ST5 | |
| ASLLK22EQ502 | Pump | | ASLLK21EQ528 | TSI (Vane) | | ASLLK18EQ513 | ST5 | |
| ASLLK22EQ503 | Pump | | | | | ASLLK19EQ509 | ST5 | x |
| ASLLK22EQ504 | Pump | X | | | | ASLLK20EQ500 | ST5 | |
| ASLLK22EQ505 | Pump | | ASLLK16EQ502 | FID | | ASLLK21EQ519 | ST5 | |
| | | | ASLLK17EQ517 | FID | | ASLLK22EQ508 | ST5 | |
| | | | ASLLK19EQ508 | FID | | | | |
| ASLLK21EQ500 | MF Meter | | ASLLK20EQ507 | FID | | | | |
| ASLLK21EQ501 | MF Meter | | ASLLK20EQ508 | FID | | ASLLK14EQ510 | Digital Protractor | x |
| ASLLK21EQ502 | MF Meter | | ASLLK17EQ535 | Signal Cutter | | ASLLK14EQ511 | Digital Protractor | |
| ASLLK21EQ526 | MF Meter | | | | | ASLLK17EQ528 | Digital Protractor | |
| ASLLK21EQ530 | MF Meter | | | | | ASLLK18EQ507 | Digital Protractor | |
| ASLLK21EQ531 | MF Meter | | ASLLK16EQ510 | Measuring Tape | X | ASLLK20EQ514 | Digital Protractor | |
| ASLLK22EQ515 | MF Meter | x | ASLLK17EQ527 | Measuring Tape | | ASLLK20EQ515 | Digital Protractor | |
| | | | ASLLK18EQ508 | Measuring Tape | | | | |
| ASLLK14EQ514 | Heated Line | | ASLLK19EQ516 | Measuring Tape | | | | |
| ASLLK17EQ502 | Heated Line | | ASLLK20EQ509 | Measuring Tape | | ASLLK12EQ522 | Balance | |
| ASLLK17EQ503 | Heated Line | | ASLLK21EQ521 | Measuring Tape | | ASLLK15EQ509 | Balance | |
| ASLLK17EQ539 | Heated Line (5m) | | | | | ASLLK15EQ510 | Balance | |
| ASLLK19EQ523 | Heated Line | | | | | ASLLK17EQ537 | Balance | |
| ASLLK20EQ520 | Heated Line | X | ASLLK20EQ519 | PCDD Thermometer | | ASLLK19EQ515 | Balance | |
| ASLLK20EQ521 | Heated Line | | | | | ASLLK21EQ505 | Balance | |
| ASLLK21EQ523 | Heated Line (5m) | | ASLLK16EQ515 | Thermocouple K type | | ASLLK21EQ506 | Balance | x |
| ASLLK21EQ524 | Heated Line (5m) | | ASLLK16EQ516 | Thermocouple K type | | ASLLK21EQ525 | Balance | |
| ASLLK22EQ510 | Heated Line (40m) | | ASLLK21EQ513 | K type Thermocouple | X | ASLLK21EQ529 | Balance | |
| ASLLK22EQ512 | Heated Line (5m) | | ASLLK21EQ514 | K type Thermocouple | | | | |
| ASLLK22EQ513 | Heated Line (5m) | | ASLLK21EQ515 | K type Thermocouple | | | | |
| | | | ASLLK21EQ516 | K type Thermocouple | | | | |
| ASLLK12EQ518 | S type Pitot Tube | | ASLLK21EQ517 | K type Thermocouple | | | | |
| ASLLK12EQ520 | L Type Pitot tube | | ASLLK21EQ518 | K type Thermocouple | | | | |
| ASLLK13EQ506 | S type Pitot Tube | | ASLLK21EQ520 | K type Thermocouple | | | | |
| ASLLK14EQ506 | 1m S type & K type | | | | | | | |
| ASLLK16EQ506 | S type Pitot Tube | | | | | | | |
| ASLLK16EQ517 | S type Pitot Tube Long | | ASLLK17EQ519 | Stopwatch | X | | | |
| ASLLK17EQ507 | 1m S type & K type | | ASLLK17EQ520 | Stopwatch | | | | |
| ASLLK17EQ536 | S type Pitot Tube | | ASLLK17EQ521 | Stopwatch | | | | |
| ASLLK18EQ514 | S type Pitot Tube | | ASLLK18EQ509 | Stopwatch | | | | |
| ASLLK18EQ515 | S type Pitot Tube | | ASLLK19EQ518 | Stopwatch | | | | |
| ASLLK19EQ510 | S type pitot tube | | ASLLK21EQ512 | Stopwatch | | | | |
| ASLLK19EQ511 | S type pitot tube | | | | | | | |
| ASLLK19EQ521 | 1m S type & K type | | | | | | | |
| ASLLK19EQ522 | Pitot | | | | | | | |
| ASLLK22EQ506 | S type pitot tube | x | | | | | | |
| ASLLK22EQ507 | S type pitot tube | | | | | | | |
| ASLLK22EQ511 | S type pitot tube | | | | | | | |

Appendix II

2.1 Stack Emission Point Reference: A1-1

2.1.1 Suitability of Sample Location:

| | |
|---------------------|-----------|
| General Information | A1-1 |
| Permanent/Temporary | Permanent |
| Inside/ Outside | Outside |

| Platform Details | | |
|---|-------|---------|
| Irish EPA Technical Guidance Note AG1 / BS EN 15259 Platform Requirements | Value | Comment |
| Sufficient Working area to manipulate probe and measuring instruments | Yes | - |
| Platform has 2 handrails (approx. 0.5m & 1.0 m high) | Yes | - |
| Platform has vertical base boards (approx. 0.25 m high) | Yes | - |
| Platform has chains / self-closing gates at top of ladders | Yes | - |
| There are no obstructions present which hamper insertion of sampling equipment | Yes | - |
| Safe Access Available | Yes | - |
| Easy Access Available | Yes | - |
| Sampling Location / Platform Improvement Recommendations | | |
| None | | |
| EN 15259 Homogeneity Test Requirements | | |
| 1 | | |
| Select Option: | | |
| 1: There is no requirement to perform a BSEN15259 Homogeneity Test on this stack 2: Test results were obtained from previous Homogeneity test carried out by ASL 3: Test results were obtained from previous Homogeneity test carried out by Alternative contractor 4: Homogeneity Test is required on this stack and the client has been informed of this requirement | | |

2.1.2 Stack Diagram



Figure 1: A1-1

2.1.3 Stack Raw Data

| | | | | |
|---------------------------------|--|----------------------------|--------|-------------------------------------|
| Title: | Determination of Total Particulates | | | |
| Method: | EN 13284-1 | | | |
| Client: | Western Proteins | | | |
| Test Date: | 23/05/2023 | Air Volume at Pump | 0.7967 | m ³ |
| Test Time | 12:10 | Temperature at Pump | 17.43 | Deg C |
| Laboratory Used: | RPS | Pressure at Pump | 80.02 | kPa |
| Stack Name | A1-1 | Humidity at Pumps | 0 | % |
| Run I.D. | 1 | Filter Weight | 3.38 | mg |
| Filter I.D. | 253220 | Front End Weight | 1 | mg |
| Moisture Content | 8.82 | | | % |
| Reference Oxygen | 3 | Flow Uncertainty | 1.596 | m ³ /hr |
| Measured Oxygen | 5.81 | Flow Uncertainty | 26.1 | % |
| Stack Flow Rate | 7962 | | | Nm ³ /hr |
| Adjusted Stack Flow Rate | 6120.09 | | | Nm ³ /hr, dry @ % Oxygen |
| Volume of Air Sampled | 0.5915 | | | Nm ³ |

| | | | | |
|--|---------------|---|-----------------------------------|---|
| Leak Check Results | Result | | % Leak | |
| Before Sample 1 | 0 | l/min | 0.0 | |
| Average Flow Rate | 20.00 | l/min | 0.0 | |
| Standard Maximum | 0.4 | l/min | 2% | |
| Back Pressure | 69.95 | kPa | | |
| Standard Criteria to be Met | Result | Std. Requirement | | |
| Angle of Flow | Yes | <15 Degrees | Probe material | Stainless Steel |
| Negative Flow in the Stack | Yes | None | Filter housing | Stainless Steel |
| Pitot Pressure Difference | No | >5Pa | Positioning of filter | In Stack |
| Ratio of Flow Measurement | Yes | <3:1 | Filter Size & Material | 47mm Quartz |
| Stagnation Test | Yes | <10Pa | | |
| Pitot Tube Leak Check | Result | | | |
| Positive Pressure | Pass | - | | |
| Negative Pressure | Pass | - | | |
| Number of Ports | 2 | 2 | | |
| Straight length before sample point | Yes | > 5 Hydraulic Diameters | | |
| Straight length after sample point | Yes | > 5 Hydraulic Diameters to Stack Outlet or 2HD to Fan/ Bend | | |
| Sample Calculations | | | | |
| Blank (Filter and Front Wash Combined) | 0.54 | mg | | |
| Sample 1 (Filter and Front Combined) | 4.38 | mg | | |
| Volume of Air Sampled | 0.5915 | Nm ³ | | |
| Blank Result | 0.91 | mg/Nm ³ dry | 1.08 | mg/Nm ³ dry @ Ref O ₂ |
| Sample Result | 7.40 | mg/Nm ³ dry | 8.78 | mg/Nm ³ dry @ Ref O ₂ |
| Uncertainty of Measurement | 0.53 | mg/Nm ³ | | |
| Emission Limit Value | 50 | mg/Nm ³ | | |
| Blank as Percentage of ELV | 1.8 | % | Requirement | <10% ELV or <0.5 mg/m ³ |

| | | |
|--|-------------|---|
| Isokinetic Criterion Compliance | | |
| Isokinetic Variation | - | % |
| Allowable Isokinetic Range | -5 to + 15% | % |
| Isokinetic Acceptable | - | |

| | | | | |
|------------------------------------|----------------|-----------------|---------------------------|-----|
| Balance Calibration | Weight | 0 | | |
| 0 | 0 | g | Eccentric load indication | Yes |
| 500 | 500 | g | carried out - Balance Ok | |
| 1000 | 1000 | g | | |
| Impinger Weights | Initial | Final | Difference | |
| Total Impinger Weight | 2195.8 | 2241.8 | 46 | |
| Volume of Air Sampled | 0.5915 | Nm ³ | 46 | |
| Moisture Content (EN 14790) | 8.82 | % | | |

DUCT AND GAS SPECIFICATION

| | | | |
|------------------------|-----------------|-----------------------|----------|
| Name | | | a1-1 |
| Section | | | Circular |
| Diameter | | [m] | 1.27 |
| Area | | [m ²] | 1.266769 |
| Ports | | [#] | 2 |
| Points | P | [#] | 6 |
| Density | pn | [kg/Nm ³] | 1.333 |
| Carbon Dioxide | CO ₂ | [%] | 10.7 |
| Oxygen | O ₂ | [%] | 4.42 |
| Water Vapor Ratio | rw | [0:1] | 0.1 |
| Nozzle | nz | [mm] | 15 |
| Turbulence factor | ft | [sec] | 1 |
| Wall Adjustment Factor | waf | | |

PITOT DATA SPECIFICATION

| | | | |
|----------|---------|----|------|
| Name | | | |
| Velocity | [m/sec] | 5 | 0.83 |
| Velocity | [m/sec] | 10 | 0.83 |
| Velocity | [m/sec] | 20 | 0.83 |
| Velocity | [m/sec] | 30 | 0.83 |
| Velocity | [m/sec] | 40 | 0.83 |

NORMALIZATION FACTOR

| | | | |
|-------|--|-------|-------|
| Tnorm | | [K] | 273 |
| Pnorm | | [kPa] | 101.3 |

DUCT FLOW RATE

| | | | |
|---------------------------|------|----------------------|-------|
| Dry actual | QVa | [m ³ /h] | 13465 |
| Moist actual | Q'Va | [m ³ /h] | 14962 |
| Moist norm. [Tnorm Pnorm] | Q'Vn | [Nm ³ /h] | 7962 |
| Dry norm. [Tnorm Pnorm] | QVn | [Nm ³ /h] | 7165 |

AVERAGE VALUES

| | | | |
|--------------------|---------|---------|--------|
| Total Points | | [#] | 2 |
| Velocity | v'a | [m/sec] | 3.3 |
| Stack temperature | tstack | [°C] | 244.58 |
| Stack Pressure | Pa | [kPa] | 102.2 |
| Isokinetic Rate | DI | [%] | - |
| Velocity at nozzle | v'N | [m/sec] | 3.924 |
| Probe temperature | tprobe | [°C] | 20.3 |
| Filter temperature | tfilter | [°C] | 29.1 |
| Outlet temperature | toutlet | [°C] | 50.1 |
| Aux temperature | taux | [°C] | 28.7 |
| Ambient Pressure | Pamb | [kPa] | 102.29 |

GAS METER SAMPLED VOLUMES

| | | | |
|----------------------------------|------|--|----------|
| Elapsed time | et | | 00:30:00 |
| Norm. Volume [Tnorm Pnorm] | Vgn | | 0.5915 |
| Moist Volume at stack conditions | V'ga | | 1.2351 |
| Volume at dgm conditions | Vdgm | | 0.7967 |
| Gas meter temperature | tdgm | | 17.43 |
| Gas Meter Pressure | Pdgm | | 80.02 |

| Uncertainty calculation for EN 13284 | | | | | |
|---|------------------|--------------------|---------------|-----------------|------------------------|
| | Symbol | Unit | Values | UOM as % | Std Requirement |
| Sampled Volume | V _m | m ³ | 0.001 | 0.13 | <=5% |
| Sampled gas Temperature | T _m | k | 2.00 | 0.69 | <=2% |
| Sampled gas Pressure | ρ _m | kPa | 1.00 | 1.25 | <=2% |
| Sampled gas Humidity | H _m | % by volume | 1.00 | 1.00 | <=1% |
| Oxygen content | O _{2,m} | % by volume | 0.10 | - | <=5% |
| Mass particulate | m | mg | 0.102 | 2.34 | <5% of limit value |
| Leak | L | | - | 0.00 | <=2% |
| Uncollected Mass | UCM | | - | 0.00 | <10% of limit value |
| | | | | | |
| Corrected Volume (STP) | V | m ³ | 0.59 | 1.75 | - |
| Mass | m | mg | 4.38 | 2.34 | - |
| Factor for O2 Correction | fc | | 1.18 | 0.66 | - |
| Leak | L | mg.m ⁻³ | 0.00 | 0.00 | - |
| Uncollected mass | UCM | mg | 0.00 | 0.00 | - |
| Combined measurement uncertainty | | | 0.26 | - | - |
| | | | | | |
| Expanded uncertainty as percentage of measured value | | | | 5.99 | % measured of value |
| Expanded uncertainty in units of measurement | | | | 0.53 | mg.m ⁻³ |
| Expanded uncertainty as percentage of limit value | | | | 1.05 | % ELV |

| Uncertainty calculation for Velocity and Volume Flow Rate Measurement by Pitot tube EN ISO 16911-1 | | | | | |
|---|----------------------|-------------|-------------|-----------------|---|
| | Unit | Values | as % | Std Requirement | |
| Range of Delta P transducer | Pa | 2500 | - | | - |
| Resolution of Delta P transducer | Pa | 10 | - | | - |
| Repeatability of Delta P transducer | % of value | 0.01 | - | | - |
| Drift of Delta P transducer | % of range | 0.32 | - | | - |
| Lack of fit of measurement system | % of range | 0.25 | - | | - |
| Uncertainty in Delta P transducer | Pa | 2.5 | - | | - |
| Uncertainty of pitot coefficient | | 0.03 | - | | - |
| Enter uncertainties as (95%,k=2) where relevant | | | | | |
| Uncertainty in temperature readout system | °C | 1 | - | | - |
| Uncertainty in atmospheric pressure transducer | Pa | 160.5 | - | | - |
| Uncertainty in duct area measurement | % | 1.0 | - | | - |
| Uncertainty of Molar Mass | kg/mol | 0.00001 | 0.05 | | - |
| Uncertainty of Temperature | K | 0.5 | 0.10 | | - |
| Uncertainty of Stack Static Pressure | Pa | 10.22 | 0.01 | | - |
| Uncertainty of Stack Pressure | Pa | 160.8 | 0.08 | | - |
| Uncertainty of Gas Density | kg/m ³ | 0.0017 | 0.13 | | - |
| | | | | | |
| Uncertainty in velocity | m/sec | 0.43 | 13.0 | | - |
| Expanded Uncertainty in velocity | m/sec | 0.86 | 26.0 | | - |
| Uncertainty of Volumetric Flow Rate | m ³ /hour | 798 | - | | - |
| Expanded Uncertainty of Volumetric Flow Rate | m ³ /hour | 1596 | 26.1 | <10% of ELV | |


| | | | | | | |
|---|--|--------------------------|------------------------|-----------------|-----------------------|----------------------|
| Title: | <u>Determination of Flue Gases</u> | | | | | |
| Method: | EN 14792 / TS 17021 / EN 15058 / TS 17045 / EN 14789 | | | | | |
| Test Date: | 23/05/2023 | | | | | |
| Stack Name: | A1-1 | Quality Assurance | | | | |
| Test Start Time: | 11:06 | Probe Material | | Stainless Steel | | |
| Reference Conditions | | Filtration Type/size | | Stainless Steel | | |
| Measured Oxygen | 4.42 | % | Heated Filter used | Yes | | |
| Reference Oxygen | 3 | % | No. of sampling lines | 1 | | |
| Reference Moisture | 0 | | No. of Sampling points | 1 | | |
| | | | Sampling point I.D.s | 1 | | |
| Parameter | | NO | SO2 | CO | CO₂ | O₂ |
| Emission Limit Values | mg.m ⁻³ ref | 450 | 1700 | 80 | - | - |
| Instrument Range | ppm | 500 | 200 | 200 | 30% | 25.00% |
| Span Gas Value | ppm | 434 | 154 | 151 | 16.15% | 20.90% |
| Acceptable Gas Range | - | Yes | Yes | Yes | Yes | Yes |
| Calibration Gas Reference No. | - | 22ING244 | 22ING219 | 21ING603 | 19ING559 | - |
| Calibration Gas Uncertainty | % | 1.2 | 1.2 | 1.5 | 0.9 | 0.35 |
| Calibration Gas Start Bar | Bar | 55 | 30 | 45 | 25 | - |
| Expiry Date | - | Oct-23 | Jun-24 | Jul-24 | Jul-23 | - |
| Quality Assurance | Units | NO | SO2 | CO | CO₂ | O₂ |
| Conditioning Unit Temperature | C | 2 | 2 | 2 | 2 | 2 |
| Average Temperature | < C | 2 | 2 | 2 | 2 | 2 |
| Allowable Temperature | - | 4 | 4 | 4 | 4 | 4 |
| Temperature Acceptable | - | Yes | Yes | Yes | Yes | Yes |
| Pump flow rate | l/min. | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Instrument Zero Drift | Units | NO | SO2 | CO | CO₂ | O₂ |
| Instrument Zero (Ambient air or Nitrogen) | | Nitrogen | Nitrogen | Nitrogen | Nitrogen | Nitrogen |
| Instrument Zero (Pre) | ppm | 0 | 0 | 0 | 0.00% | 0.00% |
| Instrument Zero (Check) | ppm | 0 | 2 | 0 | 0.02% | 0.06% |
| Compliance Statement | Pass / Fail | Pass | Pass | Pass | Pass | Pass |
| Instrument Zero (Post) | ppm | 0 | 0.9 | 2 | 0.03% | 0.11% |
| Zero Drift | ppm | 0 | 0.9 | 2 | 0.03% | 0.11% |
| Allowable Zero Drift (Less than 2%) | ppm equiv. | 8.7 | 3.1 | 3.0 | - | 0.42% |
| Adjustable Zero Drift (2 - 5%) / 5% CO ₂ | ppm equiv. | 21.7 | 7.7 | 7.6 | 0.81% | 1.05% |
| Zero Drift Failure (<5% / >5% CO ₂) | ppm equiv. | 21.7 | 7.7 | 7.6 | 0.81% | 1.05% |
| Zero Drift Acceptable | - | Yes | Yes | Yes | Yes | Yes |
| Adjust for Zero Drift | - | No | No | No | No | No |
| Reject results | - | No | No | No | No | No |
| Calculated Drift | % | 0.0% | 0.6% | 1.3% | 0.2% | 0.5% |
| Instrument Span Drift | Units | NO | SO2 | CO | CO₂ | O₂ |
| Instrument Span Down (Pre) | ppm | 434 | 154 | 151 | 16.15% | 20.90% |
| Instrument Check Span (Post) | ppm | 436 | 155 | 151 | 16.02% | 20.99% |
| Span Drift | ppm | 2 | 1 | 0 | -0.13% | 0.09% |
| Allowable Span Drift (less than 2%) | ppm equiv. | 8.68 | 3.08 | 3.02 | 0.32% | 0.42% |
| Adjustable Span Drift (2 - 5%) | ppm equiv. | 21.7 | 7.7 | 7.55 | 0.81% | 1.05% |
| Span Drift Failure (Greater than 5%) | ppm equiv. | 21.7 | 7.7 | 7.55 | 0.81% | 1.05% |
| Span Drift Acceptable (Y/N) | - | Yes | Yes | Yes | Yes | Yes |
| Adjust for Span Drift | - | No | No | No | No | No |
| Reject results | - | No | No | No | No | No |
| Calculated Drift | % | 0.5% | 0.6% | 0.0% | -0.8% | 0.4% |
| Heated Line Check Including Leak Check | | NO | SO2 | CO | CO₂ | O₂ |
| Span Gas Conc. | ppm | 434 | 154 | 151 | 16.15% | 20.90% |
| Zero Check Acceptable Limit (+/-) | ppm | 8.68 | 3.08 | 3.02 | 0.32% | 0.42% |
| Heated Line Check Zero Gas | ppm | 0 | 1 | 1 | 0.01% | 0.28% |
| Compliance Statement | Pass / Fail | Pass | Pass | Pass | Pass | Pass |
| Heated Line Check Span Gas | ppm or % | 433 | 152 | 149 | 16.00% | 20.92% |
| Span Gas Leak Detected | ppm or % | -1 | -2 | -2 | -0.15% | 0.02% |
| Leak check acceptable (< 2%) | ppm or % | 8.68 | 3.08 | 3.02 | 0.32% | 0.42% |
| Compliance Statement | Pass / Fail | Pass | Pass | Pass | Pass | Pass |
| Response Time (<200 seconds) | | Yes | Yes | Yes | Yes | Yes |
| Test Conditions | Units | | | | | |
| Run Ambient Temperature Range | C | 12 | | | | |

Raw Data

| <i>Date/Time</i> | <i>NOx ppm</i> | <i>SO₂ ppm</i> | <i>CO ppm</i> | <i>CO₂ vol%</i> | <i>O₂ vol%</i> |
|------------------|--------------------|-------------------------------|-------------------|--------------------------------|-------------------------------|
| 23/05/2023 11:06 | 153.275 | 1.150 | 3.625 | 10.518 | 4.972 |
| 23/05/2023 11:07 | 152.125 | 1.175 | 4.250 | 10.527 | 4.813 |
| 23/05/2023 11:08 | 166.850 | 1.083 | 5.000 | 10.863 | 4.239 |
| 23/05/2023 11:09 | 155.058 | 1.100 | 3.583 | 10.610 | 4.547 |
| 23/05/2023 11:10 | 154.233 | 1.267 | 3.167 | 10.620 | 4.574 |
| 23/05/2023 11:11 | 159.242 | 1.017 | 2.917 | 10.726 | 4.448 |
| 23/05/2023 11:12 | 155.725 | 0.975 | 2.917 | 10.648 | 4.514 |
| 23/05/2023 11:13 | 157.875 | 1.042 | 2.583 | 10.679 | 4.439 |
| 23/05/2023 11:14 | 159.650 | 1.083 | 2.750 | 10.741 | 4.377 |
| 23/05/2023 11:15 | 156.442 | 1.017 | 2.250 | 10.717 | 4.403 |
| 23/05/2023 11:16 | 157.083 | 1.008 | 2.333 | 10.658 | 4.482 |
| 23/05/2023 11:17 | 164.533 | 1.008 | 2.750 | 10.828 | 4.251 |
| 23/05/2023 11:18 | 154.025 | 1.058 | 2.000 | 10.599 | 4.552 |
| 23/05/2023 11:19 | 165.975 | 1.042 | 2.750 | 10.893 | 4.137 |
| 23/05/2023 11:20 | 152.875 | 1.075 | 2.083 | 10.551 | 4.571 |
| 23/05/2023 11:21 | 156.958 | 1.125 | 2.083 | 10.694 | 4.462 |
| 23/05/2023 11:22 | 155.492 | 1.133 | 2.000 | 10.637 | 4.451 |
| 23/05/2023 11:23 | 160.442 | 1.050 | 2.417 | 10.791 | 4.322 |
| 23/05/2023 11:24 | 159.858 | 1.092 | 2.250 | 10.743 | 4.252 |
| 23/05/2023 11:25 | 157.342 | 1.125 | 2.000 | 10.708 | 4.382 |
| 23/05/2023 11:26 | 156.950 | 1.108 | 2.000 | 10.721 | 4.374 |
| 23/05/2023 11:27 | 163.025 | 1.242 | 2.583 | 10.824 | 4.219 |
| 23/05/2023 11:28 | 159.525 | 1.125 | 2.250 | 10.768 | 4.229 |
| 23/05/2023 11:29 | 156.050 | 1.117 | 2.000 | 10.695 | 4.422 |
| 23/05/2023 11:30 | 159.092 | 1.167 | 2.417 | 10.693 | 4.298 |
| 23/05/2023 11:31 | 163.892 | 1.167 | 2.083 | 10.874 | 4.164 |
| 23/05/2023 11:32 | 159.025 | 1.125 | 2.167 | 10.734 | 4.248 |
| 23/05/2023 11:33 | 153.750 | 1.158 | 2.000 | 10.655 | 4.458 |
| 23/05/2023 11:34 | 158.825 | 1.175 | 2.000 | 10.783 | 4.294 |
| 23/05/2023 11:35 | 150.700 | 1.258 | 1.917 | 10.485 | 4.573 |
| 23/05/2023 11:36 | 153.942 | 1.300 | 2.083 | 10.679 | 4.496 |
| Average | 157.7 | 1.1 | 2.6 | 10.70 | 4.42 |

Referenced Data

| | NOx mg/Nm³ | SO₂ mg/Nm³ | CO mg/Nm³ | CO₂ vol% | O₂ vol% |
|-----------------------------------|--|---|---------------------------------------|--------------------------------------|-------------------------------------|
| 23/05/2023 11:06 | 341.7 | 3.6 | 4.9 | 10.52 | 4.97 |
| 23/05/2023 11:07 | 339.2 | 3.6 | 5.8 | 10.53 | 4.81 |
| 23/05/2023 11:08 | 372.0 | 3.4 | 6.8 | 10.86 | 4.24 |
| 23/05/2023 11:09 | 345.7 | 3.4 | 4.9 | 10.61 | 4.55 |
| 23/05/2023 11:10 | 343.9 | 3.9 | 4.3 | 10.62 | 4.57 |
| 23/05/2023 11:11 | 355.1 | 3.2 | 4.0 | 10.73 | 4.45 |
| 23/05/2023 11:12 | 347.2 | 3.0 | 4.0 | 10.65 | 4.51 |
| 23/05/2023 11:13 | 352.0 | 3.2 | 3.5 | 10.68 | 4.44 |
| 23/05/2023 11:14 | 356.0 | 3.4 | 3.7 | 10.74 | 4.38 |
| 23/05/2023 11:15 | 348.8 | 3.2 | 3.1 | 10.72 | 4.40 |
| 23/05/2023 11:16 | 350.2 | 3.1 | 3.2 | 10.66 | 4.48 |
| 23/05/2023 11:17 | 366.9 | 3.1 | 3.7 | 10.83 | 4.25 |
| 23/05/2023 11:18 | 343.4 | 3.3 | 2.7 | 10.60 | 4.55 |
| 23/05/2023 11:19 | 370.1 | 3.2 | 3.7 | 10.89 | 4.14 |
| 23/05/2023 11:20 | 340.9 | 3.3 | 2.8 | 10.55 | 4.57 |
| 23/05/2023 11:21 | 350.0 | 3.5 | 2.8 | 10.69 | 4.46 |
| 23/05/2023 11:22 | 346.7 | 3.5 | 2.7 | 10.64 | 4.45 |
| 23/05/2023 11:23 | 357.7 | 3.3 | 3.3 | 10.79 | 4.32 |
| 23/05/2023 11:24 | 356.4 | 3.4 | 3.1 | 10.74 | 4.25 |
| 23/05/2023 11:25 | 350.8 | 3.5 | 2.7 | 10.71 | 4.38 |
| 23/05/2023 11:26 | 349.9 | 3.4 | 2.7 | 10.72 | 4.37 |
| 23/05/2023 11:27 | 363.5 | 3.9 | 3.5 | 10.82 | 4.22 |
| 23/05/2023 11:28 | 355.7 | 3.5 | 3.1 | 10.77 | 4.23 |
| 23/05/2023 11:29 | 347.9 | 3.5 | 2.7 | 10.70 | 4.42 |
| 23/05/2023 11:30 | 354.7 | 3.6 | 3.3 | 10.69 | 4.30 |
| 23/05/2023 11:31 | 365.4 | 3.6 | 2.8 | 10.87 | 4.16 |
| 23/05/2023 11:32 | 354.6 | 3.5 | 2.9 | 10.73 | 4.25 |
| 23/05/2023 11:33 | 342.8 | 3.6 | 2.7 | 10.66 | 4.46 |
| 23/05/2023 11:34 | 354.1 | 3.6 | 2.7 | 10.78 | 4.29 |
| 23/05/2023 11:35 | 336.0 | 3.9 | 2.6 | 10.48 | 4.57 |
| 23/05/2023 11:36 | 343.2 | 4.0 | 2.8 | 10.68 | 4.50 |
| Average | 351.7 | 3.5 | 3.5 | 10.70 | 4.42 |
| Uncertainty of Measurement | 21.1 | 1.9 | 2.1 | 0.28 | 0.35 |
| Uncertainty as % of ELV | 4.70 | 0.11 | 2.60 | - | - |
| Standard Requirement | <10% | <15% | <6% | <25% | <6% |



OGU-010-2013 Uncertainty calculation for Gaseous Measurement EN 14792 Nox

v4

| | | | | | |
|------------------------|--------|------------------------------------|--------------|---------|--------------------------|
| Limit value | 450 | mg.m ⁻³ (corrected) NO2 | Gas | NO | |
| | | | Full Scale | 500 | ppm |
| Measured concentration | 157.74 | ppm | Cal gas conc | 434 | ppm |
| Measured concentration | 323.83 | mg.m ⁻³ (corrected) NO2 | Conversion | 2.053 | |
| Ratio NO/NO2 | 100.00 | | Full Scale | 1026.5 | mg.m ⁻³ (NO2) |
| | | | Cal gas conc | 891.002 | mg.m ⁻³ (NO2) |

| Correction for reference conditions | | | | | |
|-------------------------------------|----------|-------|-------------|---------------|----------------|
| | | O2, % | Moisture, % | Pressure, kPa | Temperature, K |
| | ref | 3.00 | 0.00 | 101.30 | 273.00 |
| | measured | 4.42 | 0.00 | 101.30 | 273.00 |
| Factors | | 1.09 | 1.00 | 1.00 | 1.00 |
| Correction Factor | | 1.09 | | | |

| Performance characteristics | Value | | specification |
|------------------------------------|-------------|---------------------|---------------|
| Response time | 30 | seconds | 180.000 |
| Number of readings in measurement | 30 | | |
| Repeatability at zero | 0.03 | % full scale | 0.200 |
| Repeatability at span level | 0.06 | % full scale | 2.000 |
| Deviation from linearity | 0.2 | % of value | 2.000 |
| Zero drift | 0 | % full scale | 2.000 |
| Span drift | 0.4 | % full scale | 2.000 |
| volume or pressure flow dependence | 0 | % of full scale/kPa | 0.033 |
| atmospheric pressure dependence | 0 | % of value/kPa | 0.750 |
| ambient temperature dependence | 0.3 | % full scale/10K | 0.300 |
| NH3 (20 mg/m ³) | 0 | mg/m ³ | |
| CO2 (15%) | 0.209 | % by vol | |
| H2O (30%) | 0.0 | % by vol | 4.000 |
| dependence on voltage | 0.1 | % full scale/10V | 2%at 10V |
| converter efficiency | 95 | % | 95% |
| losses in the line (leak) | 0.230414747 | % of value | 2% of value |
| Uncertainty of calibration gas | 1.2 | % of value | |

| Effect of drift | | |
|-----------------|-------------------|---------|
| 1.30 | mg/m ³ | 0.14538 |
| 0.40 | % value | |

| | ranges | | value at calib. |
|---------------------------|--------|-------|-----------------|
| | min | max | |
| flow | 95 | 105 | 100 |
| pressure | 101.30 | 101.3 | 101.3 |
| temp | 289 | 289 | 283 |
| NH3 range | 0 | 0 | 0 |
| CO2 range | 0 | 15 | 0 |
| H2O range | 0 | 0 | 0 |
| Instrument Voltage Rating | 110 | | |
| Voltage | 93 | 121 | 110 |

| Measurement performance related to stationary conditions | | | | | |
|--|--|-------------|-------------------------------|--|-----------------|
| Performance characteristic | | Uncertainty | Value of uncertainty quantity | | |
| Standard deviation of repeatability at zero | | u0 | for mean | | use rep at span |
| Standard deviation of repeatability at span level | | u1 | for mean | | 0.01 |
| Lack of fit | | u2 | | | 1.19 |
| Drift | | u3 | | | 0.75 |
| volume or pressure flow dependence | | u4 | | | 0.00 |
| atmospheric pressure dependence | | u5 | | | 0.00 |
| ambient temperature dependence | | u6 | | | 0.18 |
| NH3 (20 mg/m ³) | | u7 | | | 0.00 |
| CO2 (15%) | | | | | 0.12 |
| H2O (30%) | | | | | 0.00 |
| Dependence on voltage | | u8 | | | 0.09 |
| Converter efficiency | | u9 | | | 9.35 |
| losses in the line (leak) | | u10 | | | 0.43 |
| Uncertainty of calibration gas | | u11 | | | 2.24 |

| Use largest negative or positive interferent effect | |
|---|------|
| 0 | 0.00 |
| 0 | 0.12 |
| 0 | 0.00 |
| 0 | 0.12 |
| Interference uncertainty | 0.12 |

| | | | |
|-----------------------------------|---|--------|---------------------------|
| Measurement uncertainty | Result | 323.83 | mg/m ³ |
| Combined uncertainty | | 9.73 | mg/m ³ |
| Expanded uncertainty | k = 2 | 19.46 | mg/m ³ |
| Uncertainty corrected to std cond | | 21.13 | mg.m-3 (corrected) |
| Expanded uncertainty | expressed with a level of confidence of 95% | 4.70 | % ELV |
| Expanded uncertainty | expressed with a level of confidence of 95% | 21.13 | mg.m ⁻³ at ELV |

OGU-008-2013 Uncertainty calculation for Gaseous Measurement SO2 EN TS 17021
 V2 Jul-08

| | | | | | |
|------------------------|------|-----------------------------------|--------------|--------|--------------------|
| Limit value | 1700 | mg/m ³ (corrected) SO2 | Cal gas conc | 440.44 | mg.m ⁻³ |
| Measured concentration | 3.19 | mg/m ³ | Full Scale | 572 | mg/m ³ |
| Measured concentration | 3.46 | mg/m ³ (Corrected) | | | |

| Correction for reference conditions | | | | | |
|-------------------------------------|----------|-------|-------------|---------------|----------------|
| | | O2, % | Moisture, % | Pressure, kPa | Temperature, K |
| | ref | 3.00 | 0.00 | 101.30 | 273.00 |
| | measured | 4.42 | 0.00 | 101.30 | 273.00 |
| | Uncert | 0.35 | 1.00 | 0.00 | 1.00 |
| Factors | | 1.09 | 1.00 | 1.00 | 1.00 |
| Uncertainty in factor | | 0.02 | 0.01 | 0.00 | 0.00 |
| Correction Factor | | 1.09 | uf | 0.03 | |

| Performance characteristics | Value | | specification |
|------------------------------------|-------------|-----------------------|--------------------|
| Response time | 160 | seconds | 180,000 |
| Logger sampling interval | 60 | seconds | |
| Measurement period | 30 | minutes | |
| Number of readings in measurement | 30 | | |
| Repeatability at zero | 0.25 | % full scale | <1% range |
| Repeatability at span level | 0.15 | % full scale | <2% range |
| Deviation from linearity | 0.2 | % of value | <2% range |
| Zero drift | 0.45 | % full scale | <2% range / 24hr |
| Span drift | 0.5 | % full scale | <2% range/24hr |
| volume or pressure flow dependence | 0.02 | % of full scale/3 kPa | <2% / 3 kPa |
| atmospheric pressure dependence | 0.8 | % of full scale/2 kPa | <3% / 2 kPa |
| ambient temperature dependence | 0.01 | % full scale/10K | <3% range / 10 K |
| N2O (mg/m ³) | 20 | 0.2 | mg/m ³ |
| CO2 (% vol) | 15 | 0.2 | mg/m ³ |
| CH4 (mg/m ³) | 40 | 0.7 | mg/m ³ |
| H2O (% vol) | 20 | 0.2 | mg/m ³ |
| dependence on voltage | 0.1 | % full scale/10V | <2% range |
| losses in the line (leak) | 1.298701299 | % of value | < 0.1%vol /10 volt |
| Uncertainty of calibration gas | 1.2 | % of value | < 2% of value |

| Effect of drift | |
|-------------------|-------------------|
| 0.45 | mg/m ³ |
| 13.11 | % value |
| CORRECT FOR DRIFT | |

| | ranges | | | |
|-----------|--------|--------|----------------|-------------------|
| | min | max | value at calib | |
| flow | 0.3 | 0.5 | 0.4 | l/hr |
| pressure | 100.76 | 100.92 | 100.88 | kPa |
| temp | 287 | 288.5 | 287.5 | K |
| N2O range | 0 | 0 | 0 | mg/m ³ |
| CO2 range | 0 | 40 | 0 | %vol |
| CH4 range | 0 | 57 | 0 | mg/m ³ |
| H2O range | 0 | 1 | 0 | %vol |
| Voltage | 93 | 121 | 110 | V |

| Performance characteristic | Uncertainty | Value of uncertainty quantity |
|---|-------------------|-------------------------------|
| Standard deviation of repeatability at zero | u ₀ | use rep at span |
| Standard deviation of repeatability at span level | u _s | for mean 0.03 |
| Lack of fit | u _{mf} | 0.66 |
| Drift | u _{dr} | 0.26 |
| volume or pressure flow dependence | u _{vpm} | 0.00 |
| atmospheric pressure dependence | u _{atm} | 0.14 |
| ambient temperature dependence | u _{atm} | 0.00 |
| N2O (mg/m ³) | u _{meas} | 0.00 |
| CO2 (% vol) | u _{meas} | 0.31 |
| CH4 (mg/m ³) | u _{meas} | 0.58 |
| H2O (% vol) | u _{meas} | 0.01 |
| Dependence on voltage | u _{volt} | 0.49 |
| losses in the line (leak) | u _{leak} | 0.03 |
| Uncertainty of calibration gas | u _{cal} | 0.02 |
| Uncertainty in factor | uf | 0.08 |

| Use largest of sum of all positive or all negative influences | | | |
|---|------------------|---|-------------|
| 0.89 | all +ves | Criteria sum <4% range | 0.063781076 |
| 0 | all -ves | | |
| 0.89 | largest | Value to use for interference uncertainty | |
| 0.89 | u _{int} | | |

| | | | |
|------------------------------------|---|-------|--------------------|
| Measurement uncertainty | | 3.46 | mg/m ³ |
| Combined uncertainty | | 0.88 | mg/m ³ |
| Expanded uncertainty | k = 2 | 1.76 | mg/m ³ |
| Uncertainty corrected to std conds | | 1.91 | mg/m ³ |
| Expanded uncertainty | expressed with a level of confidence of 95% | 0.11 | % ELV |
| Expanded uncertainty | expressed with a level of confidence of 95% | 1.91 | mg.m ⁻³ |
| Expanded uncertainty | expressed with a level of confidence of 95% | 55.23 | % value |

Uncertainty calculation for Gaseous Measurement CO

| | | | | | |
|------------------------|------|-------------------------------|--------------|--------|--------------------|
| Limit value | 80 | mg/m ³ (corrected) | Cal gas conc | 188.75 | mg.m ⁻³ |
| Measured concentration | 3.19 | mg/m ³ | Full Scale | 250 | mg/m ³ |
| Measured concentration | 2.08 | mg/m ³ (Corrected) | | | |

| Correction for reference conditions | | | | |
|-------------------------------------|-------|-------------|---------------|----------------|
| | O2, % | Moisture, % | Pressure, kPa | Temperature, K |
| ref | 3.00 | 0.00 | 101.30 | 273.00 |
| measured | 4.42 | 0.00 | 101.30 | 273.00 |
| Uncert | 0.35 | 1.00 | 0.00 | 1.00 |
| Factors | 1.09 | 1.00 | 1.00 | 1.00 |
| Uncertainty in factor | 0.02 | 0.01 | 0.00 | 0.00 |
| Correction Factor | 1.09 | uf | 0.03 | |

| Performance characteristics | Value | | specification |
|---------------------------------------|-------|-----------------------|-------------------|
| Response time | 30 | seconds | 180.000 |
| Logger sampling interval | 60 | seconds | |
| Measurement period | 30 | minutes | |
| Number of readings in measurement | 30 | | |
| Repeatability at zero | 0.25 | % full scale | <1 % range |
| Repeatability at span level | 0.15 | % full scale | <2 % range |
| Deviation from linearity(lack of fit) | 0.7 | % of value | <2 % range |
| Zero drift | 2.5 | mg/m ³ | <2% range / 24hr |
| Span drift | 0 | mg/m ³ | <2% range/24hr |
| volume or pressure flow dependence | 0.02 | % of full scale/3 kPa | <2 % / 3 kPa |
| atmospheric pressure dependence | 0.8 | % of full scale/2 kPa | <3% / 2 kPa |
| ambient temperature dependence | 0.01 | % full scale/10K | <3% range / 10 K |
| N ₂ O (mg/m ³) | 20 | 0.2 | mg/m ³ |
| CO ₂ (% vvd) | 15 | 0.2 | mg/m ³ |
| CH ₄ (mg/m ³) | 40 | 0.7 | mg/m ³ |
| H ₂ O (% vvd) | 20 | 0.2 | mg/m ³ |
| dependence on voltage | 0.1 | % full scale/10V | <2% range |
| losses in the line (leak) | -1.32 | % of value | < 0.1%vvd /10 vvd |
| Uncertainty of calibration gas | 1.5 | % of value | <2% of value |

| Effect of drift | |
|-----------------|-------------------|
| 0.04 | mg/m ³ |
| 0.02 | % full scale |

| | ranges | | | value at calib |
|------------------------|--------|--------|--------|-------------------|
| | min | max | | |
| flow | 95.00 | 105 | 100 | kPa |
| pressure | 100.76 | 100.92 | 100.88 | kPa |
| temp | 287 | 288.5 | 287.5 | K |
| N ₂ O range | 0 | 40 | 0 | mg/m ³ |
| CO ₂ range | 0 | 15 | 0 | %vvd |
| CH ₄ range | 0 | 57 | 0 | mg/m ³ |
| H ₂ O range | 0 | 1 | 0 | %vvd |
| Voltage | 93 | 121 | 110 | V |

| Performance characteristic | Uncertainty | Value of uncertainty quantity | mg/m ³ |
|---|------------------|-------------------------------|-------------------|
| Standard deviation of repeatability at zero | u ₀ | for mean | use rep at span |
| Standard deviation of repeatability at span level | u _s | for mean | 0.07 |
| Lack of fit | u _l | | 0.01 |
| Drift | u _d | | 0.02 |
| volume or pressure flow dependence | u _v | | 0.05 |
| atmospheric pressure dependence | u _p | | 0.06 |
| ambient temperature dependence | u _t | | 0.00 |
| N ₂ O (mg/m ³) | u _{N2O} | | 0.23 |
| CO ₂ (% vvd) | u _{CO2} | | 0.12 |
| CH ₄ (mg/m ³) | u _{CH4} | | 0.58 |
| H ₂ O (% vvd) | u _{H2O} | | 0.01 |
| Dependence on voltage | u _v | | 0.22 |
| losses in the line (leak) | u _l | | -0.02 |
| Uncertainty of calibration gas | u _c | | 0.03 |

| Use largest of sum of all positive or all negative influences | | | |
|---|----------|---|-------------|
| 0.93 | all +ves | Criteria sum <4% range | 0.063877688 |
| 0 | all -ves | | |
| 0.93 | largest | Value to use for interference uncertainty | |
| u _{int} | 0.93 | | |

| Measurement uncertainty | | | |
|-----------------------------------|---|------|--------------------|
| Combined uncertainty | | 0.96 | mg/m ³ |
| Expanded uncertainty | k = 2 | 1.92 | mg/m ³ |
| Uncertainty corrected to std cond | | 2.08 | mg/m ³ |
| Expanded uncertainty | expressed with a level of confidence of 95% | 2.60 | % ELV |
| Expanded uncertainty | expressed with a level of confidence of 95% | 2.08 | mg.m ⁻³ |

OGU-007-2013 Uncertainty calculation for Gaseous Measurement: Carbon Dioxide

V2.2

Jul 08

| | | | | | |
|------------------------|-------|------|-----------------|-------|------|
| Limit value | n/a | %vol | Calibration gas | 0.162 | %vol |
| Measured concentration | 10.70 | %vol | Full Scale | 25 | %vol |

| Performance characteristics | Value | | | specification |
|--|------------|---------------------|---|----------------------|
| Response time | 30 | seconds | | < 200 s |
| Logger sampling interval | 60 | seconds | | |
| Measurement period | 30 | minutes | | |
| Number of readings in measurement | 30 | | Assuming 1 minute collected over 1 hour | |
| Repeatability at zero | 0.015 | % by volume | stdev | <0.2 % range |
| Repeatability at span level | 0.014 | % by volume | stdev | <0.4 % range |
| Deviation from linearity | 0.13 | % vol | +/- | <0.3 % volume |
| Zero drift (during measurement period) | 0 | % vol at zero level | +/- | <2% of volume / 24hr |
| Span drift (during measurement period) | 0 | % vol at span level | +/- | <2% volume/24hr |
| volume or pressure flow dependence | 0 | % of fs / 100h | +/- 5 l/h | <1% range |
| atmospheric pressure dependence | 0.3 | % of fs/kPa | +/- 2kPa | < 1.5 % range |
| ambient temperature dependence | -0.07 | % by volume /10K | +/- 15K | <0.3% volume 10 K |
| CO ₂ (% vol) | 15 | % by volume per | 15 | |
| NO (mg/m ³) | 300 | % by volume per | 300 | |
| NO ₂ (mg/m ³) | 30 | % by volume per | 30 | |
| Combined interference | 0.56 | % range | | <2% range |
| Dependence on voltage | 0.1 | % by volume /10V | +/- 8% | < 0.1%vol /10 volt |
| Losses in the line (leak) | 0.92879257 | % of value | | < 2% of value |
| Uncertainty of calibration gas | 0.9 | % of value | | |

| Effect of drift | |
|-----------------|---------|
| 0.00 | % vol |
| 0.00 | % value |

| range of variation from conditions at calibration | | | | |
|---|-------|-----|----------------|-------------------|
| | min | max | value at calib | |
| flow | 5 | 15 | 10 | l/h |
| pressure | 99.00 | 101 | 100 | kPa |
| temp | 280 | 285 | 285 | K |
| CO ₂ range | 8 | 15 | 0 | % vol |
| NO range | 100 | 150 | 0 | mg/m ³ |
| NO ₂ range | 5 | 7.5 | 0 | mg/m ³ |
| Voltage | 105 | 115 | 110 | V |

| Performance characteristic | Uncertainty | Value of uncertainty quantity | % vol |
|---|-------------|-------------------------------|----------------------|
| Standard deviation of repeatability at zero | usd | for mean | Only use zpp at span |
| Standard deviation of repeatability at span level | us | for mean | 0.00 |
| Lack of fit | us | | 0.08 |
| Drift | use | | 0.00 |
| volume or pressure flow dependence | usps | | 0.00 |
| atmospheric pressure dependence | usps | | 0.04 |
| ambient temperature dependence | usps | | -0.02 |
| CO ₂ | | | 0.05 |
| NO | | | 0.01 |
| NO ₂ | | | 0.00 |
| Combined interference (from moerts) | | | 0.08 |
| dependence on voltage | usps | | 0.03 |
| losses in the line (leak) | usps | | 0.06 |
| Uncertainty of calibration gas | usps | | 0.06 |

| Use largest of sum of all positive or all negative influences | | |
|---|---------------|-------------|
| Criteria | all -ves | 0.06 |
| Criteria | all -ves | 0 |
| Criteria | sum <2% value | 0.213974732 |
| Criteria | largest | 0.06 |
| Value to use for interference uncertainty | | |
| us | | 0.06 |

| | | | |
|-------------------------|---|-------|------------|
| Measurement uncertainty | | 10.70 | %vol |
| Combined uncertainty | | 0.14 | %vol |
| % of value | | 1.29 | % |
| Coverage factor k = | 2 | | |
| Expanded uncertainty | expressed with a level of confidence of 95% | 2.58 | % of value |
| Expanded uncertainty | expressed with a level of confidence of 99% | 0.28 | % vol |

OGU-007-2013 Uncertainty calculation for Gaseous Measurement Oxygen EN14789

V2.2

Jul-08

| | | | | | |
|------------------------|------|------|-----------------|-------|------|
| Limit value | n/a | %vol | Calibration gas | 0.209 | %vol |
| Measured concentration | 4.42 | %vol | Full Scale | 0.25 | %vol |

| Performance characteristics | Value | | | specification |
|--|-------------|---------------------|---|----------------------|
| Response time | 30 | seconds | | < 200 s |
| Logger sampling interval | 60 | seconds | | |
| Measurement period | 30 | minutes | | |
| Number of readings in measurement | 30 | | Assuming 1 minute collected over 1 hour | |
| Repeatability at zero | 0.015 | % by volume | stdev | <0.2 % range |
| Repeatability at span level | 0.014 | % by volume | stdev | <0.4 % range |
| Deviation from linearity | 0 | % vol | +/- | <0.3 % volume |
| Zero drift (during measurement period) | 0.0011 | % vol at zero level | +/- | <2% of volume / 24hr |
| Span drift (during measurement period) | 0.0009 | % vol at span level | +/- | <2% volume/24hr |
| volume or pressure flow dependence | 0 | % of fs / 100h | +/- 5 l/h | <1% range |
| atmospheric pressure dependence | 0.3 | % of fs/kPa | +/- 2kPa | < 1.5 % range |
| ambient temperature dependence | -0.07 | % by volume /10K | +/- 15K | <0.3% volume 10 K |
| CO ₂ (% vol) | 15 | % by volume per | 15 | |
| NO (mg/m ³) | 300 | % by volume per | 300 | |
| NO _x (mg/m ³) | 30 | % by volume per | 30 | |
| Combined interference | 0.56 | % range | | <2% range |
| Dependence on voltage | 0.1 | % by volume /10V | +/- 8% | < 0.1%vol /10 volt |
| Losses in the line (leak) | -0.09569378 | % of value | | < 2% of value |
| Uncertainty of calibration gas | 0.35 | % of value | | |

| Effect of drift | |
|-----------------|---------|
| 0.00 | % vol |
| 0.00 | % value |

| range of variation from conditions at calibration | | | |
|---|-------|-----|---------------------|
| | min | max | value at calib |
| flow | 5 | 15 | 10 l/h |
| pressure | 99.00 | 101 | 100 kPa |
| temp | 280 | 285 | 285 K |
| CO ₂ range | 8 | 15 | 0 % vol |
| NO range | 100 | 150 | 0 mg/m ³ |
| NO _x range | 5 | 7.5 | 0 mg/m ³ |
| Voltage | 105 | 115 | 110 V |

| Performance characteristic | Uncertainty | Value of uncertainty quantity | % vol |
|---|-------------|-------------------------------|----------------------|
| Standard deviation of repeatability at zero | usd | for mean | Only use rep at span |
| Standard deviation of repeatability at span level | us | for mean | 0.00 |
| Lack of fit | us | | 0.08 |
| Drift | usd | | 0.00 |
| volume or pressure flow dependence | usd | | 0.00 |
| atmospheric pressure dependence | usd | | 0.04 |
| ambient temperature dependence | usd | | -0.02 |
| CO ₂ | | | 0.05 |
| NO | | | 0.01 |
| NO _x | | | 0.00 |
| Combined interference (from moerts) | | | 0.08 |
| dependence on voltage | usd | | 0.03 |
| losses in the line (leak) | usd | | 0.13 |
| Uncertainty of calibration gas | usd | | 0.03 |

| | | |
|---|----------|-----------------------|
| Use largest of sum of all positive or all negative influences | | |
| 0.06 | all +ves | Criteria sum<2% value |
| 0 | all -ves | |
| 0.08 | largest | 0.22 |
| Value to use for interference uncertainty | | |
| usd | | 0.06 |

| | | | |
|-------------------------|---|------|------------|
| Measurement uncertainty | | 4.42 | %vol |
| Combined uncertainty | | 0.17 | %vol |
| % of value | | 3.81 | % |
| Coverage factor k = | 2 | | |
| Expanded uncertainty | expressed with a level of confidence of 95% | 7.82 | % of value |
| Expanded uncertainty | expressed with a level of confidence of 95% | 0.35 | % vol |

2.2 Stack Emission Point Reference: A2-1

2.2.1 Suitability of Sample Location:

| | |
|---------------------|-----------|
| General Information | A2-1 |
| Permanent/Temporary | Permanent |
| Inside/ Outside | Outside |

| Platform Details | | |
|---|-------|---------|
| Irish EPA Technical Guidance Note AG1 / BS EN 15259 Platform Requirements | Value | Comment |
| Sufficient Working area to manipulate probe and measuring instruments | N/a | - |
| Platform has 2 handrails (approx. 0.5m & 1.0 m high) | N/a | - |
| Platform has vertical base boards (approx. 0.25 m high) | N/a | - |
| Platform has chains / self-closing gates at top of ladders | N/a | - |
| There are no obstructions present which hamper insertion of sampling equipment | N/a | - |
| Safe Access Available | Yes | - |
| Easy Access Available | Yes | - |
| Sampling Location / Platform Improvement Recommendations | | |
| None. | | |
| EN 15259 Homogeneity Test Requirements | | |
| 1. | | |
| Select Option: | | |
| 1: There is no requirement to perform a BSEN15259 Homogeneity Test on this stack 2: Test results were obtained from previous Homogeneity test carried out by ASL 3: Test results were obtained from previous Homogeneity test carried out by Alternative contractor 4: Homogeneity Test is required on this stack and the client has been informed of this requirement | | |

2.2.2 Stack Diagram

2.2.3 Stack Raw Data

Title: Determination of Speciated Organic Compounds

Method: EN 13649
Client: Western Proteins
Test Date: 23/05/2023
Test Time: 13:00
Laboratory Used: RPS
Stack Reference: A2-1

Leak Check Results

| | Ammonia | |
|--------------------------|---------|-------|
| Prior to test: | 0 | l/min |
| Post Test: | 0 | l/min |
| Sample Volume Flow Rate: | 0.35 | l/min |
| Standard Requirement: | <5 | % |
| Test Result: | 0.0 | % |
| Test Status | Yes | |

Calibration Details

| | Ammonia | |
|-------------------------------|---------|-----------------|
| Pump Number: | 21EQ511 | |
| Calibration Unit: | 22EQ515 | |
| Calibration Unit Uncertainty: | <2 | % |
| Calibration Rate Before Test: | 0.35 | l/min |
| Calibration Rate After Test: | 0.35 | l/min |
| Maximum allowed flow | 0.5 | l/min |
| Average sample Volume: | 0.35 | l/min |
| Sample Test Time: | 30 | minutes |
| Pump Gas Temperature: | 14 | °C |
| Pump Sample Pressure: | 101.3 | kPa |
| Normalised Gas Volume: | 0.00978 | Nm ³ |

Tube Details

| | Ammonia | |
|--------------------------------|------------|-------|
| Tube Type: | 226-10-06 | |
| Tube Identification Number: | 8745704210 | |
| Blank Identification Number: | 8745704218 | |
| Main Adsorbent Layer | 400 | mg |
| Backup Adsorbent Layer | 200 | mg |
| Containment Material | Glass | |
| Breakthrough Occurred | No | |
| Tubes in Lab in <7 days | Yes | |
| Tubes >7 days were stored | <4 | Deg C |
| Tubes >7 days were stored | Dark | - |
| Transport Container Airtight | Yes | |
| Exposed to Sunlight | No | |
| Transport Temp <20 Deg C | Yes | |
| Field Blank <10% Analyte Value | Yes | |
| Field Blank <10% ELV | Yes | |

Test Details

| | | |
|------------------------------|----|----|
| Adsorption Tube Temperature: | 14 | °C |
|------------------------------|----|----|

Speciated Organic Results

| | | |
|----------------|----------------|---------------------------|
| Class I | ug/tube | mg.Nm⁻³ |
| Ammonia | 20.8 | 2.13 |

Speciated Organic Results - Blanks

| | | |
|----------------|----------------|---------------------------|
| Class I | ug/tube | mg.Nm⁻³ |
| Ammonia | 0.7 | 0.07 |

| Uncertainty calculation | | A2-1 | TA Luft Class 1 | | | Measurement Equation | | |
|---|------------------|--|----------------------|--------------------------|---|---|--------------------|--|
| Limit value (ELV) | | mg.m ⁻³ | Reference oxygen | | % by volume | $c = \frac{m}{V} f_c$ | | |
| Measured concentration | 2.13 | mg.m ⁻³ (at reference conditions) | | | | | | |
| Measured Quantities | Symbol | Value | Standard uncertainty | Units | Uncertainty as percentage | Uncertainty at lv | Requirement of std | |
| Sampled Volume Gas | V _s | 0.009783276 | uV _s | 0.0001 m ³ | 1.02 | | <=2% | |
| Sampled gas Temperature | T _m | 287 | uT _m | 2 K | 2.00 | | <=2.5 k | |
| Sampled gas Pressure | p _m | 101.3 | uP _m | 1 kPa | 0.99 | | <=1% | |
| Sampled gas Humidity | H _m | 0 | uH _m | 1 % by volume | 1.00 | | <=1% | |
| Oxygen content | O _{2,m} | | uO _{2,m} | 0.1 % by volume | #DIV/0! | | <=5% | |
| Note - Sampled gas humidity, temperature and pressure are values at the gas meter | | | | | | | | |
| Leak | L | 0.5 | | % | 0.50 | | <=2% | |
| Intermediate calculations | | | | | | | | |
| Factor for std cond | f _s | 0.95 | | | | | | |
| uncertainty components | symbol | sensitivity coeff | u (in units of fs) | | | | | |
| | p _m | 0.009 | | 0.009 | | | | |
| | H _m | 0.010 | | 0.010 | | $f_c = \frac{(100 - H_m) \cdot 273 \cdot p_m}{100 \cdot T_m \cdot 101.3}$ | | |
| | T _m | 0.003 | | 0.007 | | | | |
| | ufs | | | 0.015 | | | 1.57 | |
| Corrected volume | V | 0.01 | uV | 0.000 m ³ | $V = V_m \cdot f_c$ | 1.90 | | |
| Factor for O2 correction | f _c | 1.00 | | | | | | |
| uncertainty components | symbol | sensitivity coeff | u | | | | | |
| | O _{2,m} | 0.05 | | 0.005 | | $f_c = \frac{21 - O_{2,ref}}{21 - O_{2,m}}$ | | |
| Factor for O2 Correction | ufc | 1.00 | | 0.005 | | | 0.48 | |
| Parameter | Value | Units | Sensitivity coeff | Uncertainty contribution | Uncertainty as % | | | |
| Corrected Volume (standard conditor) | V | 0.01 m ³ | | 228.46 | 0.04 mg.m ⁻³ | 1.90 % | | |
| Factor for O2 Correction | f _c | 1.00 | | 2.13 | 0.01 mg.m ⁻³ | 0.48 % | | |
| Leak | L | 0.01 mg.m ⁻³ | | 1.00 | 0.01 mg.m ⁻³ | 0.29 % | | |
| Combined uncertainty | | | | | 0.04 mg.m⁻³ | | | |
| Expanded uncertainty as percentage of measured value | | | 3.96 | % measured of value | expressed with a level of confidence of 95% (Using a coverage factor k=2) | | | |
| Expanded uncertainty in units of measurement | | | 0.0842 | mg.m ⁻³ | | | | |

2.3 Stack Emission Point Reference: A2-2

2.3.1 Suitability of Sample Location:

| | |
|---------------------|-----------|
| General Information | A2-2 |
| Permanent/Temporary | Permanent |
| Inside/ Outside | Outside |

| Platform Details | | |
|---|-------|---------|
| Irish EPA Technical Guidance Note AG1 / BS EN 15259 Platform Requirements | Value | Comment |
| Sufficient Working area to manipulate probe and measuring instruments | N/a | - |
| Platform has 2 handrails (approx. 0.5m & 1.0 m high) | N/a | - |
| Platform has vertical base boards (approx. 0.25 m high) | N/a | - |
| Platform has chains / self-closing gates at top of ladders | N/a | - |
| There are no obstructions present which hamper insertion of sampling equipment | N/a | - |
| Safe Access Available | Yes | - |
| Easy Access Available | Yes | - |
| Sampling Location / Platform Improvement Recommendations | | |
| None | | |
| EN 15259 Homogeneity Test Requirements | | |
| 1. | | |
| Select Option: | | |
| 1: There is no requirement to perform a BSEN15259 Homogeneity Test on this stack 2: Test results were obtained from previous Homogeneity test carried out by ASL 3: Test results were obtained from previous Homogeneity test carried out by Alternative contractor 4: Homogeneity Test is required on this stack and the client has been informed of this requirement | | |

2.3.2 Stack Diagram

2.3.3 Stack Raw Data

Title: Determination of Speciated Organic Compounds

Method: EN 13649
Client: Western Proteins
Test Date: 23/05/2023
Test Time: 14:30
Laboratory Used: RPS
Stack Reference: A2-2

Leak Check Results

| | VOCs | |
|--------------------------|------|-------|
| Prior to test: | 0 | l/min |
| Post Test: | 0 | l/min |
| Sample Volume Flow Rate: | 0.35 | l/min |
| Standard Requirement: | <5 | % |
| Test Result: | 0.0 | % |
| Test Status | Yes | |

Calibration Details

| | VOCs | |
|-------------------------------|---------|-----------------|
| Pump Number: | 21EQ511 | |
| Calibration Unit: | 22EQ515 | |
| Calibration Unit Uncertainty: | <2 | % |
| Calibration Rate Before Test: | 0.35 | l/min |
| Calibration Rate After Test: | 0.35 | l/min |
| Maximum allowed flow | 0.5 | l/min |
| Average sample Volume: | 0.35 | l/min |
| Sample Test Time: | 30 | minutes |
| Pump Gas Temperature: | 14 | °C |
| Pump Sample Pressure: | 101.3 | kPa |
| Normalised Gas Volume: | 0.00978 | Nm ³ |

Tube Details

| | VOCs | |
|--------------------------------|------------|-------|
| Tube Type: | 226-10-06 | |
| Tube Identification Number: | 8745704211 | |
| Blank Identification Number: | 8745704218 | |
| Main Adsorbent Layer | 400 | mg |
| Backup Adsorbent Layer | 200 | mg |
| Containment Material | Glass | |
| Breakthrough Occurred | No | |
| Tubes in Lab in <7 days | Yes | |
| Tubes >7 days were stored | <4 | Deg C |
| Tubes >7 days were stored | Dark | - |
| Transport Container Airtight | Yes | |
| Exposed to Sunlight | No | |
| Transport Temp <20 Deg C | Yes | |
| Field Blank <10% Analyte Value | Yes | |
| Field Blank <10% ELV | Yes | |

Test Details

| | | |
|------------------------------|----|----|
| Adsorption Tube Temperature: | 14 | °C |
|------------------------------|----|----|

Speciated Organic Results

| | | |
|----------------|----------------|---------------------------|
| Class I | ug/tube | mg.Nm⁻³ |
| Ammonia | 0.4 | 0.04 |

Speciated Organic Results - Blanks

| | | |
|----------------|----------------|---------------------------|
| Class I | ug/tube | mg.Nm⁻³ |
| Ammonia | 0.7 | 0.07 |

| Uncertainty calculation | | A2-2 | TA Luft Class 1 | | | Measurement Equation | | |
|---|------------------|--|----------------------|--------------------------|---|---|-------------------------------|--------------------|
| Limit value (ELV) | | mg.m ⁻³ | Reference oxygen | | % by volume | $c = \frac{m}{V} f_c$ | | |
| Measured concentration | 0.04 | mg.m ⁻³ (at reference conditions) | | | | | | |
| Measured Quantities | Symbol | Value | Standard uncertainty | | Units | Uncertainty as percentage | Uncertainty at lv | Requirement of std |
| Sampled Volume Gas | V _s | 0.009783276 | uV _s | | 0.0001 m ³ | 1.02 | | <=2% |
| Sampled gas Temperature | T _m | 287 | uT _m | | 2 K | 2.00 | | <=2.5 k |
| Sampled gas Pressure | p _m | 101.3 | up _m | | 1 kPa | 0.99 | | <=1% |
| Sampled gas Humidity | H _m | 0 | uH _m | | 1 % by volume | 1.00 | | <=1% |
| Oxygen content | O _{2,m} | | uO _{2,m} | | 0.1 % by volume | #DIV/0! | | <=5% |
| Note - Sampled gas humidity, temperature and pressure are values at the gas meter | | | | | | | | |
| Leak | L | 0.5 | | | % | 0.50 | | <=2% |
| Intermediate calculations | | | | | | | | |
| Factor for std cond | f _s | 0.95 | | | | | | |
| uncertainty components | symbol | sensitivity coeff | | | u (in units of f _s) | | | |
| | p _m | 0.009 | | | 0.009 | | | |
| | H _m | 0.010 | | | 0.010 | | | |
| | T _m | 0.003 | | | 0.007 | | | |
| | ufs | | | | 0.015 | | 1.57 | |
| Corrected volume | V | 0.01 | uV | | 0.000 m ³ | $V = V_m f_c$ | 1.90 | |
| Factor for O2 correction | f _c | 1.00 | | | | | | |
| uncertainty components | symbol | sensitivity coeff | | | u | $f_c = \frac{21 - O_{2,ref}}{21 - O_{2,m}}$ | | |
| Factor for O2 Correction | ufc | 1.00 | | | 0.005 | | 0.48 | |
| | | | | | | | | |
| Parameter | Value | Units | Sensitivity coeff | Uncertainty contribution | Uncertainty as % | | | |
| Corrected Volume (standard condior) | V | 0.01 m ³ | 4.39 | 0.00 mg.m ⁻³ | 1.90 % | | | |
| Factor for O2 Correction | f _c | 1.00 | 0.04 | 0.00 mg.m ⁻³ | 0.48 % | | | |
| Leak | L | 0.00 mg.m ⁻³ | 1.00 | 0.00 mg.m ⁻³ | 0.29 % | | | |
| Combined uncertainty | | | | | | | 0.00 mg.m⁻³ | |
| Expanded uncertainty as percentage of measured value | | | 3.96 | % measured of value | expressed with a level of confidence of 95% (Using a coverage factor k=2) | | | |
| Expanded uncertainty in units of measurement | | | 0.0016 | mg.m ⁻³ | | | | |

Appendix III: Certificates and Process Detail Form

Process details form information not made available from Licensee at time of reporting. Details can be obtained direct from the client.

Certificate of Analysis

Report No.: 23-06428-1

Issue No.: 1

Date of Issue 05/07/2023

Customer Details: Axis Environmental Services Ltd, Unit 3, Westlink Business Park, Clondrinagh, Limerick, V94 K6XK, Ireland

Customer Contact: Michael Healy

Customer Order No.: WEPRTL15230523

Customer Reference: Not Supplied

Quotation Reference: Q23-05037

Description: 3 gas samples, 1 liquid sample, 1 solid sample

Date Received: 09/06/2023

Date Started: 09/06/2023

Date Completed: 05/07/2023

Test Methods: Details available on request (refer to SOP code against relevant result/s)

Notes: None



Approved By: Joanne Dewhurst, Operational Manager

This certificate is issued in accordance with the accreditation requirements of the United Kingdom Accreditation Service.

This certificate shall not be reproduced except in full without the prior written approval of the laboratory.

Observations and interpretations are outside of the scope of UKAS accreditation.

Results reported herein relate only to the items supplied to the laboratory for testing.

Results on an Interim Report are not dry-weight corrected.

Where the laboratory is not responsible for the sampling, results apply to the sample(s) as they were received.

The laboratory shall not be responsible for any information that is supplied by the customer that may affect the validity of results.



rpsgroup.com

RPS Environmental Management Limited trading as RPS Laboratories. Registered in England No. 01756175.

Unit 12, Waters Edge Business Park, Modwen Road, Salford, M5 3EZ. T +44 161 872 2443

A member of the RPS Group plc. Terms and conditions apply - copy on request

Results Summary

Report No.: 23-06428-1

Customer Reference: Not Supplied

Customer Order No: WEPRTL15230523

| | | | | | |
|--------------------|------------|------------|------------|------------|------------|
| Customer Sample No | 253220 | A1-1 Wash | 8745704218 | 8745704211 | 8745704210 |
| RPS Sample No | 185199 | 185200 | 185201 | 185202 | 185203 |
| Sample Matrix | FILTER | SOLUTION | TUBE | TUBE | TUBE |
| Sampling Date | 23/05/2023 | 23/05/2023 | 23/05/2023 | 23/05/2023 | 23/05/2023 |

| Determinand | CAS No | Codes | SOP | RL | Units | | | | | |
|--------------|-----------|-------|-----|------|-------|------|-----|-----|-----|------|
| particulates | | UM | D9 | 0.04 | mg | 3.38 | | | | |
| particulates | | UM | D9 | 0.5 | mg | | 1.0 | | | |
| ammonia | 7664-41-7 | U | A6 | 0.2 | ug | | | 0.7 | 0.4 | 20.8 |

Deviating Samples

Report No.: 23-06428-1

Customer Reference: Not Supplied

Customer Order No: WEPRTL15230523

Our policy on Deviating Samples has been implemented in accordance with UKAS Policy on Deviating Samples (TPS63).

RPS is not responsible for the integrity of samples as received, unless RPS personnel performed the sampling. Samples submitted may be declared to be deviating.

Where applicable the analysis method remains UKAS accredited, however results reported for a deviating sample may be compromised.

Where no sampling date was supplied, samples have been declared to be deviating. If the date can be supplied, results may be reissued if assessed not deviating.

Where the sample container used was unsuitable or broken, the sample is flagged as deviating and re-sampling/re-submission may be required.

| RPS No. | Customer No. | Customer ID | Date Sampled | Containers Received | Deviating | Reason for Deviation |
|---------|--------------|-------------|--------------|---------------------|-----------|----------------------|
| 185199 | 253220 | | 23/05/2023 | Container | No | |
| 185200 | A1-1 Wash | | 23/05/2023 | Container | No | |
| 185201 | 8745704218 | | 23/05/2023 | Container | No | |
| 185202 | 8745704211 | | 23/05/2023 | Container | No | |
| 185203 | 8745704210 | | 23/05/2023 | Container | No | |

Report No.: 23-06428-1

| Key Code | Description |
|------------------|---|
| N | Not Accredited Test |
| U | UKAS Accredited Test - UKAS accreditation is only implied if the report carries the UKAS logo |
| UF | UKAS Flexible Scope Test |
| M | MCERTS Accredited Test - MCERTS accreditation is only implied if the report carries the MCERTS logo |
| O | Marine Management Organisation (MMO) Validated |
| SN | Subcontracted to approved laboratory not accredited for the test |
| SU | Subcontracted to approved laboratory UKAS Accredited for the test |
| SM | Subcontracted to approved laboratory MCERTS/UKAS Accredited for the test |
| SIN | Subcontracted to internal RPS Group laboratory not accredited for the test |
| SIU | Subcontracted to internal RPS Group laboratory UKAS Accredited for the test |
| SIM | Subcontracted to internal RPS Group laboratory MCERTS/UKAS Accredited for the test |
| I/S (in results) | Insufficient Sample |
| U/S (in results) | Unsuitable Sample |
| S/C (in results) | See Comments |
| ND (in results) | Not Detected |
| L (in results) | Result is outside normal limits |

Please note that all samples will be destroyed 4 WEEKS after the report has been issued, with the exception of asbestos samples.

Note: Sample retention may be subject to agreement with the customer for particular projects

| Certificate Notes | Description |
|-------------------|---|
| Note 1 | This test report shall not be reproduced except in full, without written approval of the Laboratory. |
| Note 2 | Unless otherwise stated, results are not corrected for analytical recoveries. |
| Note 3 | Samples were taken by the customer and, unless otherwise stated, sampling locations were not supplied. |
| Note 4 | Opinions and interpretations expressed herein are outside the scope of UKAS accreditation. |
| Note 5 | Unless otherwise stated, method D9 conditioning temperatures are 180°C for pre-weigh and 160°C for re-weigh. |
| Note 6 | The PDF version of the certificate is the definitive copy and the Excel version is uncontrolled and provided for information only. |
| Note 7 | For asbestos analysis, all records, communications and reports pertaining to the analysis are retained for five years from the date of issue of the report. The sample analysed is retained for six months. |
| Note 8 | For asbestos analysis, method of analysis used is stereo microscopy, polarised light microscopy and dispersion staining. |

Note: Where the following information is included in this certificate, it has usually been supplied by the customer: Customer Sample ID, Sample Location, Sampling Date and Sample Air Volumes. The laboratory shall not be responsible for any information that is supplied by the customer that may affect the validity of results.

Report No.: 23-06428-1

| Determinand | CAS No | Media | SOP | % Recovery | % Uncertainty |
|---------------------------------------|------------|---------------------------------|------|------------|---------------|
| acetaldehyde | 75-07-0 | tube | A40 | 98 | 16.2 |
| benzaldehyde | 100-52-7 | tube | A40 | 100 | 19.4 |
| butyraldehyde | 123-72-8 | tube | A40 | 92 | 11.5 |
| formaldehyde | 50-00-0 | tube | A40 | 97 | 12.8 |
| hexanal | 66-25-1 | tube | A40 | 89 | 11 |
| propionaldehyde | 123-38-6 | tube | A40 | 96 | 12.6 |
| valeraldehyde | 110-62-3 | tube | A40 | 93 | 12.3 |
| ammonia | 7664-41-7 | sulphuric acid solution | A6 | n/a | 8.9 |
| chlorine | 7782-50-5 | sodium hydroxide solution | C27 | n/a | 15.2 |
| hydrogen bromide | 10035-10-6 | sulphuric acid solution | C27 | n/a | 10.9 |
| hydrogen chloride | 7647-01-0 | deionised water | C27 | n/a | 7.9 |
| hydrogen chloride | 7647-01-0 | sulphuric acid solution | C27 | n/a | 13.3 |
| hydrogen fluoride | 7664-3-3 | sodium hydroxide solution | C27 | n/a | 7.9 |
| sulphur dioxide | 7446-09-5 | hydrogen peroxide solution | C27 | n/a | 7.7 |
| nitrogen oxide | 10102-43-9 | potassium permanganate solution | C27 | n/a | 11.7 |
| particulates | n/a | filter | D9 | n/a | 12.2 |
| particulates | n/a | wash solution | D9 | n/a | 14.8 |
| formaldehyde | 50-00-0 | deionised water | M103 | n/a | 23.7 |
| 2,4- & 2,6-toluene diisocyanate (TDI) | n/a | filter | M119 | n/a | 8.6 |
| hexamethylene diisocyanate (HDI) | 822-06-0 | filter | M119 | n/a | 5.6 |
| methylene diphenyl diisocyanate (MDI) | 101-68-8 | filter | M119 | n/a | 11.8 |
| hydrogen sulphide | 7783-06-4 | zinc acetate solution | M120 | n/a | 4.2 |
| antimony | 7440-36-0 | filter | M31 | n/a | 10.3 |
| arsenic | 7440-38-2 | filter | M31 | n/a | 17.1 |
| cadmium | 7440-43-9 | filter | M31 | n/a | 12.1 |
| chromium | 7440-47-3 | filter | M31 | n/a | 17.1 |
| cobalt | 7440-48-4 | filter | M31 | n/a | 13.1 |
| copper | 7440-50-8 | filter | M31 | n/a | 14 |
| lead | 7439-92-1 | filter | M31 | n/a | 9.8 |
| manganese | 7439-96-5 | filter | M31 | n/a | 17.5 |
| nickel | 7440-02-0 | filter | M31 | n/a | 14.4 |
| thallium | 7440-28-0 | filter | M31 | n/a | 15.3 |
| tin | 7440-31-5 | filter | M31 | n/a | 18.5 |
| vanadium | 7440-62-2 | filter | M31 | n/a | 12.1 |
| zinc | 7440-66-6 | filter | M31 | n/a | 15.2 |
| antimony | 7440-36-0 | nitric acid wash | M31 | n/a | 10.3 |
| arsenic | 7440-38-2 | nitric acid wash | M31 | n/a | 17.1 |
| cadmium | 7440-43-9 | nitric acid wash | M31 | n/a | 12.1 |
| chromium | 7440-47-3 | nitric acid wash | M31 | n/a | 17.1 |
| cobalt | 7440-48-4 | nitric acid wash | M31 | n/a | 13.1 |
| copper | 7440-50-8 | nitric acid wash | M31 | n/a | 14 |
| lead | 7439-92-1 | nitric acid wash | M31 | n/a | 9.8 |
| manganese | 7439-96-5 | nitric acid wash | M31 | n/a | 17.5 |
| nickel | 7440-02-0 | nitric acid wash | M31 | n/a | 14.4 |
| selenium | 7782-49-2 | nitric acid wash | M31 | n/a | 15.1 |
| thallium | 7440-28-0 | nitric acid wash | M31 | n/a | 15.3 |
| tin | 7440-31-5 | nitric acid wash | M31 | n/a | 18.5 |
| vanadium | 7440-62-2 | nitric acid wash | M31 | n/a | 12.1 |
| zinc | 7440-66-6 | nitric acid wash | M31 | n/a | 15.2 |
| antimony | 7440-36-0 | nitric/peroxide solution | M31 | n/a | 5.9 |
| arsenic | 7440-38-2 | nitric/peroxide solution | M31 | n/a | 6.8 |
| cadmium | 7440-43-9 | nitric/peroxide solution | M31 | n/a | 6.3 |
| chromium | 7440-47-3 | nitric/peroxide solution | M31 | n/a | 7.2 |
| cobalt | 7440-48-4 | nitric/peroxide solution | M31 | n/a | 5.2 |
| copper | 7440-50-8 | nitric/peroxide solution | M31 | n/a | 6.8 |
| lead | 7439-92-1 | nitric/peroxide solution | M31 | n/a | 8.6 |
| manganese | 7439-96-5 | nitric/peroxide solution | M31 | n/a | 9.6 |
| nickel | 7440-02-0 | nitric/peroxide solution | M31 | n/a | 5.5 |
| selenium | 7782-49-2 | nitric/peroxide solution | M31 | n/a | 8.7 |
| thallium | 7440-28-0 | nitric/peroxide solution | M31 | n/a | 7.7 |
| tin | 7440-31-5 | nitric/peroxide solution | M31 | n/a | 5.8 |
| vanadium | 7440-62-2 | nitric/peroxide solution | M31 | n/a | 6.7 |
| zinc | 7440-66-6 | nitric/peroxide solution | M31 | n/a | 11.9 |
| 1,2,4-trimethylbenzene | 95-63-6 | tube | O8 | 88 | 8.1 |
| 1,3,5-trimethylbenzene | 108-67-8 | tube | O8 | 92 | 7.7 |
| 2-ethyltoluene | 611-14-3 | tube | O8 | 91 | 8.4 |
| 3- & 4-ethyltoluene | n/a | tube | O8 | 91 | 8.4 |
| benzene | 71-43-2 | tube | O8 | 90 | 13.9 |
| butyl acetate | 123-86-4 | tube | O8 | 90 | 10.3 |
| decane | 124-18-5 | tube | O8 | 97 | 6.7 |
| dichloromethane | 75-09-2 | tube | O8 | 88 | 24 |
| ethyl acetate | 141-78-6 | tube | O8 | n/a | n/a |
| ethyl benzene | 100-41-4 | tube | O8 | 92 | 9.8 |
| heptane | 142-82-5 | tube | O8 | 94 | 10.5 |
| hexane | 110-54-3 | tube | O8 | n/a | n/a |
| limonene | 138-86-3 | tube | O8 | 93 | 13 |
| m- & p-xylene | n/a | tube | O8 | 90 | 9.3 |
| methyl isobutyl ketone (MIBK) | 108-10-1 | tube | O8 | 86 | 10 |
| methyl tert-butyl ether (MTBE) | 1634-04-4 | tube | O8 | 92 | 15 |
| o-xylene | 95-47-6 | tube | O8 | 86 | 9.9 |
| propylbenzene | 103-65-1 | tube | O8 | 92 | 7.5 |
| tetrachloroethylene | 127-18-4 | tube | O8 | 91 | 9.3 |
| tetrahydrofuran (THF) | 109-99-9 | tube | O8 | 87 | 14.7 |
| toluene | 108-88-3 | tube | O8 | 89 | 10.7 |
| trichloroethylene | 79-01-6 | tube | O8 | 91 | 10.6 |
| m- & p-cresol | n/a | tube | P1 | n/a | 11 |
| m- & p-xyleneol | n/a | tube | P1 | n/a | 11.9 |
| o-cresol | 95-48-7 | tube | P1 | n/a | 10.8 |
| o-xyleneol | 526-75-0 | tube | P1 | n/a | 12 |
| phenol | 108-95-2 | tube | P1 | n/a | 10.4 |

Certificate of Analysis

Report No.: 23-06426-1

Issue No.: 1

Date of Issue 22/06/2023

Customer Details: Axis Environmental Services Ltd, Unit 3, Westlink Business Park, Clondrinagh, Limerick, V94 K6XK, Ireland

Customer Contact: Michael Healy

Customer Order No.: WEPRTL15230523

Customer Reference: Not Supplied

Quotation Reference: Q23-05037

Description: 1 liquid sample, 1 solid sample

Date Received: 09/06/2023

Date Started: 09/06/2023

Date Completed: 22/06/2023

Test Methods: Details available on request (refer to SOP code against relevant result/s)

Notes: None

Approved By: Joanne Dewhurst, Operational Manager

This certificate is issued in accordance with the accreditation requirements of the United Kingdom Accreditation Service.

This certificate shall not be reproduced except in full without the prior written approval of the laboratory.

Observations and interpretations are outside of the scope of UKAS accreditation.

Results reported herein relate only to the items supplied to the laboratory for testing.

Results on an Interim Report are not dry-weight corrected.

Where the laboratory is not responsible for the sampling, results apply to the sample(s) as they were received.

The laboratory shall not be responsible for any information that is supplied by the customer that may affect the validity of results.



rpsgroup.com

RPS Environmental Management Limited trading as RPS Laboratories. Registered in England No. 01756175.

Unit 12, Waters Edge Business Park, Modwen Road, Salford, M5 3EZ. T +44 161 872 2443

A member of the RPS Group plc. Terms and conditions apply - copy on request

Results Summary

Report No.: 23-06426-1

Customer Reference: Not Supplied

Customer Order No: WEPRTL15230523

| | | |
|---------------------------|---------------|-------------------|
| Customer Sample No | 253937 | Blank Wash |
| RPS Sample No | 185191 | 185192 |
| Sample Matrix | FILTER | SOLUTION |
| Sampling Date | 23/05/2023 | 23/05/2023 |

| Determinand | CAS No | Codes | SOP | RL | Units | | |
|--------------|--------|-------|-----|------|-------|--------|-------|
| particulates | | UM | D9 | 0.04 | mg | < 0.04 | |
| particulates | | UM | D9 | 0.5 | mg | | < 0.5 |

Deviating Samples

Report No.: 23-06426-1

Customer Reference: Not Supplied

Customer Order No.: WEPRTL15230523

Our policy on Deviating Samples has been implemented in accordance with UKAS Policy on Deviating Samples (TPS63).

RPS is not responsible for the integrity of samples as received, unless RPS personnel performed the sampling. Samples submitted may be declared to be deviating.

Where applicable the analysis method remains UKAS accredited, however results reported for a deviating sample may be compromised.

Where no sampling date was supplied, samples have been declared to be deviating. If the date can be supplied, results may be reissued if assessed not deviating.

Where the sample container used was unsuitable or broken, the sample is flagged as deviating and re-sampling/re-submission may be required.

| RPS No. | Customer No. | Customer ID | Date Sampled | Containers Received | Deviating | Reason for Deviation |
|---------|--------------|-------------|--------------|---------------------|-----------|----------------------|
| 185191 | 253937 | | 23/05/2023 | Container | No | |
| 185192 | Blank Wash | | 23/05/2023 | Container | No | |

Report No.: 23-06426-1

| Key Code | Description |
|------------------|---|
| N | Not Accredited Test |
| U | UKAS Accredited Test - UKAS accreditation is only implied if the report carries the UKAS logo |
| UF | UKAS Flexible Scope Test |
| M | MCERTS Accredited Test - MCERTS accreditation is only implied if the report carries the MCERTS logo |
| O | Marine Management Organisation (MMO) Validated |
| SN | Subcontracted to approved laboratory not accredited for the test |
| SU | Subcontracted to approved laboratory UKAS Accredited for the test |
| SM | Subcontracted to approved laboratory MCERTS/UKAS Accredited for the test |
| SIN | Subcontracted to internal RPS Group laboratory not accredited for the test |
| SIU | Subcontracted to internal RPS Group laboratory UKAS Accredited for the test |
| SIM | Subcontracted to internal RPS Group laboratory MCERTS/UKAS Accredited for the test |
| I/S (in results) | Insufficient Sample |
| U/S (in results) | Unsuitable Sample |
| S/C (in results) | See Comments |
| ND (in results) | Not Detected |
| L (in results) | Result is outside normal limits |

Please note that all samples will be destroyed 4 WEEKS after the report has been issued, with the exception of asbestos samples.

Note: Sample retention may be subject to agreement with the customer for particular projects

| Certificate Notes | Description |
|-------------------|--|
| Note 1 | This test report shall not be reproduced except in full, without written approval of the Laboratory. |
| Note 2 | Unless otherwise stated, results are not corrected for analytical recoveries. |
| Note 3 | Samples were taken by the customer and, unless otherwise stated, sampling locations were not supplied. |
| Note 4 | Opinions and interpretations expressed herein are outside the scope of UKAS accreditation. |
| Note 5 | Unless otherwise stated, method D9 conditioning temperatures are 180°C for pre-weigh and 160°C for re-weigh. The PDF version of the certificate is the definitive copy and the Excel version is uncontrolled and provided for information only. |
| Note 6 | For asbestos analysis, all records, communications and reports pertaining to the analysis are retained for five years from the date of issue of the report. The sample analysed is retained for six months. |
| Note 7 | For asbestos analysis, method of analysis used is stereo microscopy, polarised light microscopy and dispersion staining. |
| Note 8 | |

Note: Where the following information is included in this certificate, it has usually been supplied by the customer: Customer Sample ID, Sample Location, Sampling Date and Sample Air Volumes. The laboratory shall not be responsible for any information that is supplied by the customer that may affect the validity of results.

Report No.: 23-06426-1

| Determinand | CAS No | Media | SOP | % Recovery | % Uncertainty |
|---------------------------------------|------------|---------------------------------|------|------------|---------------|
| acetaldehyde | 75-07-0 | tube | A40 | 98 | 16.2 |
| benzaldehyde | 100-52-7 | tube | A40 | 100 | 19.4 |
| butyraldehyde | 123-72-8 | tube | A40 | 92 | 11.5 |
| formaldehyde | 50-00-0 | tube | A40 | 97 | 12.8 |
| hexanal | 66-25-1 | tube | A40 | 89 | 11 |
| propionaldehyde | 123-38-6 | tube | A40 | 96 | 12.6 |
| valeraldehyde | 110-62-3 | tube | A40 | 93 | 12.3 |
| ammonia | 7664-41-7 | sulphuric acid solution | A6 | n/a | 8.9 |
| chlorine | 7782-50-5 | sodium hydroxide solution | C27 | n/a | 15.2 |
| hydrogen bromide | 10035-10-6 | sulphuric acid solution | C27 | n/a | 10.9 |
| hydrogen chloride | 7647-01-0 | deionised water | C27 | n/a | 7.9 |
| hydrogen chloride | 7647-01-0 | sulphuric acid solution | C27 | n/a | 13.3 |
| hydrogen fluoride | 7664-3-3 | sodium hydroxide solution | C27 | n/a | 7.9 |
| sulphur dioxide | 7446-09-5 | hydrogen peroxide solution | C27 | n/a | 7.7 |
| nitrogen oxide | 10102-43-9 | potassium permanganate solution | C27 | n/a | 11.7 |
| particulates | n/a | filter | D9 | n/a | 12.2 |
| particulates | n/a | wash solution | D9 | n/a | 14.8 |
| formaldehyde | 50-00-0 | deionised water | M103 | n/a | 23.7 |
| 2,4- & 2,6-toluene diisocyanate (TDI) | n/a | filter | M119 | n/a | 8.6 |
| hexamethylene diisocyanate (HDI) | 822-06-0 | filter | M119 | n/a | 5.6 |
| methylene diphenyl diisocyanate (MDI) | 101-68-8 | filter | M119 | n/a | 11.8 |
| hydrogen sulphide | 7783-06-4 | zinc acetate solution | M120 | n/a | 4.2 |
| antimony | 7440-36-0 | filter | M31 | n/a | 10.3 |
| arsenic | 7440-38-2 | filter | M31 | n/a | 17.1 |
| cadmium | 7440-43-9 | filter | M31 | n/a | 12.1 |
| chromium | 7440-47-3 | filter | M31 | n/a | 17.1 |
| cobalt | 7440-48-4 | filter | M31 | n/a | 13.1 |
| copper | 7440-50-8 | filter | M31 | n/a | 14 |
| lead | 7439-92-1 | filter | M31 | n/a | 9.8 |
| manganese | 7439-96-5 | filter | M31 | n/a | 17.5 |
| nickel | 7440-02-0 | filter | M31 | n/a | 14.4 |
| thallium | 7440-28-0 | filter | M31 | n/a | 15.3 |
| tin | 7440-31-5 | filter | M31 | n/a | 18.5 |
| vanadium | 7440-62-2 | filter | M31 | n/a | 12.1 |
| zinc | 7440-66-6 | filter | M31 | n/a | 15.2 |
| antimony | 7440-36-0 | nitric acid wash | M31 | n/a | 10.3 |
| arsenic | 7440-38-2 | nitric acid wash | M31 | n/a | 17.1 |
| cadmium | 7440-43-9 | nitric acid wash | M31 | n/a | 12.1 |
| chromium | 7440-47-3 | nitric acid wash | M31 | n/a | 17.1 |
| cobalt | 7440-48-4 | nitric acid wash | M31 | n/a | 13.1 |
| copper | 7440-50-8 | nitric acid wash | M31 | n/a | 14 |
| lead | 7439-92-1 | nitric acid wash | M31 | n/a | 9.8 |
| manganese | 7439-96-5 | nitric acid wash | M31 | n/a | 17.5 |
| nickel | 7440-02-0 | nitric acid wash | M31 | n/a | 14.4 |
| selenium | 7782-49-2 | nitric acid wash | M31 | n/a | 15.1 |
| thallium | 7440-28-0 | nitric acid wash | M31 | n/a | 15.3 |
| tin | 7440-31-5 | nitric acid wash | M31 | n/a | 18.5 |
| vanadium | 7440-62-2 | nitric acid wash | M31 | n/a | 12.1 |
| zinc | 7440-66-6 | nitric acid wash | M31 | n/a | 15.2 |
| antimony | 7440-36-0 | nitric/peroxide solution | M31 | n/a | 5.9 |
| arsenic | 7440-38-2 | nitric/peroxide solution | M31 | n/a | 6.8 |
| cadmium | 7440-43-9 | nitric/peroxide solution | M31 | n/a | 6.3 |
| chromium | 7440-47-3 | nitric/peroxide solution | M31 | n/a | 7.2 |
| cobalt | 7440-48-4 | nitric/peroxide solution | M31 | n/a | 5.2 |
| copper | 7440-50-8 | nitric/peroxide solution | M31 | n/a | 6.8 |
| lead | 7439-92-1 | nitric/peroxide solution | M31 | n/a | 8.6 |
| manganese | 7439-96-5 | nitric/peroxide solution | M31 | n/a | 9.6 |
| nickel | 7440-02-0 | nitric/peroxide solution | M31 | n/a | 5.5 |
| selenium | 7782-49-2 | nitric/peroxide solution | M31 | n/a | 8.7 |
| thallium | 7440-28-0 | nitric/peroxide solution | M31 | n/a | 7.7 |
| tin | 7440-31-5 | nitric/peroxide solution | M31 | n/a | 5.8 |
| vanadium | 7440-62-2 | nitric/peroxide solution | M31 | n/a | 6.7 |
| zinc | 7440-66-6 | nitric/peroxide solution | M31 | n/a | 11.9 |
| 1,2,4-trimethylbenzene | 95-63-6 | tube | O8 | 88 | 8.1 |
| 1,3,5-trimethylbenzene | 108-67-8 | tube | O8 | 92 | 7.7 |
| 2-ethyltoluene | 611-14-3 | tube | O8 | 91 | 8.4 |
| 3- & 4-ethyltoluene | n/a | tube | O8 | 91 | 8.4 |
| benzene | 71-43-2 | tube | O8 | 90 | 13.9 |
| butyl acetate | 123-86-4 | tube | O8 | 90 | 10.3 |
| decane | 124-18-5 | tube | O8 | 97 | 6.7 |
| dichloromethane | 75-09-2 | tube | O8 | 88 | 24 |
| ethyl acetate | 141-78-6 | tube | O8 | n/a | n/a |
| ethyl benzene | 100-41-4 | tube | O8 | 92 | 9.8 |
| heptane | 142-82-5 | tube | O8 | 94 | 10.5 |
| hexane | 110-54-3 | tube | O8 | n/a | n/a |
| limonene | 138-86-3 | tube | O8 | 93 | 13 |
| m- & p-xylene | n/a | tube | O8 | 90 | 9.3 |
| methyl isobutyl ketone (MIBK) | 108-10-1 | tube | O8 | 86 | 10 |
| methyl tert-butyl ether (MTBE) | 1634-04-4 | tube | O8 | 92 | 15 |
| o-xylene | 95-47-6 | tube | O8 | 86 | 9.9 |
| propylbenzene | 103-65-1 | tube | O8 | 92 | 7.5 |
| tetrachloroethylene | 127-18-4 | tube | O8 | 91 | 9.3 |
| tetrahydrofuran (THF) | 109-99-9 | tube | O8 | 87 | 14.7 |
| toluene | 108-88-3 | tube | O8 | 89 | 10.7 |
| trichloroethylene | 79-01-6 | tube | O8 | 91 | 10.6 |
| m- & p-cresol | n/a | tube | P1 | n/a | 11 |
| m- & p-xyleneol | n/a | tube | P1 | n/a | 11.9 |
| o-cresol | 95-48-7 | tube | P1 | n/a | 10.8 |
| o-xyleneol | 526-75-0 | tube | P1 | n/a | 12 |
| phenol | 108-95-2 | tube | P1 | n/a | 10.4 |