

STACK EMISSIONS MONITORING REPORT



2-4 Langlands Place
Kelvin South Business Park
East Kilbride
G75 0YF
Tel: 01355 246 730

Your contact at SOCOTEC UK LTD
David Hay Business Manager - North Tel: 01355 246 730 Email: david.hay@socotec.co.uk

Operator & Address:
Medite Europe Limited Redmondstown Clonmel Co. Tipperary

Permit Reference:
IE Licence: P0027-04

Release Point:
A2-21

Sampling Date(s):
30th September - 2nd October

SOCOTEC Job Number:	LIR 1328 / Q3
Report Date:	31-Oct-25
Version:	1
Report By:	Barry Kehoe
MCERTS Number:	MM 23 1818
MCERTS Level:	MCERTS Level 1 Technician
Technical Endorsements:	1 & 4
Report Approved By:	Brian Walsh
MCERTS Number:	MM 17 1414
Business Title:	MCERTS Level 2 - Team Leader
Technical Endorsements:	1, 2, 3 & 4
Signature:	



1015



CONTENTS

EXECUTIVE SUMMARY

Stack Emissions Monitoring Objectives

- Plant
- Operator
- Stack Emissions Monitoring Test House

Emissions Summary

Monitoring Times

Process Details

Monitoring Methods

Analytical Methods

- Sampling Methods with Subsequent Analysis
- On-Site Testing

Sampling Location

- Sampling Plane Validation Criteria
- Duct Characteristics
- Sampling Lines & Sample Points
- Sampling Platform
- Sampling Location / Platform Improvement Recommendations

Sampling and Analytical Method Deviations

APPENDICES

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

EXECUTIVE SUMMARY

MONITORING OBJECTIVES

Medite Europe Limited operates a wood fibre drier process at Medite Europe Limited which is subject to IE Licence P0027-04, under the EPA Act 1992.

SOCOTEC UK LTD were commissioned by Medite Europe Limited to carry out stack emissions monitoring to determine the release of prescribed pollutants from the following Plant under normal operating conditions.

The results of these tests shall be used to demonstrate compliance with a set of emission limit values for prescribed pollutants as specified in the Plant's IE Licence, P0027-04.

Plant

A2-21

Operator

Medite Europe Limited
Redmondstown
Clonmel
Co. Tipperary

IE Licence: P0027-04

Stack Emissions Monitoring Test House

SOCOTEC UK LTD - East Kilbride Laboratory
2-4 Langlands Place
Kelvin South Business Park
East Kilbride
G75 0YF
UKAS and MCERTS Accreditation Number: 1015

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.
The results of this testing relate only to the emission release point(s) listed in the report.
MCERTS accredited results will only be claimed where both the sampling and analytical stages are MCERTS accredited.
This test report shall not be reproduced, except in full, without written approval of SOCOTEC UK LTD.

EXECUTIVE SUMMARY

EMISSIONS SUMMARY					
A2-21					
Parameter	Units	Result	Calculated Uncertainty +/-	Emission Limit Value (ELV)	Accreditation
Total Particulate Matter	mg/m ³	5.7	0.23	20	MCERTS
Particulate Emission Rate	g/hr	1553	62	-	
Dioxins & Furans - UPPER Limits					
Dioxins & Furans (NATO I-TEQ)	ng/m ³	0.0008	0.0009	-	MCERTS
Dioxins & Furans (NATO I-TEQ) Emission Rate	µg/hr	0.1247	0.1365	-	
Dioxins & Furans (WHO TEQ Humans / Mammals)	ng/m ³	0.0008	0.0009	-	MCERTS
Dioxins & Furans (WHO TEQ H / M) Emission Rate	µg/hr	0.1276	0.1397	-	
Dioxins & Furans (WHO TEQ Fish)	ng/m ³	0.0008	0.0008	-	MCERTS
Dioxins & Furans (WHO TEQ Fish) Emission Rate	µg/hr	0.1195	0.1309	-	
Dioxins & Furans (WHO TEQ Birds)	ng/m ³	0.0026	0.0028	-	MCERTS
Dioxins & Furans (WHO TEQ Birds) Emission Rate	µg/hr	0.4042	0.4426	-	
Dioxins & Furans - LOWER Limits					
Dioxins & Furans (NATO I-TEQ)	ng/m ³	0.0006	0.0006	-	MCERTS
Dioxins & Furans (NATO I-TEQ) Emission Rate	µg/hr	0.0914	0.1001	-	
Dioxins & Furans (WHO TEQ Humans / Mammals)	ng/m ³	0.0005	0.0005	-	MCERTS
Dioxins & Furans (WHO TEQ H / M) Emission Rate	µg/hr	0.0769	0.0842	-	
Dioxins & Furans (WHO TEQ Fish)	ng/m ³	0.0004	0.0004	-	MCERTS
Dioxins & Furans (WHO TEQ Fish) Emission Rate	µg/hr	0.0640	0.0701	-	
Dioxins & Furans (WHO TEQ Birds)	ng/m ³	0.0022	0.0025	-	MCERTS
Dioxins & Furans (WHO TEQ Birds) Emission Rate	µg/hr	0.3557	0.3895	-	
Formaldehyde	mg/m ³	4.29	1.03	15	MCERTS
Formaldehyde Emission Rate	g/hr	1165.13	279.63	-	
Total Volatile Organic Compounds	mg/m ³	13.99	1.3	120	MCERTS
Total Volatile Organic Compounds Emission Rate	g/hr	2814.21	264.54	-	
Oxides of Nitrogen (as NO ₂)	mg/m ³	102.17	4.2	110	MCERTS
Oxides of Nitrogen (as NO ₂) Emission Rate	g/hr	20552	853	-	
Carbon Monoxide	mg/m ³	2.76	1.85	300	MCERTS
Carbon Monoxide Emission Rate	g/hr	555.24	372.56	-	
Moisture	%	7.19	0.19	-	MCERTS
Stack Gas Temperature	°C	58	-	-	MCERTS
Stack Gas Velocity	m/s	17.6	0.43	-	

ND = None Detected,

Results at or below the limit of detection are highlighted by bold italic text.

The above volumetric flow rate is calculated using data from the preliminary survey. Mass emissions for non isokinetic tests are calculated using these values. For all isokinetic testing the mass emission is calculated using test specific flow data and not the above values.

Reference conditions are 273K, 101.3kPa, dry gas .

EXECUTIVE SUMMARY

MONITORING TIMES			
Parameter	Sampling Date(s)	Sampling Times	Sampling Duration
Total Particulate Matter Run 1	30 September 2025	12:10 - 12:42	32 minutes
Dioxins & Furans Run 1	30 September 2025	12:50 - 18:50	360 minutes
Formaldehyde Run 1	30 September 2025	12:10 - 12:42	32 minutes
Total Volatile Organic Compounds Run 1	02 October 2025	11:43 - 12:15	32 minutes
Combustion Gases	30 September 2025	13:29 - 14:28	59 minutes
Preliminary Stack Traverse	30 September 2025	12:20	-

EXECUTIVE SUMMARY

PROCESS DETAILS

Parameter	Process Details
Description of process	Wood Fibre Drier
Continuous or batch	Continuous
Product Details	MDF
Part of batch to be monitored (if applicable)	N/A
Normal load, throughput or continuous rating	Normal Load
Fuel used during monitoring	Wood
Abatement	Cyclone
Plume Appearance	Very Heavy Steam Plume

EXECUTIVE SUMMARY

Monitoring Methods

Declaration: Unless otherwise stated as a deviation, work has been completed to conform to the specific requirements of the Irish EPA's monitoring guidance notes; AG1, AG2, and the index of preferred methods.

MONITORING METHODS							
Species	Method Standard Reference Method / Alternative Method	SOCOTEC Technical Procedure	UKAS Lab Number	Method Accreditation	Limit of Detection (LOD)	Calculated MU +/- % Result	Calculated MU +/- % ELV
Total Particulate Matter	SRM - EN 13284-1	AE 104	1015	MCERTS	0.08 mg/m ³	4%	1.14%
Dioxins & Furans	SRM - EN 1948 - Part 1	AE 109	1015	MCERTS	0.0003 ng/m ³	109.5%	N/A - No ELV
Formaldehyde	CEN/TS 17638	AE114	1015	MCERTS	0.022 mg/m ³	24%	6.86%
Total Volatile Organic Compounds	SRM - EN 12619:2013	AE 102	1015	MCERTS	0.3 mg/m ³	9.4%	1.1%
Oxides of Nitrogen	SRM - EN 14792:2017	AE 102	1015	MCERTS	0.51 mg/m ³	4.1%	3.85%
Carbon Monoxide	SRM - EN 15058:2017	AE 102	1015	MCERTS	0.28 mg/m ³	67.1%	0.6%
Moisture	EN 14790	AE 105	1015	MCERTS	0.02%	2.7%	N/A - No ELV
Velocity	SRM - EN ISO 16911-1	AE 154	1015	MCERTS	5 Pa	2.4%	N/A - No ELV
Volumetric Flow Rate	SRM - EN ISO 16911-1	AE 154	1015	MCERTS	-	5.1%	5.94%

EXECUTIVE SUMMARY

Analytical Methods

The following tables list the analytical methods employed together with the custody details. Unless otherwise stated the samples are archived at the analysis lab location.

SAMPLING METHODS WITH SUBSEQUENT ANALYSIS							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	Analysis Accreditation	Analysis Lab	Analysis Report No. Date of Analysis	Archive Period
Total Particulate Matter	Gravimetric	AE 106	1015	MCERTS	SOCOTEC (East Kilbride)	N/A	8 Weeks
Dioxins and Furans	Gas Chromatography - High Resolution Mass Spectrometry	2002a	1668	MCERTS	Marchwood	577586-577587 13 Oct 2025	8 Weeks
Formaldehyde	Spectrophotometric	M103	0605	MCERTS	RPS	25-08503-1	8 Weeks

ON-SITE TESTING							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	Accreditation	Laboratory	Data Archive Location	Archive Period
Total Volatile Organic Compounds	Flame Ionisation Detection	AE 102	1015	MCERTS	SOCOTEC (East Kilbride)	SOCOTEC (East Kilbride)	5 years
Oxides of Nitrogen	Chemiluminescence	AE 102	1015	MCERTS	SOCOTEC (East Kilbride)	SOCOTEC (East Kilbride)	5 years
Carbon Monoxide	Non Dispersive Infra Red	AE 102	1015	MCERTS	SOCOTEC (East Kilbride)	SOCOTEC (East Kilbride)	5 years
Moisture	Gravimetric	AE 105	1015	MCERTS	SOCOTEC (East Kilbride)	-	-

EXECUTIVE SUMMARY

SAMPLING LOCATION					
Sampling Plane Validation Criteria	Value	Units	Requirement	Compliant	Method
Lowest Differential Pressure	39	Pa	≥ 5 Pa	Yes	EN 15259
Lowest Gas Velocity	8.9	m/s	-	-	-
Highest Gas Velocity	25.4	m/s	-	-	-
Ratio of Gas Velocities	2.8	: 1	$< 3 : 1$	Yes	EN 15259
Mean Velocity	17.6	m/s	-	-	-
Maximum angle of flow with regard to duct axis	< 15	$^{\circ}$	$< 15^{\circ}$	Yes	EN 15259
No local negative flow	Yes	-	-	Yes	EN 15259

DUCT CHARACTERISTICS		
	Value	Units
Shape	Circular	-
Depth	2.30	m
Width	-	m
Area	4.16	m ²
Port Depth	90	mm

SAMPLING LINES & POINTS		
	Isokinetic	Non-Iso & Gases
Sample port size	4" BSP	1" Port
Number of lines used	2	1
Number of points / line	9	1
Duct orientation	Vertical	Vertical
Filtration	Out Stack	Out Stack
Filtration for TPM	In Stack	-

SAMPLING PLATFORM	
General Platform Information	
Permanent / Temporary Platform / Ground level / Floor Level / Roof	Permanent
Inside / Outside	Outside

AG1 Platform requirements	
Is there a sufficient working area so work can be performed in a compliant manner	No
Platform has 2 levels of handrails (approximately 0.5 m & 1.0 m high)	Yes
Platform has vertical base boards (approximately 0.25 m high)	Yes
Platform has removable chains / self closing gates at the top of ladders	Yes
Handrail / obstructions do not hamper insertion of sampling equipment	No
Depth of Platform = $>$ Stack depth / diameter + wall and port thickness + 1.5m	No

Sampling Platform Improvement Recommendations (if applicable)

-

EXECUTIVE SUMMARY

Sampling & Analytical Method Deviations

Nozzle Size

Due to the high velocities at the sampling point selected in the stack a 6mm nozzle was required to achieve isokinetic monitoring, this does not completely adhere to EN 13284-1.

Sampling lines

It was only possible to sample from one representative sampling point for all isokinetic monitoring due to a number of factors i.e. flow being excessively high, swirl being greater than 15° & negative flow experienced throughout sample point locations. This sampling location does not therefore comply with all the requirements of AG1 & IS EN 16911-1.

Velocity traverse

As this sampling location shows high levels of turbulence throughout the results from the standard flow traverse are only indicative. In the past, reports detailing the volumetric flow rate according to fan rating have been used to calculate mass emission rates for this stack.

APPENDICES

CONTENTS

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

MONITORING SCHEDULE					
Species	Method Standard Reference Method / Alternative Method	SOCOTEC Technical Procedure	UKAS Lab Number	MCERTS Accredited Method	Number of Samples
Total Particulate Matter	SRM - EN 13284-1	AE 104	1015	MCERTS	1
Dioxins & Furans	SRM - EN 1948 - Part 1	AE 109	1015	MCERTS	1
Formaldehyde	CEN/TS 17638	AE114	1015	MCERTS	1
Total Volatile Organic Compounds	SRM - EN 12619:2013	AE 102	1015	MCERTS	1
Oxides of Nitrogen	SRM - EN 14792:2017	AE 102	1015	MCERTS	1
Carbon Monoxide	SRM - EN 15058:2017	AE 102	1015	MCERTS	1
Moisture	EN 14790	AE 105	1015	MCERTS	1
Velocity	SRM - EN ISO 16911-1	AE 154	1015	MCERTS	1

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

CALIBRATABLE EQUIPMENT CHECKLIST					
Extractive Sampling		Instrumental Analyser/s		Miscellaneous	
Equipment	Equipment I.D.	Equipment	Equipment I.D.	Equipment	Equipment I.D.
Control Box DGM	LIR 9.49	Horiba PG - 350E Analyser	LIR 12.2	Laboratory Balance	LIR 15.21
Box Thermocouples	LIR 9.50	FT-IR	-	Tape Measure	LIR 20.2
Meter In Thermocouple	LIR 9.50	FT-IR Oven Box	-	Stopwatch	-
Meter Out Thermocouple	LIR 9.50	Bernath 3006 FID	LIR 8.4	Protractor	-
Control Box Timer	LIR 17.27	Signal 3030 FID	-	Barometer	LIR 16.13
Oven Box	LIR 13.25	Servomex	-	Digital Micromanometer	LIR 15.AF1
Probe	LIR 6.22	JCT Heated Head Filter	LIR 13.32a	Digital Temperature Meter	LIR 2.11
Probe Thermocouple	-	Thermo FID	LIR 8.27	Stack Thermocouple	-
Probe	LIR 6.17	Stackmaster	-	Mass Flow Controller	-
Probe Thermocouple	-	FTIR Heater Box for Heated Line	-	MFC Display module	-
S-Pitot	LIR 6.17	Anemometer	-	1m Heated Line (1)	-
L-Pitot	-	Ecophysics NOx Analyser	-	1m Heated Line (2)	-
Site Balance	LIR 23.24	Chiller (JCT/MAK 10)	LIR 12.12	1m Heated Line (3)	-
Last Impinger Arm	LIR 3.109	Heated Line Controller (1)	LIR 8.49	5m Heated Line (1)	-
Dioxins Cond. Thermocouple	LIR 3.209	Heated Line Controller (2)	-	10m Heated Line (1)	-
Callipers	LIR 15.1X	Site temperature Logger	-	10m Heated Line (2)	-
Small DGM	-	Gas Divider (1)	-	15m Heated Line (1)	-
Heater Controller	-	Gas Divider (2)	-	20m Heated Line (1)	LIR 8.49
Inclinometer (Swirl Device)	LIR 24.15			20m Heated Line (2)	-

NOTE: If the equipment I.D is represented by a dash (-), then this piece of equipment has not been used for this test.

CALIBRATION GASES					
Gas (traceable to ISO 17025)	Cylinder I.D Number	Supplier	ppm	%	Analytical Tolerance +/- %
Propane	LEK 232	BOC	82.8	-	2.0
Nitric Oxide	LEK 345	BOC	201	-	2.0
Carbon Monoxide	LEK 345	BOC	164.3	-	2.0

Note: Span gases may be diluted to an appropriate range with a gas divider.

STACK EMISSIONS MONITORING TEAM

MONITORING TEAM								
Personnel	MCERTS Number	MCERTS		TE / H&S Qualifications and Expiry Date				
		Level	Expiry	TE1	TE2	TE3	TE4	H&S
Brian Walsh	MM 17 1414	MCERTS Level 2	May-27	Jan-28	Mar-29	Nov-28	May-28	May-27
Stuart Gordon	MM 22 1745	MCERTS Level 1	Sep-27	Apr-29	-	Mar-30	May-30	Sep-27

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

TOTAL PARTICULATE MATTER SUMMARY					
Parameter	Sampling Times	Concentration mg/m ³	Uncertainty mg/m ³	ELV mg/m ³	Emission Rate g/hr
Run 1	12:10 - 12:42 30 September 2025	5.72	0.23	20	1553.0
Blank	-	0.08	-	-	-

Reference conditions are 273K, 101.3kPa, dry gas .

Acetone Blank Value mg/l	Acceptable Value mg/l
0.3	1.0

FILTER INFORMATION

SAMPLES								
Test	Filter & Probe Rinse Number	Filter Start Weight	Filter End Weight	Mass Gained on Filter	Probe Rinse Start Weight	Probe Rinse End Weight	Mass Gained on Probe	Combined Total Mass Gained
Run 1	IAQ 200	0.15015	0.15261	0.00246	56.00982	56.01142	0.00160	0.00406

If total mass gained is less than the LOD then the LOD is reported

BLANKS								
Test	Filter & Probe Number	Filter Start Weight	Filter End Weight	Mass Gained Filter	Probe Start Weight	Probe End Weight	Mass Gained Probe	Combined Total Mass Gained
Run 1	IAQ 199	0.15330	0.15337	0.00007	54.56067	54.56064	-0.00003	0.00006

If total mass gained is less than the LOD then the LOD is reported

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS - RUN 1			TPM
Absolute pressure of stack gas, P_s			Molecular weight of dry gas, M_d
Barometric pressure, P _b	Kpa	101.0	CO ₂ % 1.79
Stack static pressure, P _{static}	pa	81.0	O ₂ % 19.09
P _s = P _b + P _{static}	Kpa	101.1	Total % 20.88
Vol. of water vapour collected, V_{wstd}			N ₂ (100 -Total) % 79.12
Moisture trap weight increase, V _{lc}	g	44.1	M _d = 0.44(%CO ₂)+0.32(%O ₂)+0.28(%N ₂) 29.05
V _{wstd} = (0.001246)(V _{lc})	m ³	0.0549486	Molecular weight of wet gas, M_s
Volume of gas metered dry, V_{mstd}			M _s = M _d (1 - B _{wo}) + 18(B _{wo}) g/gmol 28.26
Volume of gas sample through gas meter, V _m		0.775	Actual flow of stack gas, Q_a
Gas meter correction factor, Y _d		0.993	Area of stack, A _s m ² 4.16
Mean dry gas meter temperature, T _m		297	Q _a = (60)(A _s)(V _d) m ³ /min 5904.2
Mean pressure drop across orifice, DH	mmH ₂ O	51.379	Total flow of stack gas, Q
V _{mstd} = $\frac{(0.3592)(V_m)(P_b + (DH/13.6))(Y_d)}{T_m}$	m ³	0.709	Conversion factor (K/mm.Hg) 0.3592
Volume of gas metered wet, V_{mstw}			Q _{std} = (Q _a)P _s (0.3592)(1-B _{wo}) Dry 4521.8
V _{mstw} = V _{mstd} + V _{wstd}	m ³	0.7642	Q _{stdO2} = (Q _a)P _s (0.3592)(1-B _{wo})(O ₂ REF) @O ₂ ref No O2 Ref
Vol. of gas metered at O₂ Ref. Cond., V_{mstd@X%O2}			Q _{stw} = $\frac{(Q_a)P_s(0.3592)}{(T_s)}$ Wet 4872.12
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Percent isokinetic, %I
% oxygen measured in gas stream, act%O ₂		19.1	Nozzle diameter, D _n mm 4.99
% oxygen reference condition		21	Nozzle area, A _n mm ² 19.59
O ₂ Reference O ₂ Ref = 21.0 - act%O ₂		No O2 Ref	Total sampling time, q min 32
Factor $\frac{21.0 - \text{ref}\%O_2}{21.0 - \text{act}\%O_2}$		No O2 Ref	%I = $\frac{(4.6398E6)(T_s)(V_{mstd})}{(P_s)(V_s)(A_n)(q)(1-B_{wo})}$ % 104.0
V _{mstd@X%oxygen} = (V _{mstd}) (O ₂ Ref)	m ³	No O2 Ref	Acceptable isokinetic range 95% to 115% Yes
Moisture content, B_{wo}			Particulate Concentration, C
B _{wo} = $\frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.0719	Mass collected on filter, M _f g 0.00246
		7.19	Mass collected in probe, M _p g 0.00160
Moisture by FTIR			Total mass collected, M _n g 0.00406
	%	-	C _{wet} = $\frac{M_n}{V_{mstw}}$ mg/m ³ 5.313
Velocity of stack gas, V_s			C _{dry} = $\frac{M_n}{V_{mstd}}$ mg/m ³ 5.724
Velocity pressure coefficient, C _p		0.84	C _{dry@X%O2} = $\frac{M_n}{V_{mstd@X\%oxygen}}$ mg/m ³ No O2 Ref
Mean of velocity heads, DP _{avg}	Pa	414.05	Particulate Emission Rates, E
Mean stack gas temperature, T _s	K	330	E = [(C _{wet})(Q _{stw})(60)] / 1000 1553.05
Gas density (wet, ambient), ρ			
ρ = (M _s *P _s)/(8.314*T _s)	kg/m ³	1.041	
Stack Velocity, V _s	$V_s = \frac{\sum_{i=1}^n V_i}{n}$	m/s	
		23.68	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

TOTAL PARTICULATE MATTER QUALITY ASSURANCE CHECKLIST

LEAK RATE						
Run	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests Acceptable?
Run 1	24.06	0.13	-	-381	0.48	Yes

In BS EN 13284-1:2017 a post sampling leak check is not required.

ISOKINETICITY		
Run	Isokinetic Variation %	Acceptable Isokineticity
Run 1	103.99	Yes

Acceptable isokinetic range 95% to 115%

WEIGHING BALANCE UNCERTAINTY			
Run	Result mg/m ³	5% ELV mg/m ³	LOD < 5% ELV
Run 1	0.08	1.0	Yes

The above is based on both the Filter and rinse uncertainty

BLANK VALUE				
Run	Overall Blank Value mg/m ³	Daily Limit Value mg/m ³	Acceptable Blank Value mg/m ³	Overall Blank Acceptable
Blank 1	0.08	20	2.0	Yes

FILTERS					
Run	Filter Material	Filter Size mm	Max Filtration Temperature °C	Pre-use Filter Conditioning Temperature °C	Post-use Filter Conditioning Temperature °C
Run 1	Quartz Fibre	47	57	180	160

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

DIOXINS & FURANS SUMMARY - UPPER LIMIT

NATO I-TEQ					
Test	Sampling Times	Concentration ng/m ³	LOD ng/m ³	ELV ng/m ³	Emission Rate µg/hr
Run 1	12:50 - 18:50 30 September 2025	0.0008	0.0003	-	0.12
Field Blanks Run 1	-	0.000984	0.00037	-	-

WHO TEQ (Humans / Mammals)					
Test	Sampling Times	Concentration ng/m ³	LOD ng/m ³	ELV ng/m ³	Emission Rate µg/hr
Run 1	12:50 - 18:50 30 September 2025	0.0008	0.0004	-	0.13
Field Blanks Run 1	-	0.00107	0.00046	-	-

WHO TEQ (Fish)					
Test	Sampling Times	Concentration ng/m ³	LOD ng/m ³	ELV ng/m ³	Emission Rate µg/hr
Run 1	12:50 - 18:50 30 September 2025	0.0008	0.0004	-	0.12
Field Blanks Run 1	-	0.00113	0.00050	-	-

WHO TEQ (Birds)					
Test	Sampling Times	Concentration ng/m ³	LOD ng/m ³	ELV ng/m ³	Emission Rate µg/hr
Run 1	12:50 - 18:50 30 September 2025	0.0026	0.0006	-	0.40
Field Blanks Run 1	-	0.00293	0.00064	-	-

Reference conditions are 273K, 101.3kPa, dry gas .

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

DIOXINS & FURANS SUMMARY - LOWER LIMIT

NATO I-TEQ					
Test	Sampling Times	Concentration ng/m ³	LOD ng/m ³	ELV ng/m ³	Emission Rate µg/hr
Run 1	12:50 - 18:50 30 September 2025	0.0006	-	-	0.09
Field Blanks Run 1	-	0.0008348	-	-	-

WHO TEQ (Humans / Mammals)					
Test	Sampling Times	Concentration ng/m ³	LOD ng/m ³	ELV ng/m ³	Emission Rate µg/hr
Run 1	12:50 - 18:50 30 September 2025	0.0005	-	-	0.08
Field Blanks Run 1	-	0.00092619	-	-	-

WHO TEQ (Fish)					
Test	Sampling Times	Concentration ng/m ³	LOD ng/m ³	ELV ng/m ³	Emission Rate µg/hr
Run 1	12:50 - 18:50 30 September 2025	0.0004	-	-	0.06
Field Blanks Run 1	-	0.000948687	-	-	-

WHO TEQ (Birds)					
Test	Sampling Times	Concentration ng/m ³	LOD ng/m ³	ELV ng/m ³	Emission Rate µg/hr
Run 1	12:50 - 18:50 30 September 2025	0.0022	-	-	0.36
Field Blanks Run 1	-	0.00281297	-	-	-

Reference conditions are 273K, 101.3kPa, dry gas .

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

DIOXINS & FURANS ANALYSIS SUMMARY - RUN 1

NATO I-TEQ & WHO TEQ (Humans / Mammals)							
Congener	Result ng	NATO I-TEQ ng	WHO TEQ Humans / Mammals ng	Extraction Recovery		Sampling Recovery	
				Actual %	Permitted %	Actual %	Permitted %
Dioxins							
2,3,7,8 Tetra CDD	< 0.00032	0.0003	0.0003	92	50% - 130%		
1,2,3,7,8 Penta CDD	< 0.00099	0.0005	0.0010	72	50% - 130%		
1,2,3,4,7,8 Hexa CDD	< 0.00045	0.0000	0.0000	86	50% - 130%		
1,2,3,6,7,8 Hexa CDD	0.00236	0.0002	0.0002	88	50% - 130%		
1,2,3,7,8,9 Hexa CDD	< 0.00045	0.0000	0.0000		-		
1,2,3,4,6,7,8 Hepta CDD	0.0134	0.0001	0.0001	71	40% - 130%		
OCDD Octa CDD	0.0449	0.0000	0.00001	74	40% - 130%		
Total -Dioxins	0.06286	0.0013	0.0018				
Furans							
2,3,7,8 Tetra CDF	0.0079	0.0008	0.0008	80	50% - 130%		
1,2,3,7,8 Penta CDF	0.00162	0.0001	0.0000		-	86	>=50
2,3,4,7,8 Penta CDF	0.00172	0.0009	0.0005	72	50% - 130%		
1,2,3,4,7,8 Hexa CDF	0.00125	0.0001	0.0001	84	50% - 130%		
1,2,3,6,7,8 Hexa CDF	0.00123	0.0001	0.0001	81	50% - 130%		
2,3,4,6,7,8 Hexa CDF	0.00146	0.0001	0.0001	85	50% - 130%		
1,2,3,7,8,9 Hexa CDF	< 0.00044	0.0000	0.0000		-	84	>=50
1,2,3,4,6,7,8 Hepta CDF	0.00398	0.0000	0.0000	67	40% - 130%		
1,2,3,4,7,8,9 Hepta CDF	0.00136	0.00001	0.00001		-	88	>=50
OCDF Octa CDF	0.00699	0.00001	0.00000	69	40% - 130%		
Total -Furans	0.027951	0.0022	0.0018				
Mean Recoveries (%)				79		86	
Total Isomers	0.090811	0.0035	0.0036				
Total ITEQ (<LOD = 0)		0.0026	0.0022				

NOTE: The Total Isomers result includes all isomers below the limit of detection. This gives a "worst case" Dioxins & Furans result.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

DIOXINS & FURANS ANALYSIS SUMMARY - RUN 1

WHO TEQ (Fish) & WHO TEQ (Birds)							
Congener	Result	WHO TEQ Fish	WHO TEQ Birds	Extraction Recovery		Sampling Recovery	
				Actual	Permitted	Actual	Permitted
	ng	ng	ng	%	%	%	%
Dioxins							
2,3,7,8 Tetra CDD	< 0.00032	0.0003	0.0003	92	50% - 130%		
1,2,3,7,8 Penta CDD	< 0.00099	0.0010	0.0010	72	50% - 130%		
1,2,3,4,7,8 Hexa CDD	< 0.00045	0.0002	0.0000	86	50% - 130%		
1,2,3,6,7,8 Hexa CDD	0.00236	0.0000	0.0000	88	50% - 130%		
1,2,3,7,8,9 Hexa CDD	< 0.00045	0.0000	0.0000		-		
1,2,3,4,6,7,8 Hepta CDD	0.0134	0.00001	0.00001	71	40% - 130%		
OCDD Octa CDD	0.0449	-	-	74	40% - 130%		
Total -Dioxins	0.06286	0.0016	0.0014				
Furans							
2,3,7,8 Tetra CDF	0.0079	0.0004	0.0079	80	50% - 130%		
1,2,3,7,8 Penta CDF	0.00162	0.0001	0.0000		-	86	>=50
2,3,4,7,8 Penta CDF	0.00172	0.0009	0.0017	72	50% - 130%		
1,2,3,4,7,8 Hexa CDF	0.00125	0.0001	0.0001	84	50% - 130%		
1,2,3,6,7,8 Hexa CDF	0.00123	0.0001	0.0001	81	50% - 130%		
2,3,4,6,7,8 Hexa CDF	0.00146	0.0001	0.0001	85	50% - 130%		
1,2,3,7,8,9 Hexa CDF	< 0.00044	0.0000	0.0000		-	84	>=50
1,2,3,4,6,7,8 Hepta CDF	0.00398	0.0000	0.0000	67	40% - 130%		
1,2,3,4,7,8,9 Hepta CDF	0.00136	0.00001	0.00001		-	88	>=50
OCDF Octa CDF	0.00699	0.00000	0.00000	69	40% - 130%		
Total -Furans	0.027951	0.0018	0.0101				
Mean Recoveries (%)				79		86	
Total Isomers	0.090811	0.0034	0.0115				
Total ITEQ (<LOD = 0)		0.0018	0.0101				

NOTE: The Total Isomers result includes all isomers below the limit of detection. This gives a "worst case" Dioxins & Furans result.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

DIOXINS & FURANS ANALYSIS SUMMARY - FIELD BLANK RUN 1

NATO I-TEQ & WHO TEQ (Humans / Mammals)							
Congener	Result ng	NATO I-TEQ ng	WHO TEQ Humans / Mammals ng	Extraction Recovery		Sampling Recovery	
				Actual %	Permitted %	Actual %	Permitted %
Dioxins							
2,3,7,8 Tetra CDD	< 0.00042	0.000423	0.000423	96	50% - 130%		
1,2,3,7,8 Penta CDD	0.00203	0.001015	0.002030	73	50% - 130%		
1,2,3,4,7,8 Hexa CDD	< 0.00065	0.000065	0.000065	89	50% - 130%		
1,2,3,6,7,8 Hexa CDD	< 0.00066	0.000066	0.000066	88	50% - 130%		
1,2,3,7,8,9 Hexa CDD	< 0.00068	0.000068	0.000068		-		
1,2,3,4,6,7,8 Hepta CDD	0.0088	0.000088	0.000088	73	40% - 130%		
OCDD Octa CDD	0.0405	0.000041	0.000012	75	40% - 130%		
TOTAL 2,3,7,8-Dioxins	0.053741	0.0018	0.0028				
Furans							
2,3,7,8 Tetra CDF	0.00753	0.000753	0.000753	90	50% - 130%		
1,2,3,7,8 Penta CDF	0.00192	0.000096	0.000058		-	85	>=50
2,3,4,7,8 Penta CDF	0.00266	0.001330	0.000798	78	50% - 130%		
1,2,3,4,7,8 Hexa CDF	0.00118	0.000118	0.000118	87	50% - 130%		
1,2,3,6,7,8 Hexa CDF	0.00144	0.000144	0.000144	86	50% - 130%		
2,3,4,6,7,8 Hexa CDF	0.0014	0.000140	0.000140	88	50% - 130%		
1,2,3,7,8,9 Hexa CDF	< 0.00044	0.000044	0.000044		-	82	>=50
1,2,3,4,6,7,8 Hepta CDF	0.00341	0.000034	0.000034	72	40% - 130%		
1,2,3,4,7,8,9 Hepta CDF	< 0.00054	0.000005	0.000005		-	86	>=50
OCDF Octa CDF	0.00558	0.000006	0.000002	69	40% - 130%		
TOTAL 2,3,7,8-Furans	0.026093	0.0027	0.0021				
Mean Recoveries (%)				82		84	
Total Isomers	0.079834	0.0044	0.0048				
Total ITEQ (<LOD = 0)		0.0037642	0.0041765				

NOTE: The Total Isomers result includes all isomers below the limit of detection. This gives a "worst case" Dioxins & Furans result.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

DIOXINS & FURANS ANALYSIS SUMMARY - FIELD BLANK RUN 1

WHO TEQ (Fish) & WHO TEQ (Birds)							
Congener	Result ng	WHO TEQ Fish ng	WHO TEQ Birds ng	Extraction Recovery		Sampling Recovery	
				Actual %	Permitted %	Actual %	Permitted %
Dioxins							
2,3,7,8 Tetra CDD	< 0.00042	0.000423	0.000423	96	50% - 130%		
1,2,3,7,8 Penta CDD	0.00203	0.002030	0.002030	73	50% - 130%		
1,2,3,4,7,8 Hexa CDD	< 0.00065	0.000327	0.000033	89	50% - 130%		
1,2,3,6,7,8 Hexa CDD	< 0.00066	0.000007	0.000007	88	50% - 130%		
1,2,3,7,8,9 Hexa CDD	< 0.00068	0.000007	0.000007		-		
1,2,3,4,6,7,8 Hepta CDD	0.0088	0.000009	0.000009	73	40% - 130%		
OCDD Octa CDD	0.0405	-	-	75	40% - 130%		
TOTAL 2,3,7,8-Dioxins	0.053741	0.0028	0.0025				
Furans							
2,3,7,8 Tetra CDF	0.00753	0.000377	0.007530	90	50% - 130%		
1,2,3,7,8 Penta CDF	0.00192	0.000096	0.000019		-	85	>=50
2,3,4,7,8 Penta CDF	0.00266	0.001330	0.002660	78	50% - 130%		
1,2,3,4,7,8 Hexa CDF	0.00118	0.000118	0.000118	87	50% - 130%		
1,2,3,6,7,8 Hexa CDF	0.00144	0.000144	0.000144	86	50% - 130%		
2,3,4,6,7,8 Hexa CDF	0.0014	0.000140	0.000140	88	50% - 130%		
1,2,3,7,8,9 Hexa CDF	< 0.00044	0.000044	0.000044		-	82	>=50
1,2,3,4,6,7,8 Hepta CDF	0.00341	0.000034	0.000034	72	40% - 130%		
1,2,3,4,7,8,9 Hepta CDF	< 0.00054	0.000005	0.000005		-	86	>=50
OCDF Octa CDF	0.00558	0.000001	0.000001	69	40% - 130%		
TOTAL 2,3,7,8-Furans	0.026093	0.0023	0.0107				
Mean Recoveries (%)				82		84	
Total Isomers	0.079834	0.0051	0.0132				
Total ITEQ (<LOD = 0)		0.0042780	0.0126847				

NOTE: The Total Isomers result includes all isomers below the limit of detection. This gives a "worst case" Dioxins & Furans result.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS - RUN 1			Dioxins & Furans	
Absolute pressure of stack gas, P_s			Molecular weight of dry gas, M_d	
Barometric pressure, P _b	kPa	101.00	CO ₂	% 1.79
Stack static pressure, P _{static}	Pa	68.00	O ₂	% 19.09
P _s = P _b + (P _{static})	kPa	101.07	Total	% 20.88
			N ₂ (100 -Total)	% 79.12
			M _d = 0.44(%CO ₂)+0.32(%O ₂)+0.28(%N ₂)	29.05
Vol. of water vapour collected, V_{wstd}			Molecular weight of wet gas, M_s	
Moisture trap weight increase, V _{lc}	g	294.7	M _s = M _d (1 - B _{wo}) + 18(B _{wo})	g/gmol 28.22
V _{wstd} = (0.001246)(V _{lc})	m ³	0.3672	Velocity of stack gas, V_s	
Volume of gas metered dry, V_{mstd}			Velocity pressure coefficient, C _p	
Volume of gas sample through gas meter, V _m	m	4.95		0.84
Gas meter correction factor, Y _d		0.99	Mean of velocity heads, DP _{avg}	Pa 141.42
Mean dry gas meter temperature, T _m		297.00	Mean stack gas temperature, T _s	K 328.00
Mean pressure drop across orifice, DH	mmH ₂ O	17.61	Gas density (wet, ambient), ρ	
			ρ = (M _s *P _s)/(8.314*T _s)	kg/m ³ 1.046
V _{mstd} = $\frac{(0.3592)(V_m)(P_b + (DH/13.6))(Y_d)}{T_m + 273}$	m ³	4.51	Stack Velocity, V _s	$V_s = \frac{\sum_{i=1}^n V_i}{n}$ m/s 13.80
Volume of gas metered wet, V_{mstw}			Actual flow of stack gas, Q_a	
V _{mstw} = V _{mstd} + V _{wstd}	m ³	4.8765	Area of stack, A _s	m ² 4.16
Vol. of gas metered at O₂ Ref. Cond., V_{mstd@X%O2}			Q _a = (60)(A _s)(V _s)	
Is the process burning hazardous waste? (if yes, no favourable oxygen correction)	No			m ³ /min 3440.9
% oxygen measured in gas stream, act%O ₂	19.09		Total flow of stack gas, Q	
% oxygen reference condition	21		Conversion factor (K/mm.Hg)	
O ₂ Reference O ₂ Ref = 21.0 - act%O ₂	No O ₂ Ref		Q _{std} = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})}{(T_s)}$	Dry 2641.3
Factor 21.0 - ref%O ₂	No O ₂ Ref		Q _{stdO2} = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})(O_2REF)}{(T_s)}$	@O2ref No O ₂ Ref
V _{mstd@X%oxygen} = (V _{mstd}) (O ₂ Ref)	m ³	No O ₂ Ref	Q _{stw} = $\frac{(Q_a)P_s(0.3592)}{(T_s)}$	Wet 2856
Moisture content, B_{wo}			Percent isokinetic, %I	
B _{wo} = $\frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.0753	Nozzle diameter, D _n	mm 5.0
	%	7.53	Nozzle area, A _n	mm ² 19.6
Moisture by FTIR			Total sampling time, q	
	%	-		min 360.0
			%I = $\frac{(4.6398E6)(T_s)(V_{mstd})}{(P_s)(V_s)(A_n)(q)(1-B_{wo})}$	% 100.6
			Acceptable isokinetic range 95% to 115%	
				Yes

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

DIOXINS & FURANS QUALITY ASSURANCE CHECKLIST

Leak Test Results	Mean Sampling litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Leak Tests Acceptable litre/min	Acceptable Leak Rate litre/min	Leak Tests Acceptable litre/min
Run 1	13.65	0.19	0.19	-381	Yes	0.68	Yes

Isokinetic Criterion Compliance	Isokinetic Variation %	Acceptable Isokineticity %
Run 1	100.6	Yes

Acceptable isokinetic range 95% to 115%

Filtration	Filter Material	Filter Size mm	Maximum Filtration Temperature °C
Run 1	Quartz Fibre	47	120

Critical Sampling Requirement	Maximum Temperature at Condenser / Adsorber °C	Acceptable Temperature?	Temperature during storage / transit <25°C
Run 1	0	Yes	Yes
Acceptance Criteria	< 20°C	-	< 25°C

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

FORMALDEHYDE SUMMARY					
Test	Sampling Times	Concentration mg/m ³	LOD mg/m ³	ELV mg/m ³	Emission Rate g/hr
Run 1	12:10 - 12:42 30 September 2025	4.29	0.022	15	1165.1
Field Blank	-	0.053	-	-	-

Reference conditions are 273K, 101.3kPa, dry gas .

FORMALDEHYDE QUALITY ASSURANCE CHECKLIST

	Barometric Pressure Kpa	Average Oxygen Value for Referencing %	Total Sample Volume @ ref Conditions m ³	Mean Sampling Rate l/min	Pre Sampling Leak Rate l/min	Post Sampling Leak Rate l/min	Acceptable Leak Rate l/min	Leak Tests Acceptable?
Run 1	101.0	-	0.709	24.1	0.13	-	0.48	Yes

	Filter Material	Filter Size mm	Max. Filtration Temp. °C	Temperature during storage / transit <25°C	Type of Absorbers	Absorption Solutions
Run 1	Glass Fibre	47	57	0	PTFE	Analytical Grade Water

FORMALDEHYDE ABSORPTION EFFICIENCY

Parameter	Total ug	IMP C ug	Absorption Efficiency %	Acceptable Absorption Efficiency %	Absorption Efficiency Acceptable ?
Run 1	3045.9	15.6	99	95	Yes

ND - None Detected

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS 1			Formaldehyde	
Absolute pressure of stack gas, P_s			Velocity of stack gas, V_s	
Barometric pressure, P _b	kPa	101	Velocity pressure coefficient, C _p	0.84
Stack static pressure, P _{static}	Pa	81	Mean of velocity heads, DP _{avg}	Pa 414.05
P _s = P _b + (P _{static})	kPa	101.08	Mean stack gas temperature, T _s	K 330.00
Vol. of water vapour collected, V_{wstd}			Gas density (wet, ambient), ρ	kg/m ³ 1.041
Moisture trap weight increase, V _{lc}	g	-	p=(Ms*Ps)/(8.314*Ts)	
V _{wstd} = (0.001246)(V _{lc})	m ³	-	Stack Velocity, V _s	m/s 23.68
Volume of gas metered dry, V_{mstd}			Actual flow of stack gas, Q_a	
Volume of gas sample through gas meter, V _m	m ³	0.7752	Area of stack, A _s	m ² 4.16
Gas meter correction factor, Y _d		0.9933	Q _a = (60)(A _s)(V _s)	m ³ /min 5904
Mean dry gas meter temperature, T _m	K	296.88	Dry total flow of stack gas, Q_{std}	
Mean pressure drop across orifice, DH	mmH ₂ O	51.38	Conversion factor (K/mm.Hg)	0.3592
V _{mstd} = $\frac{(0.3592)(V_m)(P_b + (DH/13.6))(Y_d)}{T_m}$	m ³	0.71	Q _{std} = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})}{(T_s)}$	m ³ /min 4522
Volume of gas metered wet, V_{mstw}			Wet total flow of stack gas, Q_{stw}	
V _{mstw} = V _{mstd} + V _{wstd}	m ³	0.7642	Q _{stw} = $\frac{(Q_a)P_s(0.3592)}{(T_s)}$	m ³ /min 4872
Vol. of gas metered at O₂ Ref. Cond., V_{mstd@X%O₂}			Dry total flow of stack gas at X% O₂, Q_{stdO₂}	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)	No		Q _{stdO₂} = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})(O_2REF)}{(T_s)}$	m ³ /min No O ₂ Ref
% oxygen measured in gas stream, act%O ₂	19.09		Percent isokinetic, %I	
% oxygen reference condition	21		Nozzle diameter, D _n	mm 4.99
O ₂ Reference Factor = $\frac{O_2 Ref = 21.0 - act\%O_2}{21.0 - ref\%O_2}$	No O ₂ Ref		Nozzle area, A _n	mm ² 19.59
V _{mstd@X%oxygen} = (V _{mstd}) (O ₂ Ref)	m ³	No O ₂ Ref	Total sampling time, q	min 32
Moisture content, B_{wo}			%I = $\frac{(4.6398E6)(T_s)(V_{mstd})}{(P_s)(V_s)(A_n)(q)(1-B_{wo})}$	% 104
B _{wo} = $\frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.0719	Acceptable isokinetic range 95% to 115%	Yes
Moisture by FTIR		%	Formaldehyde Concentration, C	
Molecular weight of dry gas, M_d			Mass collected, M	ug 3046
CO ₂		1.79	C _{wet} = $\frac{M_n}{V_{mstw}}$	mg/m ³ 3.986
O ₂		19.09	C _{dry} = $\frac{M_n}{V_{mstd}}$	mg/m ³ 4.294
Total		20.88	C _{dry@X%O₂} = $\frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m ³ No O ₂ Ref
N ₂ (100 -Total)		79.12	Formaldehyde Emission Rates, E	
M _d = 0.44(%CO ₂)+0.32(%O ₂)+0.28(%N ₂)		29.05	E = $\frac{[(C_{wet})(Q_{stw})(60)]}{1000}$	g/hr 1165.13
Molecular weight of wet gas, M_s				
M _s = M _d (1 - B _{wo}) + 18(B _{wo})	g/gmol	28.3		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

TOTAL VOLATILE ORGANIC COMPOUNDS SUMMARY

Test	Sampling Times	Concentration mg/m ³	LOD mg/m ³	ELV mg/m ³	Emission Rate g/hr
Run 1	11:43 - 12:15 02 October 2025	13.99	0.30	120	2814.21

Reference conditions are 273K, 101.3kPa, dry gas .


INSTRUMENTAL SPAN & ZERO CHECKS

PRE-SAMPLING CALIBRATION CHECKS								
Date	02 October 2025							
Start Time	11:00							
End Time	11:40							
Gas	Span Conc (ppm)	Analyser Range	Instrument Zero Reading	Instrument Span Reading	Instrument Zero Reading	Zero Down line reading	Span down line reading	Leak Rate (%)
Propane	82.8	100	0.19	82.9	0.22	0.13	83.0	-0.12

Zero and Span gas contained 20.27% Oxygen

POST-SAMPLING CALIBRATION CHECKS								
Date	02 October 2025							
Start Time	12:55							
End Time	13:10							
Gas	Mean Raw Value ppm	Zero down line reading	Span down line reading	Zero Drift (%)	Span Drift (%)	Corrected for Zero Drift	Corrected for Span Drift	Corrected Values ppm / %
Propane	8.08	0.30	82.0	0.21	-1.41	x	x	N/A - not corrected

TOTAL VOLATILE ORGANIC COMPOUNDS EMISSIONS CHART



Reference conditions are 273K, 101.3kPa, dry gas .

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

COMBUSTION GASES SUMMARY

Test	Sampling Time and Date	Concentration mg/m ³	LOD mg/m ³	ELV mg/m ³	Emission Rate g/hr
Oxides of Nitrogen	13:29 - 14:28 30 September 2025	102.2	0.51	110	20552
Carbon Monoxide	13:29 - 14:28 30 September 2025	2.8	0.28	300	555.24

Reference conditions are 273K, 101.3kPa, dry gas .

PRE-SAMPLING CALIBRATION DATA

Date	30 September 2025
Start Time	12:10
End Time	13:15

Chiller Temperature (°C)	2.3
Requirement	< 4°C
Compliant	Yes

Gas	Analyser Range (ppm / %)	Zero Reading at analyser	Span Reading at analyser	Zero Check at analyser	Zero Check down line	Span Check down line	Response Time (Secs)	Leak Rate %
Nitric Oxide	250	0.00	200.9	0.10	0.20	200.8	23	0.05
Carbon Monoxide	200	0.10	164.1	0.20	0.10	163.9	22	0.12


POST-SAMPLING CALIBRATION DATA

Date	30 September 2025
Start Time	15:10
End Time	15:20


Chiller Temperature (°C)	2.4
Requirement	< 4°C
Compliant	Yes

Gas	Zero Check at Analyser	Span Check at Analyser	Zero Drift (% of Span Gas)	Span Drift (% of Span Gas)	Corrected for Zero Drift	Corrected for Span Drift	Corrected Values ppm / %
Nitric Oxide	0.30	200.1	0.10	-0.50	×	×	N/A - not corrected
Carbon Monoxide	0.10	161.9	-0.06	-1.28	×	×	N/A - not corrected

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts
OXIDES OF NITROGEN (as NO₂) EMISSIONS CHART



CARBON MONOXIDE EMISSIONS CHART



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

MOISTURE CALCULATIONS

Moisture Determination - Isokinetic							
Test Number	Sampling Time and Date	Start Weight	End Weight	Total gain	Concentration	LOD	Uncertainty
		kg	kg	kg	%	%	%
Run 1	12:10 - 12:42 30 September 2025	1.6494	1.6935	0.0441	7.2	0.02	2.7

Moisture Quality Assurance							
Test Number	Sampling Duration	Total Volume Sampled	Sampling Rate	Start Leak Rate	End Leak Rate	Acceptable Leak Rate	Leak Tests Acceptable?
	mins	l	l/min	l/min	l/min	l/min	
Run 1	32	764	24.1	0.13	-	0.48	Yes

PRELIMINARY STACK SURVEY

Stack Characteristics		
Stack Diameter / Depth, D	2.30	m
Stack Width, W	-	m
Stack Area, A	4.16	m ²
Average stack gas temperature	58	°C
Stack static pressure	0.083	kPa
Barometric Pressure	101	kPa

Stack Gas Composition & Molecular Weights								
Component	Molar Mass M	Density kg/m ³ p	Conc Dry % Vol	Dry Volume Fraction r	Dry Conc kg/m ³ pi	Conc Wet % Vol	Wet Volume Fraction r	Wet Conc kg/m ³ pi
CO ₂	44	1.963059	1.789517	0.017895	0.035129	1.660846	0.016608	0.032603
O ₂	32	1.427679	19.544295	0.195443	0.279030	18.139005	0.181390	0.258967
N ₂	28	1.249219	78.666188	0.786662	0.982713	73.009870	0.730099	0.912053
H ₂ O	18	0.803070	-	-	-	7.190278	0.071903	0.057743

Where: $p = M / 22.41$ $pi = r \times p$

Calculation of Stack Gas Densities		
Determinand	Result	Units
Dry Density (STP), P_{STD}	1.2969	kg/m ³
Wet Density (STP), P_{STW}	1.2614	kg/m ³
Dry Density (Actual), P_{Actual}	1.0689	kg/m ³
Average Wet Density (Actual), $P_{ActualW}$	1.040	kg/m ³

Where:

$$P_{STD} = \text{sum of component concentrations, kg/m}^3 \text{ (not including water vapour)}$$

$$P_{Actual} = P_{STD} \times (Ts / Ps) \times (Pa / Ta)$$

$$P_{STW} = (P_{STD} + pi \text{ of H}_2\text{O}) / (1 + (pi \text{ of H}_2\text{O} / 0.8036))$$

$$P_{ActualW} = P_{STW} \times (Ts / Ps) \times (Pa / Ta)$$

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PRELIMINARY STACK SURVEY

TRAVERSE 1

Date of Survey	30 September 2025
Time of Survey	12:20
Velocity Measurement Device:	S-Type Pitot

Sampling Line A								
Traverse Point	Distance into duct (m)	DP pt Pa (average of 3 readings)	DP pt mmH ₂ O (average of 3 readings)	Temp °C	Velocity m/s	Volumetric Flow Rate (actual) m ³ /s	O ₂ % Vol	Angle of Swirl °
1	0.07	473.7	48.3	57	25.4	105.3	-	<15
2	0.21	343.0	35.0	57	21.6	89.6	-	<15
3	0.38	294.0	30.0	57	20.0	83.0	-	<15
4	0.61	267.9	27.3	57	19.1	79.2	-	<15
5	1.15	251.5	25.7	57	18.5	76.8	-	<15
6	1.69	173.1	17.7	57	15.3	63.7	-	<15
7	1.92	124.1	12.7	57	13.0	53.9	-	<15
8	2.09	88.2	9.0	57	10.9	45.5	-	<15
9	2.23	58.8	6.0	57	8.9	37.1	-	<15
-	-	-	-	-	-	-	-	-
Mean	-	230.5	23.5	57	17.0	70.5	-	-

Sampling Line B								
Traverse Point	Distance into duct (m)	DP pt Pa (average of 3 readings)	DP pt mmH ₂ O (average of 3 readings)	Temp °C	Velocity m/s	Volumetric Flow Rate (actual) m ³ /s	O ₂ % Vol	Angle of Swirl °
1	0.07	460.6	47.0	58	25.0	103.9	-	<15
2	0.21	408.3	41.7	58	23.5	97.8	-	<15
3	0.38	343.0	35.0	58	21.6	89.6	-	<15
4	0.61	294.0	30.0	58	20.0	83.0	-	<15
5	1.15	264.6	27.0	58	18.9	78.7	-	<15
6	1.69	209.1	21.3	58	16.8	70.0	-	<15
7	1.92	169.9	17.3	58	15.2	63.1	-	<15
8	2.09	130.7	13.3	58	13.3	55.3	-	<15
9	2.23	65.3	6.7	58	9.4	39.1	-	<15
-	-	-	-	-	-	-	-	-
Mean	-	260.6	26.6	58	18.2	75.6	-	-

PRELIMINARY STACK SURVEY QUALITY ASSURANCE CHECKLIST

PITOT LEAK CHECK								
Run	Pre Traverse Leak Rate				Post Traverse Leak Rate			
	Start Value mmH ₂ O	End Value mmH ₂ O	Difference %	Outcome	Start Value mmH ₂ O	End Value mmH ₂ O	Difference %	Outcome
Run 1	147	147	0.0	Pass	129	129	0.0	Pass

To complete a compliant pitot leak check a pressure of over 80 mmH₂O (or 800 Pa) is applied and the pressure drop monitored over 15 seconds. A drop of less than 5% must be observed.

S-Type Pitot Stagnation Check				
Run	Stagnation (Pa)	Reference (Pa)	Difference (Pa)	Outcome (Permitted +/- 10 Pa)
Run 1	85	81	4.0	Pass

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PRELIMINARY STACK SURVEY (CONTINUED)

Sampling Plane Validation Criteria				
EA Technical Guidance Note (Monitoring) M1	Result	Units	Requirement	Compliant
Lowest Average Differential Pressure	59	Pa	>= 5 Pa	Yes
Lowest Gas Velocity	8.9	m/s	-	-
Highest Gas Velocity	25.4	m/s	-	-
Ratio of Gas Velocities	2.8	-	< 3 : 1	Yes
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes
No local negative flow	Yes	-	-	Yes

Calculation of Stack Gas Velocity, V		
Velocity at Traverse Point, $V = K_{pt} \times (1-e) \times \sqrt{2 * DP_{pt} / P_{ActualW}}$		
Where:		
K_{pt} = Pitot tube calibration coefficient		
(1-e) = Compressibility correction factor, assumed at a constant 0.998		
Average Stack Gas Velocity, V_a	17.6	m/s

Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	58	0	°C
Total Pressure	101.083	101.3	kPa
Oxygen	19.1	21	%
Moisture	7.19	0.00	%
Pitot tube calibration coefficient, K_{pt}	0.84		

Gas Volumetric Flowrate	Result	Units
Average Stack Gas Velocity (V_a)	17.58	m/s
Stack Area (A)	4.16	m ²
Gas Volumetric Flowrate (Actual), Q_{Actual}	262945.91	m ³ /hr
Gas Volumetric Flowrate (STP, Wet), Q_{STP}	216733.62	m ³ /hr
Gas Volumetric Flowrate (STP, Dry), $Q_{STP,Dry}$	201149.87	m ³ /hr
Gas Volumetric Flowrate (REF), Q_{Ref}	201149.87	m ³ /hr

Where:

$$Q_{Actual} = V_a \times A \times 3600$$

$$Q_{STP} = Q (Actual) \times (T_s / T_a) \times (P_a / P_s)$$

$$Q_{STP,Dry} = Q (STP) / (100 - (100 / Ma))$$

$$Q_{Ref} = Q (STP) \times ((100 - Ma) / (100 - Ms)) \times ((21 - O_{2a}) / (21 - O_{2s}))$$

Nomenclature:

T_s = Absolute Temperature, Standard Conditions, 273 K

P_s = Absolute Pressure, Standard Conditions, 101.3 kPa

T_a = Absolute Temperature, Actual Conditions, K

P_a = Absolute Pressure, Actual Conditions, kPa

Ma = Water vapour, Actual Conditions, % Vol

Ms = Water vapour, Reference Conditions, % Vol

O_{2a} = Oxygen, Actual Conditions, % Vol


O_{2s} = Oxygen, Reference Conditions, % Vol

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

STACK DIAGRAM

	Value	Units
Stack Depth	2.30	m
Stack Width	-	m
Area	4.16	m ²

Non-Isokinetic/Gases Sampling			
Sampling Point	Distance (% of Depth)	Distance into Stack	Units
A	30	0.69	m



- Isokinetic sampling point
- Isokinetic sampling points not used
- Non Isokinetic/Gases sampling point

Isokinetic Sampling			
Sampling Point	Distance (% of Depth)	Distance into Stack (m)	Swirl °
1	2.9	0.07	< 15
2	9.2	0.21	< 15
3	16.7	0.38	< 15
4	26.4	0.61	< 15
5	50.0	1.15	< 15
6	73.6	1.69	< 15
7	83.3	1.92	< 15
8	90.8	2.09	< 15
9	97.1	2.23	< 15
10	2.9	0.07	< 15
11	9.2	0.21	< 15
12	16.7	0.38	< 15
13	26.4	0.61	< 15
14	50.0	1.15	< 15
15	73.6	1.69	< 15
16	83.3	1.92	< 15
17	90.8	2.09	< 15
18	97.1	2.23	< 15
-	-	-	-
-	-	-	-

APPENDIX 3 - Measurement Uncertainty Budget Calculations

MEASUREMENT UNCERTAINTY BUDGET - TOTAL PARTICULATE MATTER

Run	Sampled Volume m ³	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Limit of Detection % by mass	Leak %	Uncollected Mass mg
MU required	≤ 2%	≤ 2%	≤ 1%	≤ 1%	≤ 10%	≤ 5% of ELV	≤ 2%	≤ 10% of ELV
Run 1	0.001	2.0	0.50	1.0	N/A	0.06	-	-
as a %	0.20	0.61	0.50	1.0	N/A	0.42	0.54	0.000
compliant?	Yes	Yes	Yes	Yes	N/A	Yes	Yes	Yes

Run	Volume (STP) m ³	Mass of particulate mg	O ₂ Correction -	Leak mg/m ³	Uncollected Mass mg	Combined uncertainty
Run 1	0.59	4.0600	1.0	0.0179	0.0000	-
MU as mg/m ³	0.0740	0.0846	-	0.0179	0.0000	0.11
MU as %	1.29	1.4778	-	0.312	0.0009	-

R1 - Uncertainty expressed at a 95% confidence level (where k = 2)	0.23	mg/m³	3.98	% Result	1.14	% ELV
---	-------------	-------------------------	-------------	-----------------	-------------	--------------

(k is a coverage factor which gives a 95% confidence in the quoted figures)

Reference – SOCOTEC Technical Procedure AE150 Estimation of Uncertainty of Measurement

APPENDIX 3 - Measurement Uncertainty Budget Calculations

MEASUREMENT UNCERTAINTY BUDGET - DIOXINS & FURANS

Run	Sampled Volume m ³	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Leak %	Uncollected Mass ng/m ³
MU required	≤ 2%	≤ 2%	≤ 1%	≤ 1%	≤ 10%	≤ 5%	≤ 10% ELV
Run 1	0.009	2.0	0.50	1.0	N/A	-	0.00098
as a %	0.20	0.7	0.50	1.0	N/A	1.39	N/A
compliant?	Yes	Yes	Yes	Yes	N/A	Yes	N/A

Run	Volume (STP) m ³	O2 Correction -	Mass of Dioxin & Furan ng	Leak ng/m ³	Uncollected Mass ng/m ³	Laboratory analysis -	Combined uncertainty
Run 1	4.1327	1.0	0.0908	0.00001	0.00057	-	-
MU as ng/m ³	0.0000	-	0.0001	0.00001	0.0004099	0.0001	0.0004
MU as %	1.3214	-	14.2857	0.8037	52.1118	8.60	-

R1 - Uncertainty expressed at a 95% confidence level (where k = 2)	0.0009	ng/m³	109.5	% Result	N/A	% ELV
---	---------------	-------------------------	--------------	-----------------	------------	--------------

(k is a coverage factor which gives a 95% confidence in the quoted figures)

Reference – SOCOTEC Technical Procedure AE150 Estimation of Uncertainty of Measurement

APPENDIX 3 - Measurement Uncertainty Budget Calculations

MEASUREMENT UNCERTAINTY BUDGET - ISOKINETIC FORMALDEHYDE

Run	Sampled Volume m ³	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Limit of Detection % by mass	Leak %
MU required	<=2%	<2.5 k	<=1%	<=1%	<=10%	≤ 5% of ELV	<=2%
Run 1	0.709	297	101.81	1.0	-	4.5	-
as a %	0.14	0.67	0.49	1.0	-	0.32	0.54
compliant?	Yes	Yes	Yes	Yes	N/A	Yes	Yes

Run	Volume (STP) m ³	Mass of Formaldehyde mg	O2 Correction -	Leak mg/m ³	Lab Uncertainty mg	Combined uncertainty
Run 1	0.6555	4.4988	-	0.0134	-	-
MU as mg/m ³	0.0563	0.0475	-	0.0134	0.5089	0.5144
MU as %	1.3108	1.1060	-	0.3119	11.9	-

R1 - Uncertainty expressed at a 95% confidence level (where k = 2)	1.03	mg/m³	23.96	% Result	6.86	% ELV
---	-------------	-------------------------	--------------	-----------------	-------------	--------------

(k is a coverage factor which gives a 95% confidence in the quoted figures)
Reference – SOCOTEC Technical Procedure AE150 Estimation of Uncertainty of Measurement

APPENDIX 3 - Measurement Uncertainty Budget Calculations

MEASUREMENT UNCERTAINTY BUDGET - MOISTURE

Run	Sampled Volume m ³	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Leak %
MU required	≤ 2%	≤ 2%	≤ 1%	≤ 1%	≤ 10%	≤ 2%
Run 1	0.0014	2.0	0.50	1.0	N/A	-
as a %	0.20	0.61	0.50	1.0	N/A	0.54
compliant?	Yes	Yes	Yes	Yes	N/A	Yes

Run	Volume (STP) m ³	Mass Gained mg	O ₂ Correction -	Leak mg/m ³	Uncollected Mass mg	Combined uncertainty
Run 1	0.59	44100	1.0	193.94	58	-
MU as % v/v	0.101	0.018	-	0.024	0.010	0.106
MU as %	1.29	0.23	-	0.31	0.13	-

R1 - Uncertainty expressed at a 95% confidence level (where k = 2)	0.21	% v/v	2.71	%
---	-------------	--------------	-------------	----------

APPENDIX 3 - Measurement Uncertainty Budget Calculations

MEASUREMENT UNCERTAINTY BUDGET - VOLATILE ORGANIC COMPOUNDS RUN 1

Measured Concentration	14.0	mg/m ³
Limit	120	mg/m ³
Calibration Gas Concentration	132.48	mg/m ³
Range	160	mg/m ³

Performance characteristics	Value	Units	specification	MU Met?
Response time	31	seconds	<180	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	32	minutes	-	-
Number of readings in measurement	32	-	-	-
Repeatability at zero	0.25	% full scale	<1 % range	Yes
Repeatability at span level	0.15	% full scale	<2 % range	Yes
Deviation from linearity	0.70	% of value	<2 % range	Yes
Zero drift	0.21	% full scale	<5% range / 24hr	Yes
Span drift	-1.41	% full scale	<5% range / 24hr	Yes
volume or pressure flow dependence	0.02	% of full scale/3 kPa	<2 % / 3 kPa	Yes
atmospheric pressure dependence	0.80	% of full scale/2 kPa	<3% / 2 kPa	Yes
ambient temperature dependence	0.01	% full scale/10K	<3% range / 10 K	Yes
dependence on voltage	0.10	% full scale/10V	< 0.1%vol /10 volt	Yes
losses in the line (leak)	-0.12	% of value	< 2% of span gas value	Yes
Uncertainty of calibration gas	1.0	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	0.03
Standard deviation of repeatability at span level	urs	0.03
Lack of fit	ufit	0.65
Drift	u0dr	0.03
volume or pressure flow dependence	uspres	0.00
atmospheric pressure dependence	uapres	0.04
ambient temperature dependence	utemp	0.00
Dependence on voltage	uvolt	0.14
losses in the line (leak)	uleak	-0.01
Uncertainty of calibration gas	ucalib	0.08
Uncertainty in factor	uf	0.03

Measurement uncertainty Measured Concentration	13.99	mg/m ³
Combined uncertainty	0.67	mg/m ³
Expanded uncertainty	1.31	mg/m ³

Expanded uncertainty expressed with a level of confidence of 95%	1.09	% ELV
Expanded uncertainty expressed with a level of confidence of 95%	1.31	mg/m³
Expanded uncertainty expressed with a level of confidence of 95%	9.38	% value

Reference – SOCOTEC Technical Procedure AE150 Estimation of Uncertainty of Measurement

APPENDIX 3 - Measurement Uncertainty Budget Calculations

MEASUREMENT UNCERTAINTY BUDGET - OXIDES OF NITROGEN

Limit value	110	mg/m ³
Concentration @ Ref conditions	102.2	mg/m ³
Cal gas conc	412	mg/m ³
Analyser Full Scale	513	mg/m ³

	Value	Units	specification	MU Met?
Response time	23	seconds	180	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	59	minutes	-	-
Number of readings in measurement	59	-	-	-
Repeatability at zero	0.11	% full scale	<1 % range	Yes
Repeatability at span level	0.1	% full scale	<2 % range	Yes
Deviation from linearity	-0.40	% of value	<2 % range	Yes
Zero drift	0.10	% full scale	<5% range / 24hr	Yes
Span drift	-0.50	% full scale	<5% range / 24hr	Yes
volume or pressure flow dependence	0.25	% of full scale/3 kPa	<2 % / 3 kPa	Yes
atmospheric pressure dependence	0.25	% of full scale/2 kPa	<3% / 2 kPa	Yes
ambient temperature dependence zero / span	0.00	% full scale/10K	<3% range / 10 K	Yes
Combined interference	-0.01	% range	<4% of Range	Yes
dependence on voltage	0.04	% full scale/10V	< 0.1%vol / 10 volt	Yes
Influence of Vibration	N/A	% of upper limit of Cal range	<2%	-
losses in the line (leak)	0.04	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
repeatability	$U_r = S_r$	0.0037
lack of fit	U_{lof}	-0.2309
short term zero drift	$U_{d,z}$	0.0579
short term span drift	$U_{d,s}$	-0.2872
influence of Ambient Temp at Zero	$U_{t,z}$	0.0000
influence of Ambient Temp at Span	$U_{t,s}$	0.6750
influence of sample gas pressure	U_p	0.0000
influence of sample gas flow	U_{fit}	0.1732
influence of supply voltage	U_v	0.1099
Combined Interference	U_i	-0.0018
Uncertainty of Cal gas	U_{adj}	2.0100

Measurement uncertainty (Concentration Measured)	102.17	mg/m ³
Combined uncertainty	2.16	mg/m ³
Expanded at a 95% confidence interval	4.24	mg/m ³

Expanded uncertainty expressed with a level of confidence of 95%	3.85	% ELV
---	-------------	--------------

Expanded uncertainty expressed with a level of confidence of 95%	4.2	mg/m³
---	------------	-------------------------

Expanded uncertainty expressed with a level of confidence of 95%	4.1	% value
---	------------	----------------

Reference – SOCOTEC Technical Procedure AE150 Estimation of Uncertainty of Measurement

APPENDIX 3 - Measurement Uncertainty Budget Calculations

MEASUREMENT UNCERTAINTY BUDGET - CARBON MONOXIDE

Limit value	300	mg/m ³
Concentration @ Ref conditions	2.8	mg/m ³
Cal gas conc	205.4	mg/m ³
Analyser Full Scale	250	mg/m ³

Performance characteristics	Value	Units	specification	MU Met?
Response time	22	seconds	180	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	59	minutes	-	-
Number of readings in measurement	59	-	-	-
Repeatability at zero	0.1	% full scale	<1 % range	Yes
Repeatability at span level	0.2	% full scale	<2 % range	Yes
Deviation from linearity	0.61	% of value	<2 % range	Yes
Zero drift	-0.06	% full scale	<5% range / 24hr	Yes
Span drift	-1.28	% full scale	<5% range / 24hr	Yes
volume or pressure flow dependence	0.2	% of full scale/3 kPa	<2 % / 3 kPa	Yes
atmospheric pressure dependence	0.44	% of full scale/2 kPa	<3% / 2 kPa	Yes
ambient temperature dependence zero / span	-0.8	% full scale/10K	<3% range / 10 K	Yes
Combined interference	-0.01	% of Range	<4% of Range	Yes
dependence on voltage	-0.06	% full scale/10V	< 0.1%vol /10 volt	Yes
Influence of Vibration	N/A	% of upper limit of Cal range	<2%	N/A
losses in the line (leak)	0.00	% of value	< 2% of value	Yes
Uncertainty of calibration gas	1.00	% of value	< 2% of value	Yes

N/A - Horiba's are not effected by Vibration

Performance characteristic	Uncertainty	Value of uncertainty quantity
repeatability	$U_r = S_r$	0.003
lack of fit	U_{lof}	0.12
short term zero drift	$U_{d,z}$	0.35
short term span drift	$U_{d,s}$	-0.03
influence of Ambient Temp zero	$U_{t,z}$	-0.01
influence of Ambient Temp span	$U_{t,s}$	0.05
influence of sample gas pressure	U_p	0.00
influence of sample gas flow	U_{fit}	0.14
influence of supply voltage	U_v	-0.09
Combined Interference	U_i	-0.22
Uncertainty of Cal gas	U_{adj}	0.82

Measurement uncertainty (Concentration Measured)	2.8	mg/m ³
Combined uncertainty	0.9	mg/m ³
Expanded uncertainty	1.9	mg/m ³

Expanded uncertainty expressed with a level of confidence of 95%	0.6	% ELV
Expanded uncertainty expressed with a level of confidence of 95%	1.9	mg/m³
Expanded uncertainty expressed with a level of confidence of 95%	67.1	% value

Reference – SOCOTEC Technical Procedure AE150 Estimation of Uncertainty of Measurement

APPENDIX 3 - Measurement Uncertainty Budget Calculations

MEASUREMENT UNCERTAINTY BUDGET - VELOCITY & VOLUMETRIC FLOW RATE

Measured Velocity at Actual Conditions	17.6	m/s
Measured Volumetric Flow rate at Actual Conditions	262946	m ³ /hr

Performance Characteristics & Source of Value	Units	Values	Requirement	Compliant
Uncertainty of Local Gas Velocity Determination				
Uncertainty of pitot tube coefficient	-	0.010		
Uncertainty of mean local dynamic pressures	-	1.93		
Factor loading, function of the number of measurements.	3 readings	0.591	minimum 3	Yes
Range of measurement device	pa	1000		
Resolution	pa	1.00		
Calibration uncertainty	pa	37.33	<1% of Value or 20 Pa whichever is greater	Yes
Drift	% range	0.10		
Linearity	% range	0.06	<2% of value	Yes
Uncertainty of gas density determination				
Uncertainty of molar mass determination	kg/mol	0.00002		
Uncertainty of temperature measurement	K	1.69	<1% of value	Yes
Uncertainty of absolute pressure in the duct	pa	516		
Uncertainty associated with the calculation of density	kg/m ³	0.008		
Uncertainty associated with the measurement of local velocity	-	0.0001		
Uncertainty associated with the measurement of mean velocity	-	0.0002		

Measurement Uncertainty - Velocity	m/s
Combined uncertainty	0.22
Expanded uncertainty at a 95% Confidence Interval	0.43

Note - The expanded uncertainty uses a coverage factor of $k = 2$.

Expanded Measurement Uncertainty of Velocity at a 95% Confidence Interval	%
Expressed as a % of the Measured Velocity	1.2
Expanded uncertainty at a 95% Confidence Interval	2.4

Measurement Uncertainty Volumetric Flow Rate	m ³ /hr
Combined uncertainty	6900
Expanded uncertainty at a 95% Confidence Interval	13523

Note - The expanded uncertainty uses a coverage factor of $k = 2$.

Expanded Measurement Uncertainty of Volumetric Flow Rate at a 95% Confidence Interval	%
Expressed as a % of the Measured Volumetric Flow Rate	2.6
Expanded uncertainty at a 95% Confidence Interval	5.1

Reference – SOCOTEC Technical Procedure AE150 Estimation of Uncertainty of Measurement

END OF REPORT

Thank you for choosing SOCOTEC for your environmental monitoring needs. We hope our services have met your requirements and that you are fully satisfied with your experience of working with us, we really do value your custom and would welcome your feedback. We would appreciate it if you could take a moment to complete a short online questionnaire so that we can improve our operations and address any areas that have not met with your expectations, by clicking on the following

https://www.surveymonkey.co.uk/r/CAE_customer_feedback_weblink