

LS Rejection - Notice

Licence: P1113-02 - Echelon Clondalkin DC Services Limited

Submitted On: 28/09/2026

Licensee Submission LR108293 **Title** (P1113-02) Echelon Clondalkin DC Services Limited - DUB10 Noise Management Plan

Notification

Dear Mr Keogh,

The Agency has reviewed your submission LR108293, "(P1113-02) Echelon Clondalkin DC Services Limited - DUB10 Noise Management Plan" in relation to the noise management plan (NMP) required under Condition 6.13 of IE Licence P1113-02.

I am to advise you that this submission is not to the satisfaction of the Agency, in accordance with Condition 6.13.3.1. Please note the following for resubmission of the NMP for the installation:

- Section 6 does not have any information on modelled sound power data (in LwA) for each piece of equipment
- Section 8 does not address the requirements of Conditions 6.13.3.3 and 6.13.3.4. No information on proposed abatement measures in light of the volume of complaints has been provided.
- The contents of Section 12 and the appendices are not applicable under "implementation of the NMP". All these items should form part of the NMP.

Please note, the timescales for implementation of the NMP refer to the time taken to install any abatement or mitigation identified in accordance with Conditions 6.13.3.3 and 6.13.3.4.

The revised NMP is to be submitted to the Agency no later than two weeks from the date of this notice.

In addition, you, the licensee, are required to attend a compliance meeting at the EPA offices in Richview, Dublin, at 10.30am on Thursday 1st October 2026. Please confirm attendance no later than one day from the date of this notice.

If you have any questions regarding this matter please contact the undersigned.

Yours sincerely,

Dr Aoife Brennan

Office of Environmental Enforcement, Dublin

Tel: 01 2680100