

Incident INCI026203 for Greater Dublin Area Licence (D0034-01)

Notification No: INCI026203

Submitted: 25/09/2023 16:35

Licensee Details

Organisation:

Uisce Éireann

Licence Name:

Greater Dublin Area

Reg No:

D0034-01

Site Address:

Dublin

Notifier Details

Name:

Paul Nolan

Address:

1 Foley Street ,Dublin,Ireland

Phone:

01 6021345

Email:

panolan@water.ie

Details

Description of Incident:

There was a report of possible Waste Water Pollution issue at pedestrian footbridge over the Santry River close to Royal Oak, Santry, Dublin 9 on 24/09/2023 where a manhole surcharged onto the bridge walkway. The foul sewer was blocked and this was the cause of the discharge. The discharge was filtered through the locking cover so no ragging was discharged only liquids were discharged. Due to the filtered nature of the discharge and the high levels in the river the effect should be minimal. Jetter was called to clear the choke in the sewer line and the area was washed down afterwards.

Incident Category:

Category 1

Approximate Start of Incident:

24/09/2023 14:15

First Noticed:

24/09/2023 14:15

Still Ongoing:

No

End Date:

24/09/2023 18:00

New or Recurring Incident:

New

Incident Nature:

Uncontrolled Release

Impact of Incident on Environment:

The discharge was filtered through the locking cover so no ragging was discharged only liquids were discharged. Due to the filtered nature of the discharge and the high levels in the river the effect should be minimal.

Uncontrolled Release to Receptors:

Ground

Details of any Vulnerable Receptors:

Santry River

Likely Cause:

Blocked Sewer

Incident Location

Licensed Discharge Point: No

Location Description: Pedestrian footbridge over the Santry River close to Royal Oak, Santry, Dublin 9

Emission Parameter Results

Communication

EPA Informed by Telephone: No

EPA Informed Date:

EPA Informed Staff Member:

EPA Informed Contact Details:

Other Communications:

Notified	Contact Details / Telephone	Date
Department of Agriculture, Food and the Marine	email	25/09/2023 16:13
Bord Iascaigh Mhara	email	25/09/2023 16:13
Sea Fisheries Protection Authority	email	25/09/2023 16:13
Marine Institute	email	25/09/2023 16:13
Food Safety Authority of Ireland	email	25/09/2023 16:13
Inland Fisheries Ireland	email	25/09/2023 16:13

Additional Details

Activity in Process at time of incident:

Normal Activities

Corrective Actions Taken:

Action	Name	Date
A jetter was called to clear choke in the sewer and clean up the area afterwards.		24/09/2023 17:30

Preventive Actions to be Taken:

Action	Target Date
No preventative actions as the corrective actions implemented to clear the blocked sewer.	24/09/2023 00:00

Likelihood of Recurrence: Low

Other Revelant Information