Incident INCI032184 for Runways Information Services Limited Licence (P1192-01)

Notification No: INCI032184

Submitted: 06/02/2026 13:52

Licensee Details

Organisation:

Runways Information Services Limited

Licence Name:

Runways Information Services Limited

Reg No:

P1192-01

Site Address:

Slí Na Cháirde, Portan, Clonee, Meath, D15 NN9V

Notifier Details

Name:

Dominic Marshall

Address:

Meta Ballsbridge Campus ,Dublin,Ireland

Phone:

Email:

domm@meta.com

Details

Description of Incident:

During the period 2025 Q4, the peak wastewater flow discharge rates from the Clonee Data Centre (1-3 campus) discharging to licenced discharged point SE1, were not in compliance with the peak wastewater flow limits (m3/hour and m3/d) as set out in the IE Licence (noting below).
These occurrences took place on: October 1/ 20-22/ 25, November 3-16/ 18/ 25, December 2/ 8-11/ 19,.
All discharged flows during this period were within the limits of the Uisce Eireann connection agreement issued on 28 Feb 2024. A technical amendment has been submitted to the EPA to update the existing IE licence limits to reflect those in the Irish Water / Uisce Eireann Connection Agreement. The EPA are currently in the process of processing the technical amendment submission.

Incident Category:

Category 1

Approximate Start of Incident:

01/10/2025 00:00

First Noticed:

01/10/2025 00:00

Still Ongoing:

No

End Date:

10/10/2025 00:00

New or Recurring Incident:

Recurring

Incident Nature:

Other

Impact of Incident on Environment:

None

Uncontrolled Release to Receptors:

Water

Details of any Vulnerable Receptors:

None

Likely Cause:

Other (add details)

Exceedance incidents occurred during and following the receipt of inhibit signals from Irish Water / Uisce Eireann. All exceedances were within flow limits agreed with Uisce Eireann.

Incident Location

Licensed Discharge Point: No

Location Description: Licensed Discharge Point SE1.

Clonee 1/2/3 Terminal Pumping Station, specifically where site combined (process effluent + foul) effluent exits Meta property and discharges into Uisce Eireann sewer network

Emission Parameter Results

Communication

EPA Informed by Telephone: No

EPA Informed Date:

EPA Informed Staff Member:

EPA Informed Contact Details:

Other Communications:

Additional Details

Activity in Process at time of incident:

Normal Operations

Corrective Actions Taken:

Action	Name	Date
All discharged flows during this period were within the limits of the Uisce Eireann connection agreement issued on 28 Feb 2024. The Site has received an upgraded wastewater connection agreement with Uisce Eireann that allows for a higher volume of wastewater to be released from the facility (noting that a new connection offer with higher flows was received and approved 28 Feb 2024). The wastewater discharge from the Clonee DC campus was below the compliance limits of the connection agreement. A technical amendment has been submitted to the EPA to update the existing IE licence limits to reflect those in the Irish Water / Uisce Eireann Connection Agreement. The EPA are currently processing the technical amendment submission to address.		10/10/2025 00:00

Preventive Actions to be Taken:

Action	Target Date
All discharged flows during this period were within the limits of the Uisce Eireann connection agreement issued on 28 Feb 2024. The Site has received an upgraded wastewater connection agreement with Uisce Eireann that allows for a higher volume of wastewater to be released from the facility (noting that a new connection offer with higher flows was received and approved 28 Feb 2024). The wastewater discharge from the Clonee DC campus was below the compliance limits of the connection agreement. A technical amendment has been submitted to the EPA to update the existing IE licence limits to reflect those in the Irish Water / Uisce Eireann Connection Agreement. The EPA are currently processing the technical amendment submission to address.	06/02/2026 00:00

Likelyhood of Recurrence: Low

Other Revelant Information