

Incident INCI024391 for Arthurstown Landfill Licence (W0004-04)

Notification No: INCI024391

Submitted: 01/12/2022 15:15

Licensee Details

Organisation:

South Dublin County Council

Licence Name:

Arthurstown Landfill

Reg No:

W0004-04

Site Address:

Arthurstown, Kill, Kildare

Notifier Details

Name:

John Smith

Address:

South Dublin County Council PO Box 4122, Dublin, Ireland

Phone:

045 877674

Email:

arthurstownlandfill@eircom.net

Details

Description of Incident:

The concentration of COD in Oct (837 MG/L) and (1030mg/l) in Nov exceed it respective concentration of ELV 750mg/l

The concentration of ammonia in November (5.02mg/l) slightly exceeds the respective concentration ELV (5MG/L)

Incident Category:

Category 1

Approximate Start of Incident:

25/10/2022 09:15

First Noticed:

03/11/2022 00:00

Still Ongoing:

Yes

New or Recurring Incident:

Recurring

Incident Nature:

Other

Impact of Incident on Environment:

NONE

Uncontrolled Release to Receptors:

Sewer

Details of any Vulnerable Receptors:

NONE

Likely Cause:

Leachate management

Incident Location

Licensed Discharge Point: No

Location Description: Balance Tank

Emission Parameter Results

Communication

EPA Informed by Telephone: No

EPA Informed Date:

EPA Informed Staff Member:

EPA Informed Contact Details:

Other Communications:

Additional Details

Activity in Process at time of incident:

leachate treatment

Corrective Actions Taken:

Action	Name	Date
have applied to IRISH WATER TO CHANGE PARAMETERS FOR SEWER DISCHARGE AND WILL BE APPLYING FOR TECHNICAL AMENDMENT IN DEC 22 TO EPA ALSO THE REASON REPORTING OF INCIDENT IS LATE IS BECAUSE TMS LAB. HAD COVID OUT BREAK period appears to be 27th October – 21st November		01/12/2022 10:14

Preventive Actions to be Taken:

Action	Target Date
HAVE DAILY SAMPLING HERE IN LAB IN ARTHURSTOWN	01/12/2022 00:00

Likelihood of Recurrence: Medium

Other Relevant Information

TMS LAB. HAD COVID OUT BREAK period appears to be 27th October – 21st November

